



Central Valley Regional Water Quality Control Board

10 September 2021

WDID: 5A520104001

Martha Slack
Rio Alto Water District
22099 River View Drive
Cottonwood, CA 96022

CERTIFIED MAIL:
7017 3380 0000 2868 8696

REQUEST FOR REDUCTION IN GROUNDWATER MONITORING AND REPORTING PROGRAM, RIO ALTO WATER DISTRICT WASTEWATER TREATMENT FACILITY, WASTE DISCHARGE REQUIREMENTS ORDER R5-2016-0033, TEHAMA COUNTY

The Central Valley Regional Water Quality Control Board (Central Valley Water Board) has reviewed your 30 September 2020 *Request for Review of Proposed Reduction in Groundwater Monitoring Letter* prepared by your consultant Lawrence and Associates (Consultant). The letter is requesting a reduction in the frequency of groundwater monitoring associated with Rio Alto Water District's wastewater treatment facility (Facility) located in Cottonwood, Tehama County. The Facility is currently regulated by the Central Valley Water Board under Waste Discharge Requirements Order R5-2016-0033 (WDRs), adopted on 21 April 2016.

The current Monitoring and Reporting Program (MRP) requires groundwater monitoring on a quarterly basis for groundwater depth and gradient, Eh, pH, total nitrogen, ammonia, nitrite, nitrate, EC, total coliform organisms, total dissolved solids, total Kjeldahl nitrogen, turbidity, standard minerals, and metals. The Discharger is requesting quarterly monitoring for groundwater depth and gradient; semiannual monitoring for Eh, pH, EC, turbidity, chloride, nitrate, total coliform organisms, and total dissolved solids; and annual monitoring for nitrogen series, standard minerals, and metals; as well as cease monitoring for cadmium, lead, thallium, mercury, copper, dissolved iron, nickel, and selenium.

Central Valley Water Board staff does not have any objections to the proposed reduction in the frequency of groundwater monitoring and reporting requirements.

Please see the enclosed Amended Monitoring and Reporting Program R5-2016-0033.

KARL E. LONGLEY SCD, P.E., CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

364 Knollcrest Drive, Suite 205, Redding, CA 96002 | www.waterboards.ca.gov/centralvalley

If you have any questions, please contact Valerie Rasmussen by mail, at the footer address at the bottom of this notice, by phone at (530) 224-6130, or by email at Valerie.Rasmussen@waterboards.ca.gov.



Clint E. Snyder, P.G.
Assistant Executive Officer

VMR: cc

Enclosure: Technical Memorandum
 Amended Monitoring and Reporting Program Order R5-2016-0033