



California Regional Water Quality Control Board Central Valley Region

Katherine Hart, Chair



Arnold
Schwarzenegger
Governor

Linda S. Adams
Secretary for
Environmental
Protection

11020 Sun Center Drive #200, Rancho Cordova, California 95670-6114
Phone (916) 464-3291 • FAX (916) 464-4645
<http://www.waterboards.ca.gov/centralvalley>

17 June 2010

Mr. Greg Stanton, Deputy Director
El Dorado County
Environmental Management Department
2850 Fairlane Ct. Building C
Placerville, CA 95667


***FLOW RATE INCREASE REQUEST, EL DORADO ENVIRONMENTAL MANAGEMENT
DEPARTMENT, UNION MINE SEPTAGE/LEACHATE TREATMENT FACILITY,
EL DORADO COUNTY***

Thank you for your letter dated on 3 May 2010 regarding El Dorado County's (Discharger) request to increase the monthly average inflow limit of Order No. R5-2006-0019 for Union Mine Septage/Leachate Treatment Facility (Union Mine Facility). Central Valley Water Quality Control Board staff have reviewed the *Request to Increase Monthly Average Influent Flows Report* attached to your letter and determined it is in accordance with the following:

Provision G.1. a. of Order No. R5-2006-0019 allows the Discharger to submit a report to the Executive Officer for the approval of increased monthly average inflow limit from 10,500 gallons per day (gpd) to 16,000 gpd once the Discharger obtains a permit with El Dorado Irrigation District (EID) to discharge wastewater to the EID municipal sewer system. The Discharger has obtained EID Permit DC 09-155, which became effective 1 October 2009. The EID Permit allows the Union Mine Facility to discharge treated wastewater to the EID Deer Creek Wastewater Treatment Plant with a maximum flow rate of 144,000 gpd, five days a week, Monday through Friday.

Based on the provided documents, the discharge to the EID municipal sewer system provides the additional disposal capacity required by the proposed inflow rate of 16,000 gpd. Therefore, the monthly average inflow limit for the Union Mine Septage/Leachate Treatment Facility is hereby increased to 16,000 gallons per day.

If you have any questions on this information please contact Ms. Mary Serra at (916) 464-4732 or mserra@waterboards.ca.gov.

for 
Pamela C. Creedon
Executive Officer

California Environmental Protection Agency