
Central Valley Regional Water Quality Control Board

12 February 2020

WDID: 5A320104004

Mr. John Rowden
PECSD Board Members
Plumas Eureka CSD
200 Lundy Lane
Blairsden, CA 96103-9713

CERTIFIED MAIL:
7018 1130 0001 8556 4606

Three Trees Holdings II LLC, and
Plumas Pines Golf Resort
402 Poplar Valley Road
Cromberg, CA 96103

CERTIFIED MAIL
7018 1130 0001 8556 4590

**NOTICE OF APPLICABILITY, WATER QUALITY ORDER 2014-0153-DWQ-R5332,
PLUMAS EUREKA COMMUNITY SERVICES DISTRICT AND THREE TREES
HOLDING II LLC, WASTEWATER TREATMENT AND DISPOSAL FACILITIES,
PLUMAS COUNTY**

On 8 October 2018, Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff inspected the wastewater facilities at Plumas Eureka Community Services District (PECSD). PECSD owns and operates two wastewater treatment facilities (WWTP #6 and #7) each with its own backup leachfield. PECSD leases property owned by Plumas Pines Golf Resort and Three Trees Holding II LLC where WWTP #6 and #7 wastewater's primary disposal is to a community leachfield named Dynamite Hill. PECSD and Three Trees Holding II LLC are hereafter jointly referred to as "Discharger".

PECSD's District office is located inside the Fire Department building at 200 Lundy Lane, Blairsden, Plumas County. The wastewater treatment facilities and disposal systems are located on both sides of Poplar Valley Road, Blairsden, Plumas County (see Location Map, Attachment A). Based on the site inspection and a case file review, the Discharger treats and disposes equal to or less than 100,000 gallons of wastewater per day and is therefore eligible for coverage under the general and specific conditions of State Water Resources Control Board (State Water Board) Water Quality Order 2014-0153-DWQ General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems (General Order). This letter serves as formal notice that the General Order is applicable to your facility and the wastewater discharge described below. You are hereby assigned General Order 2014-0153-DWQ-R5332 for your facility.

You can also find the General Order on the [State Water Board's Adopted Orders web page](http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf) (http://www.waterboards.ca.gov/board_decisions/adopted_orders/water_quality/2014/wqo2014_0153_dwq.pdf).

You should familiarize yourself with the entire General Order and its attachments, attached to this letter, which prescribes mandatory discharge and monitoring requirements. Sampling, monitoring, and reporting requirements that are applicable to your treatment and disposal methods must be completed in accordance with the sections of the General Order and the attached Monitoring and Reporting Program (MRP). This MRP was developed after consideration of your treatment system infrastructure and site conditions described in the attached Technical Memorandum.

REGULATORY BACKGROUND

The Discharger's wastewater treatment and disposal systems are currently regulated under the individual Waste Discharge Requirements (WDRs) Order 98-007. The WDR was adopted on 23 January 1998 and is due for an update.

FACILITY AND DESCRIPTION

The Discharger owns and operates two WWTPs, two backup leachfields and a community leachfield located throughout a golf course and residential community located in Sections 4, 5, 8 and 9, T22N, R12W, MDB&M, with surface water drainage to the Feather River (see Facility Map, Attachment B). PECSD has been established as the entity responsible for the daily operation and maintenance of the WWTP systems.

This is an existing facility, therefore enrollment under the General Order is categorically exempt from the California Environmental Quality Act (CEQA) pursuant to California Code of Regulations, title 14, section 15301 which applies to ongoing or existing projects.

FACILITY SPECIFIC REQUIREMENTS

The Discharger will maintain exclusive control over the discharge and shall comply with the terms and conditions of this Notice of Applicability (NOA) and the General Order 2014-0153-DWQ-R5332, with all attachments.

The General Order states in Section B.1.L that the discharger shall comply with the setbacks as described in Table 3. The following applicable setback requirements from Table 3, for which the Discharger shall comply, are summarized below:

Table 3: Summary of Wastewater System Setbacks

The following table has been adapted from Table 3 of the General Order and only include setback requirements for specific equipment or activities applicable to the subject facility. Table notes are not in alphabetical order due to the way they were formatted in the General Order.

N/A denotes Not Applicable, as the defined feature is not found within the general area of the facility.

Equipment or Activity	Domestic Well	Flowing Stream (see a below)	Ephemeral Stream Drainage (see b below)	Property Line	Lake or Reservoir (see d. below)
Septic Tank, Aerobic Treatment Unit, Treatment System, or Collection System (see e below)	150 ft. (see y below) 100 ft (see o below) 50 ft (see c below)	50 ft. (see c below)	50 ft.	5 ft. (see c below) (see z below)	200 ft. (see w below) 50 ft (see c below)
Leach Field (see f below)	100 ft (see o below) (see c below)	100 ft (see c below)	50 ft	5 ft. (see c below)	200 ft. (see w below) 100 ft (see c below)
LAND APPLICATION AREA REQUIREMENTS					
Spray Irrigation (disinfected tertiary recycled water) (see k below)	No spray irrigation of any recycled water, other than disinfected tertiary recycled water, shall take place within 100 feet of a residence or a place where public exposure could be similar to that of a park, playground, or school yard				

Table Notes:

- a A flowing stream shall be measured from the ordinary high-water mark established by fluctuations of water elevation and indicated by characteristics such as shelving, changes in soil character, vegetation type, presence of litter or debris, or other appropriate means.
- b Ephemeral Stream Drainage denotes a surface water drainage feature that flows only after rain or snowmelt and does not have sufficient groundwater seepage (baseflow) to maintain a condition of flowing surface water. The drainage shall be measured from a line that defines the limit of the ordinary high-water mark (described in “a” above). Irrigation canals are not considered ephemeral streams drainage features. The ephemeral stream shall be a “losing stream” (discharging surface water to groundwater) at the proposed wastewater system site.
- c Setback established by California Plumbing Code, Table K-1.
- d Lake or reservoir boundary measured from the high-water line.
- e Septic Tank, Aerobic Treatment Unit, Treatment System, or Collection System addresses equipment located below ground or that impedes leak detection by routine visual inspection.
- f Leach Field includes all subsurface dispersal systems, including mound systems except seepage pits.
- k Additional restrictions for spray irrigation of recycled water are contained in California Code of Regulations, title 22, section 60310(f)
- o California Well Standards, part II, section 8. Site-specific conditions may allow reduced setback or require an increased setback. See discussion in Well Standards.
- w Setback established by the Onsite Wastewater Treatment System Policy, section 7.5.5.
- y Setback established by Onsite Wastewater Treatment System Policy, section 7.5.6.
- z Collection system to property line setback is not applicable.

The General Order also states in Section E.4.a that the Discharger shall comply with the MRP issued with the NOA. The MRP issued with this NOA requires the monitoring of the facility's trickling filter system, aerobic treatment system, disposal areas, solids disposal, french drains, groundwater monitoring well network and receiving waters (see Monitoring Location Map, Attachment C).

Failure to comply with the requirements in the documents could result in an enforcement action as authorized by provisions of the California Water Code. Discharge of wastes other than those described in this NOA is prohibited. If the method of waste disposal changes from that described in this NOA, you must submit a new Report of Waste Discharge describing the new operation.

The required annual fee specified in the annual billing from the State Water Board shall be paid until this NOA is officially terminated. You must notify this office in writing if the discharge regulated by the General Order ceases, so that we may terminate coverage and avoid unnecessary billing.

Facility Information

Facility Name	Plumas Eureka CSD
Program	WDR
Order Number	R5-2014-0153-R5332
WDID	5A320104004
Design Flow	100,000
Threat and Complexity	2B
Monitoring Requirements	Monthly, Quarterly, Annual

Billing Information

Name	Plumas Eureka CSD
Contact	John Rowden
Email	John.rowden@digitalpath.net
Address	200 Lundy Lane, Blairsden, CA 96103
Phone	(530) 836 - 1953

The Central Valley Water Board has gone to a Paperless Office System. All regulatory documents, MRPs, submissions, materials, data, monitoring reports, and correspondence should be converted to a searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50MB should be emailed to the following email address centralvalleyredding@waterboards.ca.gov.

12 February 2020

Documents that are 50MB or larger should be transferred to a disc and mailed to the appropriate regional water board office, in this case 364 Knollcrest Drive, Suite 205, Redding, CA 96002.

To ensure that your submittals are routed to the appropriate staff, the following information block should be included in any email used to transmit documents to this office:

Program: Non-15

WDID: 5A320104004

Facility Name: Plumas Eureka CSD

Order: 2014-0153-DWQ-R5332

Please note that WDRs Order No. 98-007 is proposed to be rescinded at the 16/17 April 2020 meeting of the Central Valley Water Board. Upon rescission of your individual WDRs, coverage for your facility under the General Order shall become applicable and subject to this NOA.

If you have any questions regarding submitting an updated report of waste discharge, making changes to your permitted operations, compliance or enforcement please contact Heidi Bauer by phone at (530) 224-4996, by email at heidi.bauer@waterboards.ca.gov, or at the footer address located on the first page of this correspondence.

Original signed by Bryan J. Smith for
PATRICK PULUPA, Executive Officer

HB: ch

Attachments: Attachment A – Site Location Map
Attachment B – Facility Map
Attachment C – Monitoring Location Map
Technical Memorandum
Monitoring and Reporting Program
General Order 2014-0153-DWQ

cc without enclosures:

Plumas County Environmental Health Department, Quincy
Tim O'Brien, State Water Board, Sacramento
David Lancaster, SWRCB, Office of Chief Counsel, Sacramento