



CHENNAI METROPOLITAN WATER SUPPLY AND SEWERAGE BOARD  
QUALITY ASSURANCE WING, WATER ANALYSIS LABORATORY  
NEW AVADI ROAD, CHENNAI - 600 010.

RESULTS OF PHYSICAL AND CHEMICAL EXAMINATION

DRINKING PURPOSE

|     |                                  |              |            |
|-----|----------------------------------|--------------|------------|
| To: | P.S.Senior Secondary School      | Challan No   | 94         |
|     | No.33,Alarmelmangapuram,Mylapore | Challan Date | 12.05.2023 |
|     | Chennai-04                       | Amount(Rs)   | 200/-      |

|                         |                             |
|-------------------------|-----------------------------|
| Water Sample No/ Source | Bore Well Water             |
| Sample sent by          | P.S.Senior Secondary School |
| Date of Collection      | 12.05.2023                  |
| Location                | Chennai-04                  |

| S.No | Parameter Name                                               | Result             | IS:10500-2012<br>Acceptable Limit | IS:10500-2012<br>Permissible Limit in the<br>absence of alternate source |
|------|--------------------------------------------------------------|--------------------|-----------------------------------|--------------------------------------------------------------------------|
| 1    | Colour                                                       | Colourless & Clear | Colourless & Clear                | Colourless & Clear                                                       |
| 2    | Odour                                                        | Nil                | Agreeable                         | Agreeable                                                                |
| 3    | Turbidity (N.T.U)                                            | 2.0                | 1                                 | 5                                                                        |
| 4    | Total Dissolved Solids at 105 °C (mg/l)                      | 60                 | 500                               | 2000                                                                     |
| 5    | Calcium ( As Ca) (mg/l)                                      | 5.2                | 75                                | 200                                                                      |
| 6    | Magnesium (As Mg) (mg/l)                                     | 1.9                | 30                                | 100                                                                      |
| 7    | Total Hardness(As CaCO <sub>3</sub> ) (mg/l)                 | 21                 | 200                               | 600                                                                      |
| 8    | Chlorides (As Cl) (mg/l)                                     | 15                 | 250                               | 1000                                                                     |
| 9    | Ammoniacal Nitrogen (as N) (mg/l)                            | 0.04               | 0.5                               | No relaxation                                                            |
| 10   | Albuminoid Nitrogen (as N) (mg/l)                            | 0.048              | 0.5                               | No relaxation                                                            |
| 14   | Nitrous Nitrogen (As N) (mg/l)                               | Nil                | -                                 | -                                                                        |
| 12   | Oxygen absorbed (Tidy's 4 hours test)(mg/l)                  | 1.05               | -                                 | -                                                                        |
| 13   | Hydrogen Ion Concentration (pH)                              | 6.5                | 6.5 TO 8.5                        | 6.5 TO 8.5                                                               |
| 14   | Alkalinity to Phenolphthalein (AS CaCO <sub>3</sub> ) (mg/l) | Nil                | Nil                               | 0                                                                        |
| 15   | Alkalinity to methyl orange (As CaCO <sub>3</sub> ) (mg/l)   | 24                 | 200                               | 600                                                                      |
| 16   | Sulphates (As SO <sub>4</sub> ) (mg/l)                       | 6                  | 200                               | 400                                                                      |
| 17   | Phosphates (as PO <sub>4</sub> ) (mg/l)                      | 0.01               | -                                 | -                                                                        |
| 18   | Iron (As Fe) (mg/l)                                          | Trace              | 0.3                               | No relaxation                                                            |
| 19   | Fluorides (as F) mg/l)                                       | 0.1                | 1.0                               | 1.5                                                                      |
| 20   | Specific Conductance(micro Siemens/cm) at 25°C               | 90                 | -                                 | -                                                                        |

**Report** The Water Sample tested for the above parameters are within the Permissible Limit of Drinking Water Standard. Hence it is Suitable for drinking purpose after boiling to ensure hygienic safety.

**Observation;**Suitable for Drinking purpose.

M. Sudha  
23/05/23  
WATER ANALYST

23/5/23  
CHIEF ANALYST

23/05/2023  
EXECUTIVE ENGINEER (QA)