

TOTAL SAMPEL GARDU

1 Unit

Semua data sesuai filter

OVERLOAD (> 80%)

0 Unit

0% dari total gardu aktif

NORMAL (40 - 80%)

1 Unit

100% kapasitas optimal

UNDERLOAD (< 40%)

0 Unit

Potensi relokasi kapasitas

INDIKATOR KESEHATAN

Rata2 Beban: 75%

Rata2 Unbalance: 8%

Arde >5©: undefined Unit

Parameter Filter: ULP: | Penyulang: | Status: undefined | Kapasitas: undefined kVA

No	Nama Gardu	ULP	Penyulang	kVA	% Beban	Status	% Unb	Arus R/S/T (A)	Arus N (A)	V (FN/FF)	Arde	Koordinat GPS
1	GDU001	ULP Bulukumba	KRL01	100	75%	NORMAL	8%	50/55/52	5	220/380	3 . 5	-5.5000, 120.2000