Company:		Inspection date:	
Project:		Location:	
Inspected by:			

SN	General Workplace Inspection Checklist	Compliance		Findings
		Y	N	
1	Is a properly sized, inspected and stocked First Aid Kit available on the job site?			
2	Is fall protection selected based on a hazard analysis of the planned work, known hazards and specific work location?			
3	Are all portable cord and plug type electrical tools used with a portable GFCI?			
4	Are flexible cord used on the job site of a properly rated and listed to support the load required?			
5	Is the site cleaned-up at a regular intervals and at the end of shift?			
6	Are aerial lifts inspected prior to use and maintained in accordance with the manufacturer's recommendations for safe use of the equipment?			
7	Is fall protection equipment stored and maintained in accordance with the requirements outlined in the fall protection program?			
8	Are ladders maintained in good usable condition at all times?			
9	Are walkways kept clear of cords, hoses or materials that could trip personnel?			
10	Are employees using the ladders maintaining 3-points of contact/control while climbing the ladder?			
11	Are warning signs, flags, traffic control devices/ barriers and flaggers in place when working near vehicular traffic?			
12	If required, is the scaffold system secured/ tied to the wall or structure at the proper intervals? (30' horizontal/24' vertical)			

13	Are scaffolds used at the work site inspected and tagged after erection and at least every 7 days thereafter by a competent person?			
14	Has each employee who works on a scaffold been trained by a competent person on hazards and procedures used to control hazards?			
15	Are portable fire extinguishers fully charged, inspected monthly and serviced annually?			
16	Are skylights and roof openings covers guarded? And constructed to hold at least 200 pounds?			
17	Are floor and wall openings guarded by a cover, guardrail or equivalent (except at in trance to stairways and ladders)?			
18	For multi-story work sites is water available on every floor, and located as close as practicable to areas where employees are working?			
19	Are only authorized and trained personnel permitted to use welding, cutting or brazing equipment?			
20	Are cylinders located or stored in areas where they will not be damaged by passing or falling objects or subjects to tempering by unauthorized persons?			
21	Is at least a 10-foot safe working clearance from overhead power lines maintained by workers or cranes?			
22	If using cranes, are precautions in place to not fly loads over workers or occupied structures?			

Remarks: