

STATUS: CRITICAL - RESOLVED

Incident Report

Title: INC-2840 - Lagos West Power Cluster Failure

Date: 2026-04-28

Severity: CRITICAL

Status: RESOLVED

1. Executive Summary

On 2026-04-28, the IKEDC sector 7 grid experienced a feeder fault resulting in 3 towers offline within 90 seconds. The outage impacted approximately 38,400 subscribers across Lagos West. Service was restored after manual genset intervention and coordination with IKEDC NOC.

2. Timeline of Events

Time	Event	Actor
14:12	Grid alarm detected	System
14:13	TWR-LAG-W-014 (Surulere) offline	System
14:14	Auto-genset inhibited (maintenance flags on 2 sites)	System
14:21	Manual genset start completed	field-team-1
14:27	All towers restored	NOC

3. Root Cause

The incident was caused by an IKEDC sector 7 feeder fault combined with maintenance flags on two sites, which blocked automatic genset failover. This led to simultaneous outages across multiple towers in Lagos West.

4. Impact Assessment

Tower Code	Signal (%)	Load (%)	Subscribers Impacted
TWR-LAG-W-014 (Surulere)	0	0	12,800
TWR-LAG-W-022 (Mushin)	0	0	13,200
TWR-LAG-W-031 (Yaba North)	0	0	12,400

Total Subscribers Impacted: 38,400

5. Resolution

- Manual genset start executed by field-team-1 at 14:21.
- All towers restored by 14:27.
- IKEDC NOC notified via API integration for feeder fault escalation.

6. Policy Change

Effective immediately:

- Clusters with more than 2 towers on the same feeder must maintain a minimum 12-hour fuel reserve to ensure resilience against grid instability.

7. Sign-off

Prepared by: tunde.b (Admin)

Reviewed by: amaka.o (NOC Manager)