

Power Availability Report - Lekki Cluster, Q1 2026

Document Code: PAR-LEK-Q1-2026

Prepared by: Babatunde Okafor

Reviewed by: Amaka Obi

Submission Date: April 5, 2026

1. Power Source Summary

Tower	Grid %	Generator %	Battery %	Uptime %
TWR-LEK-003	71%	27%	2%	96.2%
TWR-LEK-008	79%	19%	2%	97.8%
TWR-LEK-014	85%	14%	1%	99.1%

2. Monthly Breakdown (Jan-Mar 2026)

Tower	Jan Grid	Jan Gen	Jan Out	Feb Grid	Feb Gen	Feb Out	Mar Grid
TWR-LEK-003	510	200	9	520	180	8	530
TWR-LEK-008	540	160	7	550	150	6	560
TWR-LEK-014	580	120	5	590	110	4	600

3. Notable Power Events Log

Jan 12, 2026 - TWR-LEK-003
Generator ran for 6 hours continuously due to EKEDC feeder fault.

Feb 8, 2026 - TWR-LEK-008
Generator operated for 5.5 hours following scheduled grid maintenance.

Mar 21, 2026 - TWR-LEK-014
Generator ran for 4.2 hours due to transformer trip at Lekki Phase 1 substation.

4. EKEDC Performance

Lekki cluster is served by EKEDC. Overall feeder reliability recorded at 78% in Q1 2026.

5. Generator Health

Tower	Last Service	Next Due	Hours Since	Condition
TWR-LEK-003	Jan 5, 2026	Apr 5, 2026	410	Good
TWR-LEK-008	Jan 12, 2026	Apr 12, 2026	380	Good
TWR-LEK-014	Feb 2, 2026	May 2, 2026	320	Good

6. Battery Bank Status

Power Availability Report - Lekki Cluster, Q1 2026

TWR-LEK-003: 82% health - Good

TWR-LEK-008: 74% health - Monitor

TWR-LEK-014: 91% health - Good

7. Fuel Efficiency

Average generator fuel consumption per site: 3.8 L/h

8. Cost Summary

Total generator fuel cost across Lekki cluster in Q1 2026: NGN 14,280,000

9. Sign-off

Prepared by:

Babatunde Okafor

Power/Generator Technician

Reviewed by:

Amaka Obi

NOC Manager

Date: April 5, 2026