

MTN Nigeria

Fuel Consumption Report - Lagos West Cluster, April 2026

Document Code: FUEL-LAGW-APR2026

Prepared by: Babatunde Okafor (Power Technician)

Reviewed by: Amaka Obi (NOC Manager)

Submission Date: May 2, 2026

1. Summary Table

Tower	Grid Hours	Generator Hours	Fuel Used (L)	Cost (N)	Refuels
TWR-LAG-W-014	312h	408h	1,840L	N3,312,000	6
TWR-LAG-W-022	498h	222h	890L	N1,602,000	3
TWR-LAG-W-031	541h	179h	720L	N1,296,000	2

2. April Generator Run Log

Date	Tower	Reason	Start	Stop	Hours	Fuel Used
Apr 02	TWR-LAG-W-014	IKEDC outage	08:12	11:45	3.5	160L
Apr 05	TWR-LAG-W-022	Grid fluctuation	14:20	16:05	1.8	70L
Apr 09	TWR-LAG-W-031	Scheduled grid work	09:00	12:30	3.5	140L
Apr 14	TWR-LAG-W-014	IKEDC feeder trip	19:10	22:00	2.8	120L
Apr 18	TWR-LAG-W-022	Grid outage	07:45	10:15	2.5	100L
Apr 22	TWR-LAG-W-031	Grid instability	13:00	15:20	2.3	95L
Apr 28	TWR-LAG-W-014	INC-2840 cluster failure	05:30	14:00	8.5	380L
Apr 28	TWR-LAG-W-022	INC-2840 cluster failure	05:30	14:00	8.5	360L
Apr 28	TWR-LAG-W-031	INC-2840 cluster failure	05:30	14:00	8.5	320L

3. IKEDC Outage Events That Triggered Generator

- Apr 02 - 3.5h - TWR-LAG-W-014
- Apr 05 - 1.8h - TWR-LAG-W-022
- Apr 09 - 3.5h - TWR-LAG-W-031
- Apr 14 - 2.8h - TWR-LAG-W-014

- Apr 18 - 2.5h - TWR-LAG-W-022
- Apr 22 - 2.3h - TWR-LAG-W-031
- Apr 28 - 8.5h - Cluster-wide (TWR-LAG-W-014, TWR-LAG-W-022, TWR-LAG-W-031)

4. Fuel Delivery Log

Date	Supplier	Litres	Cost/Litre	Invoice No
Apr 04	Total Nigeria	600L	N1,800	INV-APR-041
Apr 12	Oando Plc	800L	N1,800	INV-APR-122
Apr 20	Total Nigeria	700L	N1,800	INV-APR-203
Apr 27	Oando Plc	1,350L	N1,800	INV-APR-274
Apr 29	Total Nigeria	1,000L	N1,800	INV-APR-295

5. Budget vs Actual

- Budget: N4,500,000
- Actual: N6,210,000
- Variance: N1,710,000 over

Explanation: Overrun caused by INC-2840 IKEDC cluster failure on April 28, which required extended generator operation across three towers.

6. Observation

TWR-LAG-W-014 generator operated for 57% of April, the highest in the Lagos West cluster. Escalation to IKEDC is recommended to address recurring feeder instability.

7. Next Month Forecast

Based on April actuals, estimated May fuel requirement: 6,000L with projected cost of N10,800,000 (assuming N1,800/L).

8. Sign-off

Prepared by:

Babatunde Okafor

Power/Generator Technician, MTN Nigeria

Reviewed by:

Amaka Obi

NOC Manager, MTN Nigeria