

Site Visit Report - TWR-LAG-W-014 Generator Emergency Start

Document Code: SVR-LAGW014-20260428

Site: TWR-LAG-W-014 (Surulere)

Date: April 28, 2026

Time: 14:18 - 15:30 WAT

Engineer: Babatunde Okafor, Power Technician

Approved by: Amaka Obi, NOC Manager

1. Purpose

Emergency generator manual start due to auto-failover inhibited by maintenance flag.

2. Grid Status on Arrival

IKEDC sector 7 feeder was completely down. No ETA was provided by IKEDC for restoration.

3. Generator State Found

Generator was healthy but locked by a maintenance flag set three days prior for scheduled service that was never completed.

4. Actions Taken

1. Obtained authorisation from Amaka Obi at 14:19 to override maintenance flag.
2. Manually cleared flag and initiated generator start sequence.
3. Verified generator parameters: oil pressure, coolant temperature, fuel level, and output voltage.
4. Confirmed all radio equipment powered up and stable.

5. Generator Parameters

Parameter	Value
Fuel Level	68%
Oil Pressure	4.2 bar

Site Visit Report - TWR-LAG-W-014 Generator Emergency Start

Coolant Temp	82°C
Output Voltage	415 V
Load	72 kW

6. Fault Root Cause

Maintenance flag was not cleared after scheduled service was cancelled on April 25.

7. Fuel Assessment

Fuel level at 68% will sustain approximately 9.4 hours of operation. Emergency fuel delivery requested for 12-hour top-up.

8. Additional Observations

Battery bank on site measured at 61% health. Recommended replacement during next scheduled maintenance visit.

9. Time Log

Event	Timestamp (WAT)
Arrival on site	14:18
Authorisation received	14:19
Generator started	14:23
Parameters verified	14:30
Radio equipment stable	14:35
Departure	15:30

10. Recommendations for Corrective Action

Policy update required: maintenance flags must be cleared within 24 hours of service cancellation to prevent auto-failover inhibition.

Site Visit Report - TWR-LAG-W-014 Generator Emergency Start

11. Sign-off

Engineer: Babatunde Okafor

Role: Power Technician

Signature: Babatunde Okafor

Date: 2026-04-28

Approved by: Amaka Obi

Role: NOC Manager

Signature: Amaka Obi

Date: 2026-04-28