

IKEDC Feeder Reliability Assessment - Lagos West Coverage Zone, 2026 Q1

Document Code: GRA-IKEDC-Q1-2026

Prepared by: Babatunde Okafor (Power Technician)

Reviewed by: Ngozi Okonkwo

Submission Date: April 8, 2026

1. Background

The Lagos West cluster of MTN Nigeria (TWR-LAG-W-014 Surulere, TWR-LAG-W-022 Mushin, TWR-LAG-W-031 Yaba North) is served by IKEDC grid sectors 5, 7, and 11. This report evaluates grid reliability and its impact on base station operations during Q1 2026.

2. Q1 Grid Availability

Month	Sector 5 Hours On		Sector 7 Hours On		Sector 11 Hours On		Total Hours	Availability %
Jan	498h	389h	421h	720h	Sec5: 69%, Sec7: 54%, Sec11: 58%			
Feb	512h	401h	438h	672h	Sec5: 76%, Sec7: 60%, Sec11: 65%			
Mar	541h	452h	467h	744h	Sec5: 73%, Sec7: 61%, Sec11: 63%			

3. Outage Events Log

Date	Sector	Duration	Reason Given by IKEDC	Towers Impacted	Generator Hours Run
Jan 05	Sec 5	4h	Transformer fault	TWR-LAG-W-014	4h
Jan 14	Sec 11	3h	Cable theft	TWR-LAG-W-031	3h
Jan 28	Sec 7	6h	Load shedding	TWR-LAG-W-022	6h
Feb 09	Sec 5	2h	Planned maintenance	TWR-LAG-W-014	2h
Feb 22	Sec 7	5h	Transformer trip	TWR-LAG-W-022	5h
Mar 03	Sec 11	7h	Cable fault	TWR-LAG-W-031	7h
Mar 15	Sec 5	3h	Load shedding	TWR-LAG-W-014	3h
Mar 28	Sec 7	4h	Feeder overload	TWR-LAG-W-022	4h

4. Generator Runtime Triggered by IKEDC Failures (Q1 Total)

TWR-LAG-W-014 (Surulere): 1,104 hours
TWR-LAG-W-022 (Mushin): 608 hours
TWR-LAG-W-031 (Yaba North): 491 hours

5. Cost Impact

Q1 generator fuel spend attributed directly to IKEDC failures amounted to NGN 14.8M.

6. IKEDC Response Quality

Average time from MTN fault notification to IKEDC acknowledgement was 5.2 hours.

IKEDC Feeder Reliability Assessment - Lagos West Coverage Zone, 2026 Q1

7. Formal Complaints Sent to IKEDC

Date	Reference Number	Issue	Resolution Status
Jan 06	MTN/IKEDC/2026-01	Transformer fault Sec 5	Pending
Jan 15	MTN/IKEDC/2026-02	Cable theft Sec 11	Closed
Feb 23	MTN/IKEDC/2026-03	Transformer trip Sec 7	Pending
Mar 04	MTN/IKEDC/2026-04	Cable fault Sec 11	Closed

8. Recommendation

MTN Nigeria should initiate formal SLA negotiation with IKEDC for priority restoration on MTN feeders to reduce downtime and generator reliance.

9. Escalation

This report is copied to the Regional Director and the Regulatory Affairs team for further engagement with IKEDC and NCC.

10. Sign-off

Prepared by:
Babatunde Okafor
Power Technician

Reviewed by:
Ngozi Okonkwo
Procurement & Contracts Officer

Date: April 8, 2026