

STATUS: CRITICAL

Lagos West Power Outage Pattern - Last 90 Days

Date: 2026-05-01 Region: Lagos West

1. Executive Summary

A total of 14 power-related outages were recorded in Lagos West over the past 90 days. The most affected areas were IKEDC sectors 5, 7, and 11, with sector 7 showing the highest exposure. These outages significantly impacted service availability across key towers including TWR-LAG-W-014, TWR-LAG-W-022, and TWR-LAG-W-031.

2. Monthly Breakdown

Month	Outages	Total Duration (hrs)	Subscribers Affected
February	4	6.2	38,000
March	6	9.5	54,200
April	4	5.8	36,100

3. IKEDC Feeder Reliability

Feeder Sector	Uptime (%)
Sector 5	72%
Sector 7	61%
Sector 11	68%

4. Tower-Feeder Mapping

The following towers are mapped to IKEDC Sector 7 feeder:

- TWR-LAG-W-014 (Surulere)
- TWR-LAG-W-022 (Mushin)
- TWR-LAG-W-031 (Yaba North)

5. Genset Performance

Auto-start success rate for gensets in Lagos West stood at 78%. Failures were primarily due to maintenance flag inhibitions that prevented automatic generator activation during grid outages.

6. New Policy Impact

The 12-hour fuel reserve policy implemented in February 2026 has led to a measurable reduction in average outage duration. March and April show improved recovery times compared to January.

STATUS: CRITICAL

7. OPEX Analysis

Power Option	Monthly OPEX (NGN)
Grid Supply (IKEDC)	3.2M
Diesel Genset (12h/day)	6.5M
Solar + Battery Hybrid	4.1M (after CAPEX amortization)

8. Recommendations

Deploy solar/battery hybrid power solution at TWR-LAG-W-014 (Surulere), the most exposed site in Lagos West. This will reduce dependency on unreliable grid supply and mitigate genset failure risks.