

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> NLE27 HACKNEY EAST			<b>Zone No.:</b> 343			<b>Population:</b> 83106		
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value (all samples)</b>			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015			<b>Min.</b>	<b>Mean</b>	<b>Max.</b>	<b>Total</b>	<b>Contra-vening</b>	<b>% of samples contravening PCV</b>
Coliform bacteria	no./100ml	0	0	0.022	3	228	2	0.9
<i>E. coli</i>	no./100ml	0	0	0	0	228	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	806	0	0
Colony count 22°C	cfu/ml	-	0	1.842	24	76	0	0
Colony count 37°C	cfu/ml	-	0	2.197	38	76	0	0
Residual Disinfectant	mg/l	-	0.28	0.611	0.85	228	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	0.8	1.334	4.1	76	0	0
Hydrogen Ion	pH	6.50-9.50	7.5	7.727	8	77	0	0
Turbidity	FTU	4	0.04	0.074	0.14	76	0	0
Conductivity at 20°C	uS/cm	2500	540	591.737	631	76	0	0
Ammonium as NH4	mg/l	0.5	0.11	0.179	0.25	77	0	0
Chloride as Cl	mg/l	250	35.79	45.178	54.77	9	0	0
Sodium as Na	mg/l	200	26.3	30.175	32.8	8	0	0
Sulphate as SO4	mg/l	250	41.7	46.744	51	9	0	0
Nitrate as NO3	mg/l	50	18.7	24.465	30.9	77	0	0
Nitrite as NO2	mg/l	0.5	<0.010	0.014	0.07	77	0	0
Nitrate/Nitrite calculation	mg/l	1	0.38	0.493	0.63	77	0	0
Total Organic Carbon as C	mg/l	-	1.5	2.124	3.1	72	0	0
Total Hardness as CaCO3	mg/l	N/A	254	264	270	3	0	0
Odour (quantatative)	dilution no.	0	0	0	0	40	0	0
Taste (quantatative)	dilution no.	0	0	0	0	40	0	0
Iron as Fe	ug/l	200	1.4	2.433	17.9	76	0	0
Manganese as Mn	ug/l	50	<0.200	0.77	0.9	76	0	0
Aluminium as Al	ug/l	200	<1.400	6.117	11	76	0	0
Antimony as Sb	ug/l	5	<0.700	<0.788	<0.800	8	0	0
Arsenic as As	ug/l	10	0.9	1.075	1.3	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.938	<1.200	8	0	0
Copper as Cu	mg/l	2	<0.004	0.029	0.156	8	0	0
Lead as Pb	ug/l	10	<0.200	0.4	1.3	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.087	<0.120	72	0	0
Nickel as Ni	ug/l	20	<1.300	<1.338	<1.600	8	0	0
Fluoride as F	mg/l	1.5	0.13	0.146	0.17	8	0	0
Selenium as Se	ug/l	10	<0.800	0.863	1.3	8	0	0
Boron as B	mg/l	1	0.049	0.059	0.069	8	0	0
Bromate as BrO3	ug/l	10	<0.700	1.015	2	72	0	0
Cyanide as CN	ug/l	50	<0.700	0.707	1.1	72	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	11.9	16.75	18.3	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	9	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.267	<0.300	9	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> NLE27 HACKNEY EAST			<b>Zone No.:</b> 343			<b>Population:</b> 83106		
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value</b> (all samples)			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	9	0	0
Atrazine	ug/l	0.1	<0.005	0.005	0.01	73	0	0
Bentazone	ug/l	0.1	<0.005	0.005	0.007	72	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	72	0	0
Carbetamide	ug/l	0.1	<0.003	0.004	0.008	73	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	73	0	0
Clopyralid	ug/l	0.1	<0.009	0.01	0.013	72	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	72	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	72	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.004	72	0	0
Diuron	ug/l	0.1	<0.003	0.003	0.01	73	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	72	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	73	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	72	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	73	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	72	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	72	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	72	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	72	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	72	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	72	0	0
Propyzamide	ug/l	0.1	<0.004	0.007	0.025	73	0	0
Simazine	ug/l	0.1	<0.005	0.005	0.007	73	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	72	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	72	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	72	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	72	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	73	0	0
Picloram	ug/l	0.1	<0.005	0.008	0.01	72	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	72	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	72	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	72	0	0
Carbendazim	ug/l	0.1	<0.002	0.006	0.259	73	1	1.4
Metaldehyde	ug/l	0.1	0.018	0.049	0.138	72	6	8.3
Metazachlor	ug/l	0.1	<0.002	0.003	0.015	72	0	0
Quinmerac	ug/l	0.1	<0.004	0.008	0.021	73	0	0
Total Pesticides	ug/l	0.5	0	0.069	0.354	75	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b>	NLE27    HACKNEY EAST	<b>Zone No.:</b>	343
		<b>Population:</b>	83106
<b>Time Period:</b> 01/01/2014 to 31/12/2014			
<b>Date extracted:</b> 10/04/2015			

**Commentary on Water Quality:**

Very good water quality, however six infringements to report for metaldehyde\*, one infringement to report for carbendazim and two infringements to report for coliforms. Our investigations showed the infringements for metaldehyde and carbendazim were transitory at our supplying assets and one infringement for coliforms was transitory and the other was due to customer plumbing. None of these infringements were indicative of the quality of water supplied to this zone.

**NOTES:**

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone

\* Metaldehyde is used by farmers to protect crops from slugs and snails. It can enter watercourses through 'run-off' from fields when rainfall occurs after slug pellets have been applied to agricultural land in the autumn.

Unlike other pesticides, metaldehyde is not easily removed from surface water by conventional treatment process, and as a result has been identified at levels which exceed the regulatory limit in treated water. These concentrations detected are well below levels that pose a risk to health.

Metaldehyde in treated water is an industry-wide issue which we are collectively working with our regulator, the Drinking Water Inspectorate, and users of metaldehyde in order to reduce the amount in water that is being treated.