

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: R43 COOKLEY GREEN			Zone No.: 298			Population: 1506		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		% of samples contravening PCV
Date extracted: 10/04/2015			(all samples)			Total	Contra-vening	
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	
Coliform bacteria	no./100ml	0	0	0	0	12	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	12	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	4	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	264	0	0
Colony count 22°C	cfu/ml	-	0	0	0	4	0	0
Colony count 37°C	cfu/ml	-	0	0	0	4	0	0
Residual Disinfectant	mg/l	-	0.15	0.25	0.42	12	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.200	<0.650	<0.800	4	0	0
Hydrogen Ion	pH	6.50-9.50	7.1	7.225	7.3	4	0	0
Turbidity	FTU	4	<0.040	<0.060	<0.070	4	0	0
Conductivity at 20°C	uS/cm	2500	558	562.75	569	4	0	0
Ammonium as NH ₄	mg/l	0.5	<0.030	<0.030	<0.030	4	0	0
Chloride as Cl	mg/l	250	16.74	21.018	24.64	4	0	0
Sodium as Na	mg/l	200	13.3	16.225	17.8	4	0	0
Sulphate as SO ₄	mg/l	250	13.7	23.175	30.4	4	0	0
Nitrate as NO ₃	mg/l	50	17.9	23.85	29.1	4	0	0
Nitrite as NO ₂	mg/l	0.5	<0.010	<0.010	<0.010	4	0	0
Nitrate/Nitrite calculation	mg/l	1	0.36	0.475	0.58	4	0	0
Total Organic Carbon as C	mg/l	-	0.4	0.691	1	11	0	0
Total Hardness as CaCO ₃	mg/l	N/A	298	302	305	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	2	0	0
Taste (quantatative)	dilution no.	0	0	0	0	2	0	0
Iron as Fe	ug/l	200	1.7	2.283	5.6	12	0	0
Manganese as Mn	ug/l	50	<0.200	<0.650	<0.800	4	0	0
Aluminium as Al	ug/l	200	<1.400	<2.950	<6.300	4	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	4	0	0
Arsenic as As	ug/l	10	0.3	0.35	0.4	4	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	4	0	0
Chromium as Cr	ug/l	50	<0.900	1.025	1.3	4	0	0
Copper as Cu	mg/l	2	<0.004	0.017	0.04	4	0	0
Lead as Pb	ug/l	10	<0.200	0.25	0.3	4	0	0
Mercury as Hg	ug/l	1	<0.090	<0.093	<0.120	11	0	0
Nickel as Ni	ug/l	20	<1.300	<1.375	<1.600	4	0	0
Fluoride as F	mg/l	1.5	0.088	0.135	0.185	4	0	0
Selenium as Se	ug/l	10	0.8	0.85	1	4	0	0
Boron as B	mg/l	1	0.019	0.034	0.044	4	0	0
Bromate as BrO ₃	ug/l	10	<0.700	0.755	1	11	0	0
Cyanide as CN	ug/l	50	<0.700	0.745	1.2	11	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	4	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	4	0	0
Trihalomethanes	ug/l	100	4.6	11.1	13.8	4	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	4	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	4	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.275	<0.300	4	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: R43 COOKLEY GREEN			Zone No.: 298			Population: 1506		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	4	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	12	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	10	0	0
Bromoxynil	ug/l	0.1	<0.005	<0.005	<0.005	10	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	12	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	12	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	10	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	10	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	10	0	0
Dichlorprop	ug/l	0.1	<0.003	<0.004	<0.004	10	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	12	0	0
Fluroxypyr	ug/l	0.1	<0.006	<0.006	<0.006	10	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	12	0	0
Ioxynil	ug/l	0.1	<0.005	<0.005	<0.005	10	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	12	0	0
Mecoprop	ug/l	0.1	<0.003	<0.008	<0.008	10	0	0
MCPA	ug/l	0.1	<0.004	<0.006	<0.006	10	0	0
MCPB	ug/l	0.1	<0.004	<0.004	<0.008	10	0	0
Pentachlorophenol	ug/l	0.1	<0.004	<0.004	<0.004	10	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	12	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	12	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	12	0	0
Simazine	ug/l	0.1	<0.005	0.006	0.012	12	0	0
2,4,5-T	ug/l	0.1	<0.005	<0.005	<0.005	10	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	12	0	0
2,4-DB	ug/l	0.1	<0.005	<0.005	<0.005	10	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	10	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	12	0	0
Picloram	ug/l	0.1	<0.005	<0.008	<0.008	10	0	0
Triclopyr	ug/l	0.1	<0.005	<0.005	<0.005	10	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	12	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	12	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	12	0	0
Metaldehyde	ug/l	0.1	<0.006	0.007	0.012	12	0	0
Total Pesticides	ug/l	0.5	0	0.007	0.015	12	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	R43	COOKLEY GREEN	Zone No.:	298
			Population:	1506
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone