

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SWA11 SLOUGH SOUTH			Zone No.: 153			Population: 45437		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		% of samples contravening PCV
Date extracted: 10/04/2015			(all samples)			Total	Contra- vening	
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra- vening	
Coliform bacteria	no./100ml	0	0	0.283	34	120	1	0.8
<i>E. coli</i>	no./100ml	0	0	0	0	120	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	261	0	0
Colony count 22°C	cfu/ml	-	0	2.026	41	38	0	0
Colony count 37°C	cfu/ml	-	0	0.895	18	38	0	0
Residual Disinfectant	mg/l	-	0.12	0.355	0.69	120	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	0.7	0.922	2.3	36	0	0
Hydrogen Ion	pH	6.50-9.50	7.1	7.219	7.4	36	0	0
Turbidity	FTU	4	<0.040	0.069	0.14	36	0	0
Conductivity at 20°C	uS/cm	2500	596	641.306	732	36	0	0
Ammonium as NH4	mg/l	0.5	<0.030	<0.030	<0.030	36	0	0
Chloride as Cl	mg/l	250	33.35	40.41	50.36	8	0	0
Sodium as Na	mg/l	200	22.8	28.013	39.9	8	0	0
Sulphate as SO4	mg/l	250	44.3	50.988	66.5	8	0	0
Nitrate as NO3	mg/l	50	10.3	20.7	25	8	0	0
Nitrite as NO2	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.21	0.414	0.5	8	0	0
Total Organic Carbon as C	mg/l	-	1.1	1.281	1.6	16	0	0
Total Hardness as CaCO3	mg/l	N/A	288	295	301	3	0	0
Odour (quantatative)	dilution no.	0	0	0	0	19	0	0
Taste (quantatative)	dilution no.	0	0	0	0	19	0	0
Iron as Fe	ug/l	200	<1.000	<1.944	<2.000	36	0	0
Manganese as Mn	ug/l	50	<0.200	<0.767	<0.800	36	0	0
Aluminium as Al	ug/l	200	<1.400	3.661	7.7	36	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	8	0	0
Arsenic as As	ug/l	10	<0.300	0.788	1.1	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.900	<0.900	8	0	0
Copper as Cu	mg/l	2	0.009	0.067	0.181	8	0	0
Lead as Pb	ug/l	10	<0.200	0.438	1.3	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.084	<0.090	16	0	0
Nickel as Ni	ug/l	20	<1.300	4.013	14.4	8	0	0
Fluoride as F	mg/l	1.5	0.145	0.279	0.709	8	0	0
Selenium as Se	ug/l	10	<0.800	1.775	3.9	8	0	0
Boron as B	mg/l	1	0.017	0.079	0.145	8	0	0
Bromate as BrO3	ug/l	10	<0.700	<0.700	<0.700	16	0	0
Cyanide as CN	ug/l	50	<0.700	<0.700	<0.700	16	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	7.1	12.013	20.9	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0.1	0.8	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SWA11 SLOUGH SOUTH			Zone No.: 153					
			Population: 45437					
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	16	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	16	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	16	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	16	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	16	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	16	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	16	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.005	<0.006	16	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	16	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	16	0	0
MCPA	ug/l	0.1	<0.002	<0.005	<0.006	16	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	16	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	16	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	16	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	16	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	16	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	16	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Picloram	ug/l	0.1	<0.005	0.008	0.009	16	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	16	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Metaldehyde	ug/l	0.1	0.009	0.016	0.026	16	0	0
Total Pesticides	ug/l	0.5	0	0.016	0.026	17	0	0
Gross alpha activity	Bq/l	0.1	<0.040	0.042	0.07	18	0	0
Gross beta activity	Bq/l	1	0.1	0.148	0.21	16	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	SWA11	SLOUGH SOUTH	Zone No.:	153
			Population:	45437
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Very good water quality, however one infringement to report for coliforms. Our investigations showed the infringement for coliforms was due to customer plumbing and not indicative of the quality of water supplied to this zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone