

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SLW13 CLAPHAM			Zone No.: 105					
			Population: 33307					
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	84	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	84	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	401	0	0
Colony count 22°C	cfu/ml	-	0	1	9	36	0	0
Colony count 37°C	cfu/ml	-	0	1.333	13	36	0	0
Residual Disinfectant	mg/l	-	0.21	0.564	0.93	84	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.800	1.592	4.8	36	0	0
Hydrogen Ion	pH	6.50-9.50	7.5	7.703	8	36	0	0
Turbidity	FTU	4	0.06	0.073	0.14	36	0	0
Conductivity at 20°C	uS/cm	2500	511	556.583	606	36	0	0
Ammonium as NH4	mg/l	0.5	0.07	0.143	0.24	36	0	0
Chloride as Cl	mg/l	250	31.71	38.588	44.51	8	0	0
Sodium as Na	mg/l	200	21.5	26.088	32.7	8	0	0
Sulphate as SO4	mg/l	250	40.4	43.538	47.2	8	0	0
Nitrate as NO3	mg/l	50	20.9	23.933	28.1	36	0	0
Nitrite as NO2	mg/l	0.5	<0.010	0.016	0.14	36	0	0
Nitrate/Nitrite calculation	mg/l	1	0.42	0.482	0.56	36	0	0
Total Organic Carbon as C	mg/l	-	1.5	2.297	3.7	36	0	0
Total Hardness as CaCO3	mg/l	N/A	234	252	270	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	18	0	0
Taste (quantatative)	dilution no.	0	0	0	0	18	0	0
Iron as Fe	ug/l	200	<2.000	3.297	8.8	36	0	0
Manganese as Mn	ug/l	50	<0.200	0.753	0.9	36	0	0
Aluminium as Al	ug/l	200	<1.400	6.317	18.5	36	0	0
Antimony as Sb	ug/l	5	<0.700	<0.788	<0.800	8	0	0
Arsenic as As	ug/l	10	0.8	1.038	1.2	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.800	<0.888	<0.900	8	0	0
Copper as Cu	mg/l	2	<0.004	0.036	0.221	8	0	0
Lead as Pb	ug/l	10	<0.200	1.225	3	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.088	<0.120	36	0	0
Nickel as Ni	ug/l	20	<1.300	<1.375	<1.600	8	0	0
Fluoride as F	mg/l	1.5	0.117	0.149	0.178	8	0	0
Selenium as Se	ug/l	10	<0.800	0.813	0.9	8	0	0
Boron as B	mg/l	1	0.046	0.053	0.057	8	0	0
Bromate as BrO3	ug/l	10	<0.700	0.833	1.8	36	0	0
Cyanide as CN	ug/l	50	<0.700	0.711	1	36	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	13.5	18.363	27.4	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SLW13 CLAPHAM			Zone No.: 105					
			Population: 33307					
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	36	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	36	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	36	0	0
Carbetamide	ug/l	0.1	<0.003	0.003	0.006	36	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	36	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	36	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	36	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	36	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.004	36	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	36	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	36	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	36	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	36	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	36	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	36	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	36	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	36	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	36	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	36	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	36	0	0
Propyzamide	ug/l	0.1	<0.004	0.009	0.033	36	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	36	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	36	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	36	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	36	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	36	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	36	0	0
Picloram	ug/l	0.1	<0.005	<0.008	<0.008	36	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	36	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	36	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	36	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	36	0	0
Metaldehyde	ug/l	0.1	0.02	0.036	0.07	36	0	0
Metazachlor	ug/l	0.1	<0.002	0.002	0.003	36	0	0
Quinmerac	ug/l	0.1	<0.004	0.005	0.009	36	0	0
Total Pesticides	ug/l	0.5	0	0.044	0.099	38	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SLW13 CLAPHAM

Zone No.: 105

Population: 33307

Time Period: 01/01/2014 to 31/12/2014

Date extracted: 10/04/2015

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone