

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: R11 HENLEY			Zone No.: 176			Population: 14517		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	36	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	36	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	16	0	0
Colony count 22°C	cfu/ml	-	0	0.417	3	24	0	0
Colony count 37°C	cfu/ml	-	0	0.042	1	24	0	0
Residual Disinfectant	mg/l	-	0.2	0.353	0.52	36	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.800	0.825	1.3	24	0	0
Hydrogen Ion	pH	6.50-9.50	7	7.158	7.9	24	0	0
Turbidity	FTU	4	<0.040	0.066	0.08	24	0	0
Conductivity at 20°C	uS/cm	2500	566	612.833	640	24	0	0
Ammonium as NH ₄	mg/l	0.5	<0.030	<0.030	<0.030	24	0	0
Chloride as Cl	mg/l	250	15.07	20.831	25.16	8	0	0
Sodium as Na	mg/l	200	9	12.888	16.4	8	0	0
Sulphate as SO ₄	mg/l	250	8.7	11.5	13.9	8	0	0
Nitrate as NO ₃	mg/l	50	20.8	27.425	32.8	8	0	0
Nitrite as NO ₂	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.42	0.55	0.66	8	0	0
Total Organic Carbon as C	mg/l	-	0.4	0.519	0.8	16	0	0
Total Hardness as CaCO ₃	mg/l	N/A	324	325	325	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	12	0	0
Taste (quantatative)	dilution no.	0	0	0	0	12	0	0
Iron as Fe	ug/l	200	<1.000	<1.917	<2.000	12	0	0
Manganese as Mn	ug/l	50	<0.800	<0.800	<0.800	9	0	0
Aluminium as Al	ug/l	200	<1.400	<2.844	<6.300	9	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	8	0	0
Arsenic as As	ug/l	10	0.3	0.3	0.3	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.933	<1.200	9	0	0
Copper as Cu	mg/l	2	0.004	0.026	0.081	8	0	0
Lead as Pb	ug/l	10	<0.200	0.388	0.8	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.089	<0.120	16	0	0
Nickel as Ni	ug/l	20	<1.300	1.525	2.4	8	0	0
Fluoride as F	mg/l	1.5	0.07	0.104	0.167	8	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	8	0	0
Boron as B	mg/l	1	0.02	0.055	0.078	9	0	0
Bromate as BrO ₃	ug/l	10	<0.700	0.719	0.9	16	0	0
Cyanide as CN	ug/l	50	<0.700	<0.700	<0.700	16	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	9	0	0
Trihalomethanes	ug/l	100	0	1.263	3	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: R11 HENLEY			Zone No.: 176					
			Population: 14517					
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		
Date extracted: 10/04/2015			(all samples)					
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	0.005	0.008	0.011	16	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	16	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	16	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	16	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	16	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	16	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	16	0	0
Diuron	ug/l	0.1	<0.003	0.003	0.004	16	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	16	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	16	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	16	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	16	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	16	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	16	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Simazine	ug/l	0.1	<0.005	0.006	0.009	16	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	16	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	16	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	16	0	0
Monuron	ug/l	0.1	<0.003	0.003	0.005	16	0	0
Picloram	ug/l	0.1	<0.005	<0.007	<0.008	16	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	16	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Metaldehyde	ug/l	0.1	<0.005	<0.006	<0.006	16	0	0
Total Pesticides	ug/l	0.5	0	0.011	0.022	17	0	0
Gross alpha activity	Bq/l	0.1	0.04	0.043	0.06	8	0	0
Gross beta activity	Bq/l	1	0.03	0.043	0.05	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	R11	HENLEY	Zone No.:	176
			Population:	14517
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone