

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SLW 3 EAST LAMBETH			Zone No.: 95			Population: 61553		
Time Period: 01/01/2014 to 31/12/2014 Date extracted: 10/04/2015			Concentration or Value (all samples)			No. of Samples		% of samples contravening PCV
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra- vening	
Coliform bacteria	no./100ml	0	0	0	0	144	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	144	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	1044	0	0
Colony count 22°C	cfu/ml	-	0	1.192	18	52	0	0
Colony count 37°C	cfu/ml	-	0	1.558	10	52	0	0
Residual Disinfectant	mg/l	-	0.14	0.531	0.83	144	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	0.8	1.429	3.6	52	0	0
Hydrogen Ion	pH	6.50-9.50	7.5	7.748	8.1	52	0	0
Turbidity	FTU	4	<0.060	0.073	0.12	52	0	0
Conductivity at 20°C	uS/cm	2500	528	567.135	606	52	0	0
Ammonium as NH4	mg/l	0.5	0.09	0.145	0.29	53	0	0
Chloride as Cl	mg/l	250	35.51	39.708	45.56	8	0	0
Sodium as Na	mg/l	200	23	26.575	32.4	8	0	0
Sulphate as SO4	mg/l	250	41.7	44.1	49.1	8	0	0
Nitrate as NO3	mg/l	50	21.5	23.996	27.4	53	0	0
Nitrite as NO2	mg/l	0.5	<0.010	0.02	0.08	53	0	0
Nitrate/Nitrite calculation	mg/l	1	0.43	0.485	0.56	53	0	0
Total Organic Carbon as C	mg/l	-	1.5	2.246	3.8	82	0	0
Total Hardness as CaCO3	mg/l	N/A	253	262	270	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	26	0	0
Taste (quantatative)	dilution no.	0	0	0	0	26	0	0
Iron as Fe	ug/l	200	<2.000	3.556	29.6	52	0	0
Manganese as Mn	ug/l	50	<0.200	<0.754	<0.800	52	0	0
Aluminium as Al	ug/l	200	<1.400	5.933	15.5	52	0	0
Antimony as Sb	ug/l	5	<0.700	<0.788	<0.800	8	0	0
Arsenic as As	ug/l	10	0.8	1	1.2	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.938	<1.200	8	0	0
Copper as Cu	mg/l	2	<0.004	0.013	0.049	8	0	0
Lead as Pb	ug/l	10	<0.200	<0.213	<0.300	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.089	<0.120	82	0	0
Nickel as Ni	ug/l	20	<1.300	<1.338	<1.600	8	0	0
Fluoride as F	mg/l	1.5	0.115	0.145	0.19	8	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	8	0	0
Boron as B	mg/l	1	0.046	0.053	0.057	8	0	0
Bromate as BrO3	ug/l	10	<0.700	1.171	14.5	83	1	1.2
Cyanide as CN	ug/l	50	<0.700	0.715	1.1	82	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	12.1	17.4	21.4	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SLW 3 EAST LAMBETH			Zone No.: 95			Population: 61553		
Time Period: 01/01/2014 to 31/12/2014 Date extracted: 10/04/2015			Concentration or Value (all samples)			No. of Samples		
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	83	0	0
Bentazone	ug/l	0.1	<0.005	0.005	0.007	83	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	83	0	0
Carbetamide	ug/l	0.1	<0.003	0.004	0.008	83	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	83	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	83	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	83	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	83	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.004	83	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	83	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	83	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	83	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	83	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	83	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	83	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	83	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	83	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	83	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	82	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	82	0	0
Propyzamide	ug/l	0.1	<0.004	0.008	0.033	83	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	83	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	83	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	82	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	83	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	83	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	83	0	0
Picloram	ug/l	0.1	<0.005	0.008	0.01	83	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	83	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	82	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	82	0	0
Carbendazim	ug/l	0.1	<0.002	0.002	0.008	83	0	0
Metaldehyde	ug/l	0.1	0.018	0.039	0.083	82	0	0
Metazachlor	ug/l	0.1	<0.002	0.003	0.008	82	0	0
Quinmerac	ug/l	0.1	<0.004	0.006	0.017	83	0	0
Total Pesticides	ug/l	0.5	0	0.048	0.134	90	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	SLW 3 EAST LAMBETH	Zone No.:	95
		Population:	61553
Time Period: 01/01/2014 to 31/12/2014			
Date extracted: 10/04/2015			

Commentary on Water Quality:

Very good water quality, however one infringement to report for bromate. Our investigations showed the infringement for bromate was transitory at a supplying asset and is not indicative of the quality of water supplied to this zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone