THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SWA25 BOURNE END **Zone No.:** 280

Population: 17012

Time Period: 01/01/2014 to 31/12/2014
Date extracted: 10/04/2015

			Concentration or Value (all samples)			No. of Samples		
Parameter	**Units**	**PCV**	**Min.**	**Mean**	**Max.**	**Total**	**Contra-vening**	**% of samples contravening PCV**
Coliform bacteria	no./100ml	0	0	0	0	49	0	0
E. coli	no./100ml	0	0	0	0	49	0	0
Enterococci	no./100ml	0	0	0	0	8	0	0
Clostridium perfringens	no./100ml	0	0	0	0	8	0	0
Colony count 22°C	cfu/ml	-	0	0.12	1	25	0	0
Colony count 37°C	cfu/ml	-	0	0.16	1	25	0	0
Residual Disinfectant	mg/l	-	0.05	0.321	0.55	50	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.400	0.792	1	24	0	0
Hydrogen Ion	pH	6.50-9.50	7.1	7.308	7.7	24	0	0
Turbidity	FTU	4	<0.060	0.076	0.22	24	0	0
Conductivity at 20°C	uS/cm	2500	542	560.25	628	24	0	0
Ammonium as NH4	mg/l	0.5	<0.030	<0.030	<0.030	24	0	0
Chloride as Cl	mg/l	250	20.01	20.693	21.1	8	0	0
Sodium as Na	mg/l	200	9.5	11.55	22.9	8	0	0
Sulphate as SO4	mg/l	250	12.1	12.375	12.8	8	0	0
Nitrate as NO3	mg/l	50	22.9	23.775	24.7	8	0	0
Nitrite as NO2	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.46	0.474	0.49	8	0	0
Total Organic Carbon as C	mg/l	-	0.4	0.488	0.6	8	0	0
Total Hardness as CaCO3	mg/l	N/A	294	298	301	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	13	0	0
Taste (quantatative)	dilution no.	0	0	0	0	13	0	0
Iron as Fe	ug/l	200	<1.000	14.292	125	12	0	0
Manganese as Mn	ug/l	50	<0.800	<0.800	<0.800	8	0	0
Aluminium as Al	ug/l	200	<1.400	3.238	5.9	8	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	8	0	0
Arsenic as As	ug/l	10	<0.300	<0.300	<0.300	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.900	<0.900	8	0	0
Copper as Cu	mg/l	2	<0.004	0.044	0.202	8	0	0
Lead as Pb	ug/l	10	<0.200	0.263	0.5	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.084	<0.090	9	0	0
Nickel as Ni	ug/l	20	<1.300	<1.300	<1.300	8	0	0
Fluoride as F	mg/l	1.5	0.062	0.092	0.108	8	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	8	0	0
Boron as B	mg/l	1	0.025	0.027	0.028	8	0	0
Bromate as BrO3	ug/l	10	<0.700	<0.700	<0.700	8	0	0
Cyanide as CN	ug/l	50	<0.700	<0.700	<0.700	8	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	0	2.95	16.8	10	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	1.07	1.4	10	0	0
Tetrachloromethane	ug/l	3	0.2	0.28	0.3	10	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.270	<0.300	10	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SWA25 BOURNE END **Zone No.:** 280

Population: 17012

Time Period: 01/01/2014 to 31/12/2014
Date extracted: 10/04/2015

			Concentration or Value (all samples)			No. of Samples		
Parameter	**Units**	**PCV**	**Min.**	**Mean**	**Max.**	**Total**	**Contra-vening**	**% of samples contravening PCV**
Benzene	ug/l	1	<0.100	<0.100	<0.100	9	0	0
Atrazine	ug/l	0.1	0.019	0.021	0.022	9	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	9	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	9	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	9	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	9	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	9	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.004	9	0	0
Diuron	ug/l	0.1	<0.003	0.003	0.004	9	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	9	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	9	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	9	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	9	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	9	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	9	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	9	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	9	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	9	0	0
Simazine	ug/l	0.1	0.006	0.007	0.009	9	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	9	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	9	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	9	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
Picloram	ug/l	0.1	<0.005	<0.008	<0.008	9	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	9	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Metaldehyde	ug/l	0.1	<0.005	<0.006	<0.006	9	0	0
Total Pesticides	ug/l	0.5	0	0.027	0.034	10	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	SWA25	BOURNE END	**Zone No.:**	280
			Population:	17012

Time Period: 01/01/2014 to 31/12/2014
Date extracted: 10/04/2015

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone