

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> SLE39 CRAY			<b>Zone No.:</b> 321					
			<b>Population:</b> 21287					
<b>Time Period: 01/01/2014 to 31/12/2014</b>			<b>Concentration or Value (all samples)</b>			<b>No. of Samples</b>		
<b>Date extracted: 10/04/2015</b>								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	61	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	61	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	60	0	0
Colony count 22°C	cfu/ml	-	0	0.72	10	25	0	0
Colony count 37°C	cfu/ml	-	0	0.64	9	25	0	0
Residual Disinfectant	mg/l	-	0.21	0.383	0.52	61	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.200	0.825	2.4	24	0	0
Hydrogen Ion	pH	6.50-9.50	7.1	7.267	7.7	24	0	0
Turbidity	FTU	4	<0.040	0.07	0.16	24	0	0
Conductivity at 20°C	uS/cm	2500	566	637.25	730	24	0	0
Ammonium as NH4	mg/l	0.5	<0.030	<0.030	<0.030	24	0	0
Chloride as Cl	mg/l	250	29.36	33.925	40.02	8	0	0
Sodium as Na	mg/l	200	14	21.15	48.3	8	0	0
Sulphate as SO4	mg/l	250	28.7	37.275	44.2	8	0	0
Nitrate as NO3	mg/l	50	26.5	29.375	33.2	8	0	0
Nitrite as NO2	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.53	0.589	0.67	8	0	0
Total Organic Carbon as C	mg/l	-	0.4	0.575	0.8	8	0	0
Total Hardness as CaCO3	mg/l	N/A	323	330	337	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	12	0	0
Taste (quantatative)	dilution no.	0	0	0	0	12	0	0
Iron as Fe	ug/l	200	<1.000	2.075	3.2	24	0	0
Manganese as Mn	ug/l	50	<0.200	<0.775	<0.800	24	0	0
Aluminium as Al	ug/l	200	<1.400	2.971	5.9	24	0	0
Antimony as Sb	ug/l	5	<0.500	<0.763	<0.800	8	0	0
Arsenic as As	ug/l	10	<0.300	<0.300	<0.300	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	1.2	1.6	9	0	0
Copper as Cu	mg/l	2	<0.004	0.022	0.093	8	0	0
Lead as Pb	ug/l	10	<0.200	0.45	1.8	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.084	<0.090	8	0	0
Nickel as Ni	ug/l	20	<1.300	<1.338	<1.600	8	0	0
Fluoride as F	mg/l	1.5	0.064	0.099	0.155	8	0	0
Selenium as Se	ug/l	10	0.9	1.725	2.6	8	0	0
Boron as B	mg/l	1	0.036	0.041	0.047	9	0	0
Bromate as BrO3	ug/l	10	<0.700	<0.700	<0.700	8	0	0
Cyanide as CN	ug/l	50	<0.700	<0.700	<0.700	8	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	0.8	2.013	3.1	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0.8	1.2	1.6	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> SLE39 CRAY			<b>Zone No.:</b> 321					
			<b>Population:</b> 21287					
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value</b> (all samples)			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	0.013	0.017	8	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Chlortoluron	ug/l	0.1	<0.003	0.004	0.007	8	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	8	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	8	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.004	8	0	0
Diuron	ug/l	0.1	<0.003	0.01	0.013	8	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	8	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	8	0	0
MCPA	ug/l	0.1	<0.002	<0.005	<0.006	8	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	8	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	8	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Simazine	ug/l	0.1	<0.005	0.014	0.018	8	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	8	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	8	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Monuron	ug/l	0.1	<0.003	0.004	0.004	8	0	0
Picloram	ug/l	0.1	<0.005	<0.007	<0.008	8	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	8	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Metaldehyde	ug/l	0.1	<0.005	0.006	0.009	8	0	0
Total Pesticides	ug/l	0.5	0	0.039	0.057	9	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

**Water Supply Zone:** SLE39 CRAY

**Zone No.:** 321

**Population:** 21287

**Time Period:** 01/01/2014 to 31/12/2014

**Date extracted:** 10/04/2015

**Commentary on Water Quality:**

Excellent quality water with no infringements to report for the Water Supply Zone.

**NOTES:**

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone