

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SLW 1 SOUTH LAMBETH			Zone No.: 93			Population: 67959		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		% of samples contravening PCV
Date extracted: 10/04/2015			(all samples)			Total	Contra- vening	
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra- vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	180	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	180	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	1409	0	0
Colony count 22°C	cfu/ml	-	0	2.717	74	53	0	0
Colony count 37°C	cfu/ml	-	0	4.245	84	53	0	0
Residual Disinfectant	mg/l	-	0.24	0.542	0.87	180	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.800	1.406	3.4	53	0	0
Hydrogen Ion	pH	6.50-9.50	7.6	7.733	8.1	52	0	0
Turbidity	FTU	4	<0.060	0.074	0.14	53	0	0
Conductivity at 20°C	uS/cm	2500	520	567.585	604	53	0	0
Ammonium as NH ₄	mg/l	0.5	0.05	0.144	0.19	52	0	0
Chloride as Cl	mg/l	250	35.41	39.597	46.15	9	0	0
Sodium as Na	mg/l	200	24	27.038	30.8	8	0	0
Sulphate as SO ₄	mg/l	250	42.9	44.522	46.9	9	0	0
Nitrate as NO ₃	mg/l	50	21.1	23.946	30.1	52	0	0
Nitrite as NO ₂	mg/l	0.5	<0.010	0.016	0.09	52	0	0
Nitrate/Nitrite calculation	mg/l	1	0.43	0.484	0.6	52	0	0
Total Organic Carbon as C	mg/l	-	1.4	2.206	3.8	106	0	0
Total Hardness as CaCO ₃	mg/l	N/A	252	261	265	3	0	0
Odour (quantatative)	dilution no.	0	0	0	0	27	0	0
Taste (quantatative)	dilution no.	0	0	0	0	27	0	0
Iron as Fe	ug/l	200	1.9	3.087	10.6	52	0	0
Manganese as Mn	ug/l	50	<0.200	<0.763	<0.800	52	0	0
Aluminium as Al	ug/l	200	<1.400	6.069	23.3	52	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	8	0	0
Arsenic as As	ug/l	10	0.9	1.088	1.3	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.113	<0.200	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.938	<1.200	8	0	0
Copper as Cu	mg/l	2	0.003	0.01	0.028	8	0	0
Lead as Pb	ug/l	10	<0.200	0.238	0.4	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.088	<0.120	106	0	0
Nickel as Ni	ug/l	20	<1.300	<1.338	<1.600	8	0	0
Fluoride as F	mg/l	1.5	0.118	0.142	0.168	8	0	0
Selenium as Se	ug/l	10	<0.800	0.825	1	8	0	0
Boron as B	mg/l	1	0.05	0.053	0.057	8	0	0
Bromate as BrO ₃	ug/l	10	<0.700	1.079	14.5	107	1	0.9
Cyanide as CN	ug/l	50	<0.700	0.715	1.1	106	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	13.3	18.28	22.1	10	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	9	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	9	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.270	<0.300	10	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SLW 1 SOUTH LAMBETH			Zone No.: 93			Population: 67959		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	0.1	0.1	0.1	10	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	107	0	0
Bentazone	ug/l	0.1	<0.005	0.005	0.007	107	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	107	0	0
Carbetamide	ug/l	0.1	<0.003	0.003	0.008	107	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	107	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	107	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	107	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	107	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	107	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	107	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	107	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	107	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	107	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	107	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	107	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	107	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	107	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	107	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Propyzamide	ug/l	0.1	<0.004	0.007	0.033	107	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	107	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	107	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	106	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	107	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	107	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	107	0	0
Picloram	ug/l	0.1	<0.005	0.008	0.01	107	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	107	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Carbendazim	ug/l	0.1	<0.002	0.002	0.008	107	0	0
Metaldehyde	ug/l	0.1	0.018	0.039	0.083	106	0	0
Metazachlor	ug/l	0.1	<0.002	0.003	0.008	106	0	0
Quinmerac	ug/l	0.1	0.004	0.006	0.017	107	0	0
Total Pesticides	ug/l	0.5	0	0.048	0.134	114	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	SLW 1 SOUTH LAMBETH	Zone No.:	93
		Population:	67959
Time Period: 01/01/2014 to 31/12/2014			
Date extracted: 10/04/2015			

Commentary on Water Quality:

Very good water quality, however one infringement to report for bromate. Our investigations showed the infringement for bromate was transitory at a supplying asset and is not indicative of the quality of water supplied to this zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone