

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> SLE45 PLUMSTEAD			<b>Zone No.:</b> 327			<b>Population:</b> 55553		
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value</b>			<b>No. of Samples</b>		<b>% of samples contravening PCV</b>
<b>Date extracted:</b> 10/04/2015			<b>(all samples)</b>			<b>Total</b>	<b>Contra-vening</b>	
<b>Parameter</b>	<b>Units</b>	<b>PCV</b>	<b>Min.</b>	<b>Mean</b>	<b>Max.</b>	<b>Total</b>	<b>Contra-vening</b>	
Coliform bacteria	no./100ml	0	0	0	0	144	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	144	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	1409	0	0
Colony count 22°C	cfu/ml	-	0	1.962	47	52	0	0
Colony count 37°C	cfu/ml	-	0	0.792	5	53	0	0
Residual Disinfectant	mg/l	-	0.09	0.277	0.59	144	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.400	1.106	3.5	52	0	0
Hydrogen Ion	pH	6.50-9.50	7.1	7.406	7.9	52	0	0
Turbidity	FTU	4	<0.040	0.078	0.19	52	0	0
Conductivity at 20°C	uS/cm	2500	538	616.5	765	52	0	0
Ammonium as NH <sub>4</sub>	mg/l	0.5	<0.030	0.05	0.14	52	0	0
Chloride as Cl	mg/l	250	33.9	40.03	47.79	8	0	0
Sodium as Na	mg/l	200	21.7	26.7	30.3	8	0	0
Sulphate as SO <sub>4</sub>	mg/l	250	42.7	47.013	63	8	0	0
Nitrate as NO <sub>3</sub>	mg/l	50	21.2	26.819	36	52	0	0
Nitrite as NO <sub>2</sub>	mg/l	0.5	<0.010	0.034	0.16	52	0	0
Nitrate/Nitrite calculation	mg/l	1	0.44	0.546	0.72	52	0	0
Total Organic Carbon as C	mg/l	-	1.4	2.206	3.8	106	0	0
Total Hardness as CaCO <sub>3</sub>	mg/l	N/A	306	326	345	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	26	0	0
Taste (quantatative)	dilution no.	0	0	0	0	26	0	0
Iron as Fe	ug/l	200	<1.000	3.119	12	52	0	0
Manganese as Mn	ug/l	50	<0.200	<0.754	<0.800	52	0	0
Aluminium as Al	ug/l	200	<1.400	4.242	9	52	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	8	0	0
Arsenic as As	ug/l	10	<0.300	0.838	1.3	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	1.088	2.1	8	0	0
Copper as Cu	mg/l	2	<0.004	0.006	0.01	8	0	0
Lead as Pb	ug/l	10	0.2	1.088	4.8	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.088	<0.120	106	0	0
Nickel as Ni	ug/l	20	<1.300	1.363	1.6	8	0	0
Fluoride as F	mg/l	1.5	0.125	0.136	0.148	8	0	0
Selenium as Se	ug/l	10	<0.800	1.275	3	8	0	0
Boron as B	mg/l	1	0.048	0.064	0.118	8	0	0
Bromate as BrO <sub>3</sub>	ug/l	10	<0.700	1.079	14.5	107	1	0.9
Cyanide as CN	ug/l	50	<0.700	0.715	1.1	106	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0.002	9	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	9	0	0
Trihalomethanes	ug/l	100	4.4	17.133	22	9	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0.178	1.2	9	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	9	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.256	<0.300	9	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> SLE45 PLUMSTEAD			<b>Zone No.:</b> 327			<b>Population:</b> 55553		
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value</b> (all samples)			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	9	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	107	0	0
Bentazone	ug/l	0.1	<0.005	0.005	0.007	107	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	107	0	0
Carbetamide	ug/l	0.1	<0.003	0.003	0.008	107	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	107	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	107	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	107	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	107	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	107	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	107	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	107	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	107	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	107	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	107	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	107	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	107	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	107	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	107	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Propyzamide	ug/l	0.1	<0.004	0.007	0.033	107	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	107	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	107	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	106	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	107	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	107	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	107	0	0
Picloram	ug/l	0.1	<0.005	0.008	0.01	107	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	107	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	106	0	0
Carbendazim	ug/l	0.1	<0.002	0.002	0.008	107	0	0
Metaldehyde	ug/l	0.1	0.018	0.039	0.083	106	0	0
Metazachlor	ug/l	0.1	<0.002	0.003	0.008	106	0	0
Quinmerac	ug/l	0.1	<0.004	0.006	0.017	107	0	0
Total Pesticides	ug/l	0.5	0	0.048	0.134	114	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b>	SLE45    PLUMSTEAD	<b>Zone No.:</b>	327
		<b>Population:</b>	55553
<b>Time Period:</b> 01/01/2014 to 31/12/2014			
<b>Date extracted:</b> 10/04/2015			

**Commentary on Water Quality:**

Very good water quality, however one infringement to report for bromate. Our investigations showed the infringement for bromate was transitory at a supplying asset and is not indicative of the quality of water supplied to this zone.

**NOTES:**

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone