

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: S15 SWINDON EAST			Zone No.: 222			Population: 16941		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	48	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	48	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	224	0	0
Colony count 22°C	cfu/ml	-	0	0.333	4	24	0	0
Colony count 37°C	cfu/ml	-	0	0.28	4	25	0	0
Residual Disinfectant	mg/l	-	0.11	0.298	0.45	48	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.400	<0.767	<0.800	24	0	0
Hydrogen Ion	pH	6.50-9.50	7.2	7.363	7.5	24	0	0
Turbidity	FTU	4	<0.060	0.07	0.13	24	0	0
Conductivity at 20°C	uS/cm	2500	481	540.917	576	24	0	0
Ammonium as NH ₄	mg/l	0.5	<0.030	<0.030	<0.030	24	0	0
Chloride as Cl	mg/l	250	16.22	28.306	34.65	8	0	0
Sodium as Na	mg/l	200	5.3	16.85	21.5	8	0	0
Sulphate as SO ₄	mg/l	250	17.5	52.825	70.5	8	0	0
Nitrate as NO ₃	mg/l	50	15.2	22.325	40.5	8	0	0
Nitrite as NO ₂	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.3	0.446	0.81	8	0	0
Total Organic Carbon as C	mg/l	-	0.5	1.021	2	28	0	0
Total Hardness as CaCO ₃	mg/l	N/A	267	272	276	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	24	0	0
Taste (quantatative)	dilution no.	0	0	0	0	24	0	0
Iron as Fe	ug/l	200	<1.000	2.808	13	24	0	0
Manganese as Mn	ug/l	50	<0.200	<0.750	<0.800	24	0	0
Aluminium as Al	ug/l	200	<1.400	5.429	11.6	24	0	0
Antimony as Sb	ug/l	5	<0.700	<0.788	<0.800	8	0	0
Arsenic as As	ug/l	10	0.3	0.413	0.5	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.933	<1.200	9	0	0
Copper as Cu	mg/l	2	0.005	0.044	0.203	8	0	0
Lead as Pb	ug/l	10	<0.200	0.288	0.6	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.089	<0.120	28	0	0
Nickel as Ni	ug/l	20	<1.300	1.363	1.8	8	0	0
Fluoride as F	mg/l	1.5	0.104	0.14	0.208	8	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	8	0	0
Boron as B	mg/l	1	0.013	0.04	0.049	9	0	0
Bromate as BrO ₃	ug/l	10	<0.700	0.725	1.1	28	0	0
Cyanide as CN	ug/l	50	<0.700	0.725	1.1	28	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	10.2	15.333	21.8	9	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	9	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.267	<0.300	9	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: S15 SWINDON EAST			Zone No.: 222			Population: 16941		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	9	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	28	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	28	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	28	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	28	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	28	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	28	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	28	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	28	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	28	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	28	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	28	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	28	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	28	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	28	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	28	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	28	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	28	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	28	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	28	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	28	0	0
Propyzamide	ug/l	0.1	<0.003	<0.004	<0.004	28	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	28	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	28	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	28	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	28	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	28	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	28	0	0
Picloram	ug/l	0.1	<0.005	<0.008	<0.008	28	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	28	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	28	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	28	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	28	0	0
Metaldehyde	ug/l	0.1	<0.005	0.012	0.045	29	0	0
Metazachlor	ug/l	0.1	<0.002	<0.002	<0.002	12	0	0
Quinmerac	ug/l	0.1	<0.004	<0.004	<0.004	12	0	0
Total Pesticides	ug/l	0.5	0	0.008	0.045	30	0	0
Gross alpha activity	Bq/l	0.1	<0.040	<0.040	<0.040	12	0	0
Gross beta activity	Bq/l	1	0.09	0.251	1.82	12	1	8.3

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	S15	SWINDON EAST	Zone No.:	222
			Population:	16941
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Very good water quality, however one infringement to report for gross beta activity. Our investigations (in conjunction with the Environment Agency) showed the infringement for gross beta activity was anomalous at one of our supplying assets (and not likely to recur), and not indicative of the quality of water supplied to this zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone