

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: R18			BURGHFIELD & TADLEY			Zone No.: 183		
						Population: 29914		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		
Date extracted: 10/04/2015			(all samples)					
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	72	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	72	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	8	0	0
Colony count 22°C	cfu/ml	-	0	0.2	3	25	0	0
Colony count 37°C	cfu/ml	-	0	0.24	3	25	0	0
Residual Disinfectant	mg/l	-	0.1	0.304	0.53	73	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.400	<0.767	<0.800	24	0	0
Hydrogen Ion	pH	6.50-9.50	7.6	7.717	7.9	24	0	0
Turbidity	FTU	4	<0.060	0.074	0.18	24	0	0
Conductivity at 20°C	uS/cm	2500	565	574.125	579	24	0	0
Ammonium as NH4	mg/l	0.5	0.03	0.03	0.03	24	0	0
Chloride as Cl	mg/l	250	29.42	30.162	31.19	9	0	0
Sodium as Na	mg/l	200	19.6	21.488	22.6	8	0	0
Sulphate as SO4	mg/l	250	<3.100	7.4	16.3	9	0	0
Nitrate as NO3	mg/l	50	<0.500	0.8	1.3	9	0	0
Nitrite as NO2	mg/l	0.5	<0.010	<0.010	<0.010	9	0	0
Nitrate/Nitrite calculation	mg/l	1	<0.020	0.021	0.03	9	0	0
Total Organic Carbon as C	mg/l	-	0.4	0.563	0.8	8	0	0
Total Hardness as CaCO3	mg/l	N/A	276	285	291	3	0	0
Odour (quantatative)	dilution no.	0	0	0	0	24	0	0
Taste (quantatative)	dilution no.	0	0	0	0	24	0	0
Iron as Fe	ug/l	200	2.7	8.675	15.4	12	0	0
Manganese as Mn	ug/l	50	<0.800	3.563	15.7	8	0	0
Aluminium as Al	ug/l	200	<1.400	2.05	5	8	0	0
Antimony as Sb	ug/l	5	<0.500	<0.763	<0.800	8	0	0
Arsenic as As	ug/l	10	<0.300	0.313	0.4	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.113	<0.200	8	0	0
Chromium as Cr	ug/l	50	<0.900	<0.938	<1.200	8	0	0
Copper as Cu	mg/l	2	<0.004	0.01	0.037	8	0	0
Lead as Pb	ug/l	10	<0.200	0.263	0.5	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.084	<0.090	8	0	0
Nickel as Ni	ug/l	20	<1.300	<1.338	<1.600	8	0	0
Fluoride as F	mg/l	1.5	0.891	1.007	1.17	8	0	0
Selenium as Se	ug/l	10	<0.800	0.813	0.9	8	0	0
Boron as B	mg/l	1	0.068	0.073	0.076	8	0	0
Bromate as BrO3	ug/l	10	<0.700	0.85	1.1	8	0	0
Cyanide as CN	ug/l	50	<0.700	<0.700	<0.700	8	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	9	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	9	0	0
Trihalomethanes	ug/l	100	5	9.525	12	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: R18			BURGHFIELD & TADLEY			Zone No.: 183		
						Population: 29914		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		
Date extracted: 10/04/2015			(all samples)					
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bentazone	ug/l	0.1	<0.005	0.006	0.011	8	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	8	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	8	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.004	8	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	8	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	8	0	0
MCPA	ug/l	0.1	<0.002	<0.005	<0.006	8	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	8	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	8	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	8	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	8	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Picloram	ug/l	0.1	<0.005	<0.007	<0.008	8	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	8	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Metaldehyde	ug/l	0.1	<0.005	0.007	0.009	8	0	0
Total Pesticides	ug/l	0.5	0	0.008	0.016	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	R18	BURGHFIELD & TADLEY	Zone No.:	183
			Population:	29914
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone