

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SWA 8 FARNHAM COMMON			Zone No.: 150			Population: 9794		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		% of samples contravening PCV
Date extracted: 10/04/2015			(all samples)			Total	Contra-vening	
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	
Coliform bacteria	no./100ml	0	0	0	0	25	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	25	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	261	0	0
Colony count 22°C	cfu/ml	-	0	8	104	13	0	0
Colony count 37°C	cfu/ml	-	0	1.846	18	13	0	0
Residual Disinfectant	mg/l	-	<0.050	0.21	0.39	25	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.800	0.85	1.2	12	0	0
Hydrogen Ion	pH	6.50-9.50	7.2	7.292	7.4	12	0	0
Turbidity	FTU	4	<0.040	0.074	0.11	12	0	0
Conductivity at 20°C	uS/cm	2500	552	610.083	630	12	0	0
Ammonium as NH4	mg/l	0.5	<0.030	<0.030	<0.030	12	0	0
Chloride as Cl	mg/l	250	17.06	35.429	41.48	8	0	0
Sodium as Na	mg/l	200	21.7	24.275	26.2	8	0	0
Sulphate as SO4	mg/l	250	12.5	42.663	50.2	8	0	0
Nitrate as NO3	mg/l	50	20.7	23.85	26.3	8	0	0
Nitrite as NO2	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.41	0.479	0.53	8	0	0
Total Organic Carbon as C	mg/l	-	1.1	1.281	1.6	16	0	0
Total Hardness as CaCO3	mg/l	N/A	301	303	305	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	8	0	0
Taste (quantatative)	dilution no.	0	0	0	0	7	0	0
Iron as Fe	ug/l	200	1.5	3.242	8.7	12	0	0
Manganese as Mn	ug/l	50	<0.200	2.25	18.4	12	0	0
Aluminium as Al	ug/l	200	<1.400	<4.250	<6.300	12	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	8	0	0
Arsenic as As	ug/l	10	0.4	0.725	1	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	0.913	1	8	0	0
Copper as Cu	mg/l	2	0.006	0.037	0.073	8	0	0
Lead as Pb	ug/l	10	<0.200	1.25	7.9	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.084	<0.090	16	0	0
Nickel as Ni	ug/l	20	<1.300	1.625	3.6	8	0	0
Fluoride as F	mg/l	1.5	0.081	0.147	0.181	8	0	0
Selenium as Se	ug/l	10	<0.800	1.175	1.5	8	0	0
Boron as B	mg/l	1	0.017	0.057	0.065	8	0	0
Bromate as BrO3	ug/l	10	<0.700	<0.700	<0.700	16	0	0
Cyanide as CN	ug/l	50	<0.700	0.7	0.7	16	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0.001	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	1.1	16.2	25.8	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: SWA 8 FARNHAM COMMON			Zone No.: 150			Population: 9794		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	16	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	16	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	16	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	16	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	16	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	16	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	16	0	0
Diuron	ug/l	0.1	0.003	0.003	0.003	16	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.005	<0.006	16	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	16	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	16	0	0
MCPA	ug/l	0.1	<0.002	<0.005	<0.006	16	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	16	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	16	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	16	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	16	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	16	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	16	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	16	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	16	0	0
Picloram	ug/l	0.1	<0.005	0.008	0.009	16	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	16	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	16	0	0
Metaldehyde	ug/l	0.1	0.009	0.016	0.026	16	0	0
Total Pesticides	ug/l	0.5	0	0.016	0.026	17	0	0
Gross alpha activity	Bq/l	0.1	<0.040	0.042	0.07	18	0	0
Gross beta activity	Bq/l	1	0.1	0.148	0.21	16	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	SWA 8 FARNHAM COMMON	Zone No.:	150
		Population:	9794
Time Period: 01/01/2014 to 31/12/2014			
Date extracted: 10/04/2015			

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone