

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> OX 7 CULHAM			<b>Zone No.:</b> 199					
			<b>Population:</b> 26195					
<b>Time Period: 01/01/2014 to 31/12/2014</b>			<b>Concentration or Value (all samples)</b>			<b>No. of Samples</b>		
<b>Date extracted: 10/04/2015</b>								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	73	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	73	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	261	0	0
Colony count 22°C	cfu/ml	-	0	12.92	>300.000	25	0	0
Colony count 37°C	cfu/ml	-	0	0.808	14	26	0	0
Residual Disinfectant	mg/l	-	0.14	0.381	0.51	73	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	0.5	0.8	1.2	24	0	0
Hydrogen Ion	pH	6.50-9.50	7.2	7.354	7.8	24	0	0
Turbidity	FTU	4	<0.040	0.071	0.1	24	0	0
Conductivity at 20°C	uS/cm	2500	557	565.167	588	24	0	0
Ammonium as NH <sub>4</sub>	mg/l	0.5	<0.030	<0.030	<0.030	24	0	0
Chloride as Cl	mg/l	250	22.87	24.256	25.76	8	0	0
Sodium as Na	mg/l	200	14.8	16.9	18.2	8	0	0
Sulphate as SO <sub>4</sub>	mg/l	250	27.3	29.35	35	8	0	0
Nitrate as NO <sub>3</sub>	mg/l	50	25	27.388	29.3	8	0	0
Nitrite as NO <sub>2</sub>	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.5	0.548	0.59	8	0	0
Total Organic Carbon as C	mg/l	-	0.6	0.763	1	8	0	0
Total Hardness as CaCO <sub>3</sub>	mg/l	N/A	280	284	287	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	12	0	0
Taste (quantatative)	dilution no.	0	0	0	0	12	0	0
Iron as Fe	ug/l	200	<1.000	10.55	114.6	24	0	0
Manganese as Mn	ug/l	50	<0.200	0.771	1	24	0	0
Aluminium as Al	ug/l	200	<1.400	4.142	21.1	24	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	8	0	0
Arsenic as As	ug/l	10	0.3	0.425	0.5	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	0.8	0.888	<0.900	8	0	0
Copper as Cu	mg/l	2	0.01	0.096	0.432	8	0	0
Lead as Pb	ug/l	10	<0.200	1.5	10.5	8	1	12.5
Mercury as Hg	ug/l	1	<0.090	<0.090	<0.090	8	0	0
Nickel as Ni	ug/l	20	<1.300	1.488	2.2	8	0	0
Fluoride as F	mg/l	1.5	0.107	0.132	0.149	8	0	0
Selenium as Se	ug/l	10	<0.800	0.825	0.9	8	0	0
Boron as B	mg/l	1	0.04	0.042	0.046	8	0	0
Bromate as BrO <sub>3</sub>	ug/l	10	<0.700	0.775	1	8	0	0
Cyanide as CN	ug/l	50	<0.700	0.763	1.2	8	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	2.6	8.911	19.1	9	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	9	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	9	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.256	<0.300	9	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> OX 7 CULHAM			<b>Zone No.:</b> 199					
			<b>Population:</b> 26195					
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value</b>			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015			<b>(all samples)</b>					
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	9	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	9	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bromoxynil	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
Clopyralid	ug/l	0.1	<0.010	<0.010	<0.010	8	0	0
2,4-D	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	8	0	0
Dichlorprop	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
Fluroxypyr	ug/l	0.1	<0.006	<0.006	<0.006	8	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	9	0	0
Ioxynil	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	9	0	0
Mecoprop	ug/l	0.1	<0.008	<0.008	<0.008	8	0	0
MCPA	ug/l	0.1	<0.006	<0.006	<0.006	8	0	0
MCPB	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Pentachlorophenol	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	9	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	9	0	0
2,4,5-T	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
2,4-DB	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Fenoprop	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	9	0	0
Picloram	ug/l	0.1	<0.008	<0.008	<0.008	8	0	0
Triclopyr	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	9	0	0
Metaldehyde	ug/l	0.1	<0.006	0.008	0.012	9	0	0
Total Pesticides	ug/l	0.5	0	0.007	0.015	9	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b>	OX 7	CULHAM	<b>Zone No.:</b>	199
			<b>Population:</b>	26195
<b>Time Period:</b> 01/01/2014 to 31/12/2014				
<b>Date extracted:</b> 10/04/2015				

**Commentary on Water Quality:**

Very good water quality, however one infringement to report for lead. Our investigations showed the infringement for lead was transitory and not indicative of the quality of water supplied to this zone.

**NOTES:**

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone