

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: S24 NORTHLEACH			Zone No.: 289			Population: 2408		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		
Date extracted: 10/04/2015			(all samples)					
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	12	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	12	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	4	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	21	0	0
Colony count 22°C	cfu/ml	-	0	1.25	5	4	0	0
Colony count 37°C	cfu/ml	-	0	0.25	1	4	0	0
Residual Disinfectant	mg/l	-	0.12	0.351	0.54	12	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.800	<0.800	<0.800	4	0	0
Hydrogen Ion	pH	6.50-9.50	7.3	7.35	7.4	4	0	0
Turbidity	FTU	4	<0.060	<0.068	<0.070	4	0	0
Conductivity at 20°C	uS/cm	2500	523	555.5	616	4	0	0
Ammonium as NH ₄	mg/l	0.5	<0.030	<0.030	<0.030	4	0	0
Chloride as Cl	mg/l	250	15.37	20.11	27.04	4	0	0
Sodium as Na	mg/l	200	10.5	13.22	19.6	5	0	0
Sulphate as SO ₄	mg/l	250	43.1	49.075	60.7	4	0	0
Nitrate as NO ₃	mg/l	50	5.7	12.1	17.4	4	0	0
Nitrite as NO ₂	mg/l	0.5	<0.010	<0.010	<0.010	4	0	0
Nitrate/Nitrite calculation	mg/l	1	0.11	0.243	0.35	4	0	0
Total Organic Carbon as C	mg/l	-	0.5	0.61	0.9	21	0	0
Total Hardness as CaCO ₃	mg/l	N/A	289	294	298	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	2	0	0
Taste (quantatative)	dilution no.	0	0	0	0	2	0	0
Iron as Fe	ug/l	200	<2.000	5.325	10.2	12	0	0
Manganese as Mn	ug/l	50	<0.800	<0.800	<0.800	4	0	0
Aluminium as Al	ug/l	200	<1.400	2.65	4.2	4	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	4	0	0
Arsenic as As	ug/l	10	<0.300	<0.300	<0.300	4	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	4	0	0
Chromium as Cr	ug/l	50	<0.900	<0.900	<0.900	4	0	0
Copper as Cu	mg/l	2	0.017	0.075	0.135	4	0	0
Lead as Pb	ug/l	10	0.2	0.35	0.5	4	0	0
Mercury as Hg	ug/l	1	<0.040	<0.089	<0.120	21	0	0
Nickel as Ni	ug/l	20	<1.300	<1.300	<1.300	4	0	0
Fluoride as F	mg/l	1.5	0.158	0.24	0.379	4	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	4	0	0
Boron as B	mg/l	1	0.021	0.038	0.067	4	0	0
Bromate as BrO ₃	ug/l	10	<0.700	0.795	1.9	21	0	0
Cyanide as CN	ug/l	50	<0.700	0.705	0.8	21	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0.001	0.005	4	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	0.001	0.002	4	0	0
Trihalomethanes	ug/l	100	3.6	6.475	9.3	4	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	4	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	4	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.275	<0.300	4	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: S24 NORTHLEACH			Zone No.: 289			Population: 2408		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	4	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	21	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	21	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	21	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	21	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	21	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	21	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	21	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	21	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	21	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	21	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	21	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	21	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	21	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	21	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	21	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	21	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	21	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	21	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	21	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	21	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	21	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	21	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	21	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	21	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	21	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	21	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	21	0	0
Picloram	ug/l	0.1	<0.005	<0.007	<0.008	21	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	21	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	21	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	21	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	21	0	0
Metaldehyde	ug/l	0.1	<0.005	0.007	0.012	21	0	0
Total Pesticides	ug/l	0.5	0	0.002	0.012	21	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	S24	NORTHLEACH	Zone No.:	289
			Population:	2408
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone