

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:		S28	SEZINCOTE NORTH COTSWOLD			Zone No.:		300
						Population:		4023
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	12	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	12	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	4	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	8	0	0
Colony count 22°C	cfu/ml	-	0	0	0	4	0	0
Colony count 37°C	cfu/ml	-	0	28.25	113	4	0	0
Residual Disinfectant	mg/l	-	0.24	0.337	0.4	12	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.800	<0.800	<0.800	4	0	0
Hydrogen Ion	pH	6.50-9.50	7.4	7.575	7.7	4	0	0
Turbidity	FTU	4	<0.070	0.078	0.1	4	0	0
Conductivity at 20°C	uS/cm	2500	509	523.25	536	4	0	0
Ammonium as NH ₄	mg/l	0.5	<0.030	<0.030	<0.030	4	0	0
Chloride as Cl	mg/l	250	17.58	19.198	20.6	4	0	0
Sodium as Na	mg/l	200	8.1	9.575	11.2	4	0	0
Sulphate as SO ₄	mg/l	250	35.9	39.475	43.6	4	0	0
Nitrate as NO ₃	mg/l	50	28.7	35.05	40.1	4	0	0
Nitrite as NO ₂	mg/l	0.5	<0.010	<0.010	<0.010	4	0	0
Nitrate/Nitrite calculation	mg/l	1	0.57	0.698	0.8	4	0	0
Total Organic Carbon as C	mg/l	-	0.4	0.538	0.7	8	0	0
Total Hardness as CaCO ₃	mg/l	N/A	276	287	298	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	2	0	0
Taste (quantatative)	dilution no.	0	0	0	0	2	0	0
Iron as Fe	ug/l	200	<1.000	2.008	3.1	12	0	0
Manganese as Mn	ug/l	50	<0.800	<0.800	<0.800	5	0	0
Aluminium as Al	ug/l	200	<1.400	2.58	3.4	5	0	0
Antimony as Sb	ug/l	5	<0.800	<0.800	<0.800	4	0	0
Arsenic as As	ug/l	10	<0.300	<0.300	<0.300	4	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	4	0	0
Chromium as Cr	ug/l	50	<0.900	<0.900	<0.900	5	0	0
Copper as Cu	mg/l	2	0.006	0.023	0.031	4	0	0
Lead as Pb	ug/l	10	<0.200	0.25	0.4	4	0	0
Mercury as Hg	ug/l	1	<0.040	<0.084	<0.090	8	0	0
Nickel as Ni	ug/l	20	<1.300	<1.300	<1.300	4	0	0
Fluoride as F	mg/l	1.5	0.117	0.167	0.227	4	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	4	0	0
Boron as B	mg/l	1	0.017	0.023	0.03	5	0	0
Bromate as BrO ₃	ug/l	10	<0.700	<0.700	<0.700	8	0	0
Cyanide as CN	ug/l	50	<0.700	<0.700	<0.700	8	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	4	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	4	0	0
Trihalomethanes	ug/l	100	5	6.4	7.9	4	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	4	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	4	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.250	<0.300	4	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: S28			SEZINCOTE NORTH COTSWOLD			Zone No.: 300		
						Population: 4023		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	4	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Clopyralid	ug/l	0.1	<0.009	0.011	0.016	8	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	8	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	8	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.005	<0.006	8	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	8	0	0
MCPA	ug/l	0.1	<0.002	<0.005	<0.006	8	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	8	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	8	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	8	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	8	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Picloram	ug/l	0.1	<0.005	<0.007	<0.008	8	0	0
Triclopyr	ug/l	0.1	<0.005	0.005	0.006	8	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Metaldehyde	ug/l	0.1	<0.005	0.006	0.01	8	0	0
Total Pesticides	ug/l	0.5	0	0.004	0.022	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	S28	SEZINCOTE NORTH COTSWOLD	Zone No.:	300
			Population:	4023
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone