

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> NLW44 ST JOHNS WOOD & MAYFAIR			<b>Zone No.:</b> 350			<b>Population:</b> 58842		
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value (all samples)</b>			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015			<b>Min.</b>	<b>Mean</b>	<b>Max.</b>	<b>Total</b>	<b>Contra-vening</b>	<b>% of samples contravening PCV</b>
Coliform bacteria	no./100ml	0	0	0	0	132	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	132	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	1147	0	0
Colony count 22°C	cfu/ml	-	0	1.981	18	52	0	0
Colony count 37°C	cfu/ml	-	0	1.75	21	52	0	0
Residual Disinfectant	mg/l	-	0.11	0.509	0.86	132	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.800	1.383	2.8	52	0	0
Hydrogen Ion	pH	6.50-9.50	7.5	7.773	8.1	52	0	0
Turbidity	FTU	4	0.04	0.075	0.15	53	0	0
Conductivity at 20°C	uS/cm	2500	545	570.654	605	52	0	0
Ammonium as NH4	mg/l	0.5	<0.030	0.137	0.2	52	0	0
Chloride as Cl	mg/l	250	34.13	39.526	47.94	8	0	0
Sodium as Na	mg/l	200	23.3	27.588	31.8	8	0	0
Sulphate as SO4	mg/l	250	20.6	40.963	46	8	0	0
Nitrate as NO3	mg/l	50	19.5	23.579	26.8	52	0	0
Nitrite as NO2	mg/l	0.5	<0.010	0.068	0.23	52	0	0
Nitrate/Nitrite calculation	mg/l	1	0.4	0.494	0.57	52	0	0
Total Organic Carbon as C	mg/l	-	1.4	2.177	3.7	96	0	0
Total Hardness as CaCO3	mg/l	N/A	247	250	252	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	27	0	0
Taste (quantatative)	dilution no.	0	0	0	0	27	0	0
Iron as Fe	ug/l	200	<2.000	3.298	37.4	52	0	0
Manganese as Mn	ug/l	50	<0.200	0.783	2.3	52	0	0
Aluminium as Al	ug/l	200	<1.400	6.058	10	52	0	0
Antimony as Sb	ug/l	5	<0.700	<0.788	<0.800	8	0	0
Arsenic as As	ug/l	10	0.9	1.125	1.4	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.800	<0.888	<0.900	8	0	0
Copper as Cu	mg/l	2	<0.004	0.049	0.173	8	0	0
Lead as Pb	ug/l	10	<0.200	1.038	6.3	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.088	<0.120	96	0	0
Nickel as Ni	ug/l	20	<1.300	<1.338	<1.600	8	0	0
Fluoride as F	mg/l	1.5	0.119	0.143	0.187	8	0	0
Selenium as Se	ug/l	10	0.8	0.8	0.8	8	0	0
Boron as B	mg/l	1	0.048	0.053	0.058	8	0	0
Bromate as BrO3	ug/l	10	<0.700	0.772	1.8	96	0	0
Cyanide as CN	ug/l	50	<0.700	0.713	1.1	96	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0.001	0.002	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	14.1	20.838	25.4	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> NLW44 ST JOHNS WOOD & MAYFAIR			<b>Zone No.:</b> 350			<b>Population:</b> 58842		
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value</b> (all samples)			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	97	0	0
Bentazone	ug/l	0.1	<0.005	0.005	0.007	96	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	96	0	0
Carbetamide	ug/l	0.1	<0.003	0.003	0.008	97	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	97	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	96	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	96	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	96	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	96	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	97	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.006	<0.006	96	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	97	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	96	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	97	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	96	0	0
MCPA	ug/l	0.1	<0.002	<0.006	<0.006	96	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	96	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	96	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	96	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	96	0	0
Propyzamide	ug/l	0.1	<0.004	0.008	0.033	97	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	97	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	96	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	96	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	96	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	96	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	97	0	0
Picloram	ug/l	0.1	<0.005	0.008	0.01	96	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	96	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	96	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	96	0	0
Carbendazim	ug/l	0.1	<0.002	0.002	0.008	97	0	0
Metaldehyde	ug/l	0.1	0.018	0.039	0.083	96	0	0
Metazachlor	ug/l	0.1	<0.002	0.003	0.008	96	0	0
Quinmerac	ug/l	0.1	<0.004	0.006	0.017	97	0	0
Total Pesticides	ug/l	0.5	0	0.05	0.134	101	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b>	NLW44 ST JOHNS WOOD & MAYFAIR	<b>Zone No.:</b>	350
		<b>Population:</b>	58842
<b>Time Period:</b> 01/01/2014 to 31/12/2014			
<b>Date extracted:</b> 10/04/2015			

**Commentary on Water Quality:**

Excellent quality water with no infringements to report for the Water Supply Zone.

**NOTES:**

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone