

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

Water Supply Zone:		SWA19	AYLESBURY EAST CHOLESBURY			Zone No.:		272
						Population:		4673
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value (all samples)			No. of Samples		
Date extracted: 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	24	0	0
<i>E. coli</i>	no./100ml	0	0	0	0	24	0	0
<i>Enterococci</i>	no./100ml	0	0	0	0	8	0	0
<i>Clostridium perfringens</i>	no./100ml	0	0	0	0	8	0	0
Colony count 22°C	cfu/ml	-	0	0.25	2	12	0	0
Colony count 37°C	cfu/ml	-	0	0.25	3	12	0	0
Residual Disinfectant	mg/l	-	0.22	0.275	0.42	24	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.400	<0.767	<0.800	12	0	0
Hydrogen Ion	pH	6.50-9.50	7.1	7.258	7.5	12	0	0
Turbidity	FTU	4	<0.060	0.068	0.08	12	0	0
Conductivity at 20°C	uS/cm	2500	514	543.25	555	12	0	0
Ammonium as NH4	mg/l	0.5	<0.030	<0.030	<0.030	12	0	0
Chloride as Cl	mg/l	250	18	21.633	26.36	8	0	0
Sodium as Na	mg/l	200	8.6	11.1	13.2	9	0	0
Sulphate as SO4	mg/l	250	12.4	15.775	17.9	8	0	0
Nitrate as NO3	mg/l	50	23.7	27.188	30.7	8	0	0
Nitrite as NO2	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.47	0.544	0.61	8	0	0
Total Organic Carbon as C	mg/l	-	0.3	0.4	0.7	8	0	0
Total Hardness as CaCO3	mg/l	N/A	287	293	298	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	6	0	0
Taste (quantatative)	dilution no.	0	0	0	0	6	0	0
Iron as Fe	ug/l	200	<1.000	1.975	2.7	12	0	0
Manganese as Mn	ug/l	50	<0.200	1.225	4.8	8	0	0
Aluminium as Al	ug/l	200	<1.400	2.875	9.3	8	0	0
Antimony as Sb	ug/l	5	<0.700	<0.788	<0.800	8	0	0
Arsenic as As	ug/l	10	<0.300	<0.300	<0.300	8	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	8	0	0
Chromium as Cr	ug/l	50	<0.900	1.425	4	8	0	0
Copper as Cu	mg/l	2	0.007	0.037	0.073	8	0	0
Lead as Pb	ug/l	10	<0.200	0.238	0.5	8	0	0
Mercury as Hg	ug/l	1	<0.040	<0.084	<0.090	8	0	0
Nickel as Ni	ug/l	20	<1.300	<1.300	<1.300	8	0	0
Fluoride as F	mg/l	1.5	0.079	0.113	0.172	8	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	8	0	0
Boron as B	mg/l	1	<0.011	0.015	0.02	8	0	0
Bromate as BrO3	ug/l	10	<0.700	<0.700	<0.700	8	0	0
Cyanide as CN	ug/l	50	<0.700	<0.700	<0.700	8	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	0	3.025	7.9	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b> SWA19 AYLESBURY EAST CHOLESBURY			<b>Zone No.:</b> 272		<b>Population:</b> 4673			
<b>Time Period:</b> 01/01/2014 to 31/12/2014			<b>Concentration or Value (all samples)</b>			<b>No. of Samples</b>		
<b>Date extracted:</b> 10/04/2015								
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	0.005	0.007	8	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bromoxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Chlortoluron	ug/l	0.1	<0.003	0.003	0.006	8	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	8	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	8	0	0
Dichlorprop	ug/l	0.1	<0.002	<0.004	<0.006	8	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Fluroxypyr	ug/l	0.1	<0.003	<0.005	<0.006	8	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Ioxynil	ug/l	0.1	<0.002	<0.005	<0.005	8	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	8	0	0
MCPA	ug/l	0.1	<0.002	<0.005	<0.006	8	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	8	0	0
Pentachlorophenol	ug/l	0.1	<0.002	<0.004	<0.004	8	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Simazine	ug/l	0.1	<0.005	0.006	0.007	8	0	0
2,4,5-T	ug/l	0.1	<0.003	<0.005	<0.005	8	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
2,4-DB	ug/l	0.1	<0.004	<0.005	<0.005	8	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Picloram	ug/l	0.1	<0.005	<0.007	<0.008	8	0	0
Triclopyr	ug/l	0.1	<0.003	<0.005	<0.005	8	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Metaldehyde	ug/l	0.1	<0.005	<0.006	<0.006	8	0	0
Total Pesticides	ug/l	0.5	0	0.005	0.013	8	0	0

NOTE: PCV = Prescribed Concentration or Value

**THAMES WATER UTILITIES**  
**WATER QUALITY REPORT - 2014 DATA**

<b>Water Supply Zone:</b>	SWA19	AYLESBURY EAST CHOLESBURY	<b>Zone No.:</b> 272
			<b>Population:</b> 4673
<b>Time Period:</b> 01/01/2014 to 31/12/2014			
<b>Date extracted:</b> 10/04/2015			

**Commentary on Water Quality:**

Excellent quality water with no infringements to report for the Water Supply Zone.

**NOTES:**

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone