

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:		G 3	GODALMING			Zone No.: 162		
						Population: 31557		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		
Date extracted: 10/04/2015			(all samples)					
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Coliform bacteria	no./100ml	0	0	0	0	84	0	0
E. coli	no./100ml	0	0	0	0	84	0	0
Enterococci	no./100ml	0	0	0	0	8	0	0
Clostridium perfringens	no./100ml	0	0	0	0	53	0	0
Colony count 22°C	cfu/ml	-	0	0.222	5	36	0	0
Colony count 37°C	cfu/ml	-	0	1.083	36	36	0	0
Residual Disinfectant	mg/l	-	0.14	0.42	0.64	84	0	0
Colour (Pt/Co scale)	mg/lPt/Co	20	<0.200	0.908	3.2	36	0	0
Hydrogen Ion	pH	6.50-9.50	7.2	7.372	8	36	0	0
Turbidity	FTU	4	<0.060	0.088	0.24	36	0	0
Conductivity at 20°C	uS/cm	2500	363	406.278	447	36	0	0
Ammonium as NH4	mg/l	0.5	<0.030	0.03	0.04	36	0	0
Chloride as Cl	mg/l	250	53.14	57.233	63.46	8	0	0
Sodium as Na	mg/l	200	30	32.15	35.8	8	0	0
Sulphate as SO4	mg/l	250	20.3	25.013	28.6	8	0	0
Nitrate as NO3	mg/l	50	13.5	18.7	22	8	0	0
Nitrite as NO2	mg/l	0.5	<0.010	<0.010	<0.010	8	0	0
Nitrate/Nitrite calculation	mg/l	1	0.27	0.374	0.44	8	0	0
Total Organic Carbon as C	mg/l	-	0.9	1.213	1.8	8	0	0
Total Hardness as CaCO3	mg/l	N/A	114	129	143	2	0	0
Odour (quantatative)	dilution no.	0	0	0	0	18	0	0
Taste (quantatative)	dilution no.	0	0	0	0	18	0	0
Iron as Fe	ug/l	200	<2.000	19.822	185	37	0	0
Manganese as Mn	ug/l	50	0.2	1.211	10.3	37	0	0
Aluminium as Al	ug/l	200	<1.400	3.946	10.5	37	0	0
Antimony as Sb	ug/l	5	<0.500	<0.767	<0.800	9	0	0
Arsenic as As	ug/l	10	<0.300	<0.300	<0.300	9	0	0
Cadmium as Cd	ug/l	5	<0.100	<0.100	<0.100	9	0	0
Chromium as Cr	ug/l	50	1	1.263	1.6	8	0	0
Copper as Cu	mg/l	2	0.006	0.052	0.328	9	0	0
Lead as Pb	ug/l	10	<0.200	0.611	3.6	9	0	0
Mercury as Hg	ug/l	1	<0.090	<0.090	<0.090	8	0	0
Nickel as Ni	ug/l	20	1.8	3.363	5.9	8	0	0
Fluoride as F	mg/l	1.5	0.109	0.144	0.194	8	0	0
Selenium as Se	ug/l	10	<0.800	<0.800	<0.800	9	0	0
Boron as B	mg/l	1	0.022	0.027	0.029	8	0	0
Bromate as BrO3	ug/l	10	0.7	0.75	1.1	8	0	0
Cyanide as CN	ug/l	50	<0.700	0.75	1.1	8	0	0
PAHs (Sum of 4 substances)	ug/l	0.1	0	0	0	8	0	0
Benzo (a) pyrene	ug/l	0.01	<0.001	<0.001	<0.001	8	0	0
Trihalomethanes	ug/l	100	43.6	48.788	57.3	8	0	0
Tetra- & Trichloroethene calc	ug/l	10	0	0	0	8	0	0
Tetrachloromethane	ug/l	3	<0.200	<0.200	<0.200	8	0	0
1,2 dichloroethane	ug/l	3	<0.200	<0.263	<0.300	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone: G 3			GODALMING			Zone No.: 162		
						Population: 31557		
Time Period: 01/01/2014 to 31/12/2014			Concentration or Value			No. of Samples		
Date extracted: 10/04/2015			(all samples)					
Parameter	Units	PCV	Min.	Mean	Max.	Total	Contra-vening	% of samples contravening PCV
Benzene	ug/l	1	<0.100	<0.100	<0.100	8	0	0
Atrazine	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bentazone	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Bromoxynil	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Carbetamide	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Chlortoluron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Clopyralid	ug/l	0.1	<0.009	<0.010	<0.010	8	0	0
2,4-D	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Dicamba	ug/l	0.1	<0.007	<0.007	<0.007	8	0	0
Dichlorprop	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Diuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Fluroxypyr	ug/l	0.1	<0.006	<0.006	<0.006	8	0	0
Isoproturon	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Ioxynil	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Linuron	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Mecoprop	ug/l	0.1	<0.003	<0.007	<0.008	8	0	0
MCPA	ug/l	0.1	<0.004	<0.006	<0.006	8	0	0
MCPB	ug/l	0.1	<0.004	<0.005	<0.008	8	0	0
Pentachlorophenol	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Propazine	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Prometryn	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Propyzamide	ug/l	0.1	<0.004	<0.004	<0.004	8	0	0
Simazine	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
2,4,5-T	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Terbutryn	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
2,4-DB	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Fenoprop	ug/l	0.1	<0.003	<0.004	<0.004	8	0	0
Monuron	ug/l	0.1	<0.003	<0.003	<0.003	8	0	0
Picloram	ug/l	0.1	<0.005	<0.008	<0.008	8	0	0
Triclopyr	ug/l	0.1	<0.005	<0.005	<0.005	8	0	0
Tebuthiuron	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Ametryne	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Carbendazim	ug/l	0.1	<0.002	<0.002	<0.002	8	0	0
Metaldehyde	ug/l	0.1	<0.006	0.014	0.057	8	0	0
Total Pesticides	ug/l	0.5	0	0.011	0.057	8	0	0
Gross alpha activity	Bq/l	0.1	0.04	0.041	0.05	8	0	0
Gross beta activity	Bq/l	1	0.08	0.096	0.16	8	0	0

NOTE: PCV = Prescribed Concentration or Value

THAMES WATER UTILITIES
WATER QUALITY REPORT - 2014 DATA

Water Supply Zone:	G 3	GODALMING	Zone No.:	162
			Population:	31557
Time Period: 01/01/2014 to 31/12/2014				
Date extracted: 10/04/2015				

Commentary on Water Quality:

Excellent quality water with no infringements to report for the Water Supply Zone.

NOTES:

For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone