

INSTRUMENT SYMBOL LIST

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
CP	COMPOUND GAUGE	SAH	SALINITY ALARM HIGH
DPI	DIFFERENTIAL PRESS. INDICATOR	SD	SALINITY DETECTOR
DPS	DIFFERENTIAL PRESS. SWITCH	SI	SALINITY INDICATOR
DPT	DIFFERENTIAL PRESS. TRANSMITTER	TAH	TEMPERATURE ALARM HIGH
FD	FLOW DETECTOR	TAL	TEMPERATURE ALARM LOW
FS	FLOW SWITCH	TI	TEMPERATURE INDICATOR
FT	FLOW TRANSMITTER	TIAH	TEMP. INDICATOR ALARM HIGH
LAH	LEVEL ALARM HIGH	TIAL	TEMP. INDICATOR ALARM LOW
LAL	LEVEL ALARM LOW	TIAHL	TEMP. INDICATOR ALARM HIGH LOW
LCH	LEVEL CONTROL HIGH	TIC	TEMPERATURE INDICATING CONTROLLER
LCL	LEVEL CONTROL LOW	TS	TEMPERATURE SWITCH
LI	LEVEL INDICATOR	TT	TEMPERATURE TRANSMITTER
LIAHL	LEVEL INDICATOR ALARM HIGH LOW	VAH	VISCOSITY ALARM HIGH
LIC	LEVEL INDICATING CONTROLLER	VAL	VISCOSITY ALARM LOW
LS	LEVEL SWITCH	VCA	VACUUM ALARM
LT	LEVEL TRANSMITTER	VCT	VACUUM TRANSMITTER
PAH	PRESSURE ALARM HIGH	VI	VISCOSITY INDICATOR
PAL	PRESSURE ALARM LOW	VIAHL	VISCOSITY INDICATOR ALARM HIGH LOW
PI	PRESSURE INDICATOR	VT	VISCOSITY TRANSMITTER
PIAH	PRESS. INDICATOR ALARM HIGH	VIC	VISCOSITY INDICATING CONTROLLER
PIAL	PRESS. INDICATOR ALARM LOW	XA	ABNORMAL ALARM
PIAHL	PRESS.INDICATOR ALARM HIGH LOW	XS	AUX. UNSPECIFIED SWITCH
PIC	PRESSURE INDICATING CONTROLLER	ZI	POSITION INDICATOR
PS	PRESSURE SWITCH	ZS	LIMIT SWITCH
PSL	PRESSURE LOW SWITCH	EP	E/P TRANSDUCER
PT	PRESSURE TRANSMITTER	RS	REMOTE SOUNDING (AIR PURGE TYPE)