



The Kenya Power & Lighting Co. Ltd.
Central Office – P.O. Box 30099, Nairobi, Kenya
Telephone – 254-02-3201000
Fax No. 254-02-3201889
Stima Plaza, Kolobot Road

Our Ref: KP1/9A.2/OT/023/ICT/20-21/JN/rmh

16th December 2020

M/s

Dear Sir/Madam,

ADDENDUM NO. 1 TO THE TENDER NO. KP1/9A.2/OT/023/ICT/20-21 FOR PROCUREMENT OF FIBER OPTIC CABLE SPARES, FITTINGS AND ACCESSORIES

The following clarifications are made to the specified provisions of the Tender document.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the Principal Tender Document shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read as part of the Principal Tender Document.

2. CLARIFICATIONS MADE TO QUERIES ON THE TENDER DOCUMENT

No.	Clarifications	Response
1.	Is the patchcord diameter simplex or duplex?	The patch cords shall be duplex
2.	Please note the patchcord diameter are either 2.0mm or 3.0mm, No manufacturer do 0.9mm as you have indicated in the specifications.	The cable size for the Low insertion loss SM Fiber patch cables shall be 3mm
3.	Names with full contact as well as physical addresses of previous customers of similar goods and reference letters from at least four (4) previous customers. Confirm this with respect to the manufacturer as a supplier in Kenya has only supplied KPLC has no 4 other customers	This is not a requirement as per the evaluation criteria set in the tender document
4.	Technical clarification Confirm ❖ If The suspension need to come with inner rod	The suspension clamp assembly shall consist of the housing, rubber insert, eye chain link and anchor

	<ul style="list-style-type: none"> ❖ If The tension clamps need to come with Guy Grip as there is an item with Guy grips ❖ If item for Guy grip is PC's and not pairs. 	<p>shackle only as specified in SECTION XIX part B-DTS sub-section 1.2.2 and illustrated in Fig 2 & Fig 3</p> <p>The tension clamps are to be supplied as complete in themselves – Fig 4 in SECTION XIX part B-DTS sub-section 1.2.3 is only for illustration of the use of tension clamp.</p> <p>The schedule of requirement for guy grips is as presented in Section IV, Part A, item 6 and the unit of measure is "piece"</p>
--	--	--

3. TENDER CLOSING DATE

The tender **closing date** remains **23rd December 2020, 10.00am** as communicated in the tender document.

All other terms and conditions remain as per the Principal Tender Document (PTD)

Yours faithfully,

For: **THE KENYA POWER & LIGHTING CO. PLC**

JANE MUIGAI
SUPPLY CHAIN MANAGER, PROCUREMENT