

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name **Riverpark RV Resort**

PWS ID# 41 91911

Month/Year Sept / 2026 Entry Point: WTP-A

Required Minimum Residual **1.0** mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:00am	House @ 2960 address	1.4	The water source is from the same well
2	9:00am	House @ 2960 address	1.3	
3	9:00am	House @ 2960 address	1.2	Just on the hill above the park
4	9:00am	House @ 2960 address	1.2	
5	9:00am	House @ 2960 address	1.3	
6	9:00am	House @ 2960 address	1.3	
7	9:00am	House @ 2960 address	0	
8	9:00am	House @ 2960 address	0	
9	9:00am	House @ 2960 address	0	
10	9:00am	House @ 2960 address	0	
11	9:00am	House @ 2960 address	0	
12	9:00am	House @ 2960 address	0	
13	9:00am	House @ 2960 address	0	
14	9:00am	House @ 2960 address	0	
15	9:00am	House @ 2960 address	0	
16	9:00am	House @ 2960 address	0	
17	9:00am	House @ 2960 address	1.3	
18	9:00am	House @ 2960 address	1.4	
19	9:00am	House @ 2960 address	1.5	
20	9:00am	House @ 2960 address	1.4	
21	9:00am	House @ 2960 address	1.7	
22	9:00am	House @ 2960 address	1.8	
23	9:00am	House @ 2960 address	1.8	
24	9:00am	House @ 2960 address	1.7	
25	9:00am	House @ 2960 address	1.6	
26	9:00am	House @ 2960 address	1.5	
27	9:00am	House @ 2960 address	1.4	
28	9:00am	House @ 2960 address	1.4	
29	9:00am	House @ 2960 address	1.5	
30	9:00am	House @ 2960 address	1.4	
31	9:00am	House @ 2960 address	1.6	

Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Kaden White

Title: Park Manager

Operator Certification #:

Signature: K. White

Phone #: (541) 295-1269

OR

Date: 10 / 06 / 26

Small Groundwater System ☐

Return by 10th of following month by either email dwpmce@odhsoha.oregon.gov; fax 971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019