



Warning

Electrical Shock & Flash Hazard

Equipment Name: XRGI-3_GEN

Electrical Shock Hazard

Voltage Level: 0.600 V

Approach Distances

Limited Distance: 42 inches

Restricted Distance: 12 inches

Glove Class: 0

Insulated Tools: 1



Arc Flash Hazard

Max Energy: 1.26 cal/cm²

Arc Flash Approach Boundary:
18.5 in

Working Distance: 17.9 inches

Clothing Level: 1

Face Shield: RQ

Suit Hood: NR



RQ: Required NR: Not Required NM: Non Melting AN: As Needed

ALWAYS WEAR EYE PROTECTION!

Analysis Date: 2017-02-2

Modifications of equipment or substantial changes in short-circuit current available may void results of the Arc Flash Hazard Analysis Study and values displayed on this Label. To maintain accuracy, Arc Flash review/update should be performed within 5 years of latest study/review (CSA Z462 Section 4). For more info contact PowerCore Eng. at (519) 474-1175 or online at www.PowerCore.ca.