



# Warning

Electrical Shock & Flash Hazard

Equipment Name: PL-A\_PNL

## Electrical Shock Hazard

Voltage Level: 0.480 V

### Approach Distances

Limited Distance: 42 inches

Restricted Distance: 12 inches

Glove Class: 00

Insulated Tools: RQ



## Arc Flash Hazard

Max Energy: 0.11 cal/cm2

### Arc Flash Approach Boundary:

4.9 in

Working Distance: 24.0 inches

Clothing Level: NM

Face Shield: AN

Suit Hood: NR



RQ: Required NR: Not Required NM: Non Melting AN: As Needed

**ALWAYS WEAR EYE PROTECTION!**

Analysis Date: 2017-02-2

Modifications of equipment or substantial changes in short-circuit current available may void results of the Arc Flash Hazard Analysis Study and values displayed on this Label. To maintain accuracy, Arc Flash review/update should be performed within 5 years of latest study/review (CSA Z462 Section 4). For more info contact PowerCore Eng. at (519) 474-1175 or online at [www.PowerCore.ca](http://www.PowerCore.ca).