



SALAS O'BRIEN
3200 WINDY HILL ROAD SE
SUITE 200E
ATLANTA, GEORGIA 30339
PHONE 404-881-5300

Project: Camden Farms; Sterling Residential
Location: Jefferson, GA
Description: Finley - 2A, Slab, CBonus, ACH50

Date: March 22, 2024
By: TJH
House Faces: Worst NorthEast

These Loads are dependent on the information/assumptions listed below. **Any deviation from these assumptions during construction could have a significant impact on the cooling and heating loads for this house and render the recommended equipment sizing invalid.** If any of these assumptions are incorrect, please let us know immediately so we can re-calculate them. This information will be used in a residential heating and cooling load program based on calculations recommended by ASHRAE, Handbook of Fundamentals. Equipment sizing indicated in this report is valid only upon verification that actual construction is in full compliance with the descriptions below and independent testing of HVAC systems has been performed; such verification and testing shall be performed by Vallus.

BUILDING DATA	
Typical Ceiling Height	9.0 ft
Floor Area	2,567 ft ²
Volume	24,267 ft ³
Percentage Glass	12 %
Number of Bedrooms	4

DESIGN CONDITIONS		
	Summer	Winter
Outdoor	95 °Fdb	18 °Fdb
Indoor	75 °Fdb	72 °Fdb
ΔT	20 °Fdb	54 °Fdb
Range	17.3 °Fdb	

ENERGY CALCULATIONS	
Right Choice HVAC kWh	10780
SEER	14
ACH50	3.0
Mechanical Ventilation	YES
House Outside Air CFM	75

CONSTRUCTION DESCRIPTIONS						
Walls / Partitions	#	U-Value	Description/Notes			
	W1	0.077	Above Grade	2x4	R-13 batt	
	W2	0.067	Basement	Concrete + 2x4	R-13 batt	
	W3	0.053	Attic	2x6	R-19 batt	
Doors	#	U-Value	Description/Notes			
	D1	0.167	Exterior Door		R-6	
	D2	0.5	Garage Door		R-2	
Roofs	#	U-Value	Description/Notes			
	R1	0.046	Flat Ceiling		R-20 sprayed	
	R2	0.05	Vaulted		R-20 sprayed	
Floors	#	U-Value	Description/Notes			
	F1	0.053	Framed		R-19 batt	
	F2	0.1	Slab		None	
Glass	#	Glass Type	Windows	U-Value	Internal Shading	Notes
	G1	Double Insulated	All types	0.29	Blinds/Draperies	SHGC 0.20
	G2					
	G3					

LOAD SUMMARY					
			Unit 1 - Whole House		
			Cooling	Heating	
Sensible Load			29424 Btu/hr	36835 Btu/hr	
Minimum Nominal Capacity			3.27 Tons	10.79 kW	
Load Density			785 SF/Ton	4.2 W/SF	
Floor Area Served			2567.0 SF	2567.0 SF	
Mechanical Ventilation			75 CFM	75 CFM	
System Size			3.5 Tons	15.0 kW	
Leaving Air Temperature			55.6 deg F	106.5 deg F	
Installed Capacity			733 SF/Ton	5.8 W/SF	

I understand the information provided herein, and warrant, to the best of my ability and knowledge, and to the full extent of my control as the Contractor, that this house will be built in accordance with the information given above.

Signed _____ Title _____ Date _____

Date: March 22, 2024
By: TJH
House Faces: Worst NorthEast

[illegible]

Unit 1

Size

3.50

Tons

Airflow

1400

CFM

Heat kW

15

kW

First Floor Airflows

Room	CFM Cool	CFM Heat	CFM Avg	Duct Size
Foyer & Gar Entry	60	94	77	
Dining	55	88	72	
Hall	23	27	25	
Bed 2	88	121	105	
Bath	24	34	29	
Bed 3	97	107	102	
Breakfast	75	75	75	
Kitchen	164	50	107	
Great Rm	192	200	196	
Master Bed	167	175	171	
Master Bath	44	60	52	
Master WIC	35	45	40	
Laundry	50	17	34	
Powder	11	12	11	

[illegible]

Project:Camden Farms; Sterling Residential

Location:Jefferson, GA

Description:Finley - 2A, Slab, CBonus, ACH50

Date: March 22, 2024

By: TJH

Level(s): First Floor

SEER 14

Square Feet 1981 Volume 18993 SF/Ton 792

Typical Ceiling Height9

Kneewall Height1

Cooling Size2.5

Heating Size2.5

Best Case2.5

DX Cooling kWh3041

RC Heating kWh5422

Total kWh8463

COOLING LOAD CALCULATION						Ceiling Height		9		9		9		9		9		9		12		9		9		9		9		9								
Components					CLTD (°F)	U-Value (Btu/hr-sq-Ft)	Cooling Load Factor		Entire House		Foyer & Gar Entry		Dining		Hall		Bed 2		Bath		Bed 3		Breakfast		Kitchen		Great Rm		Master Bed		Master Bath		Master WIC		Laundry		Powder	
	Type	Description		Qty			Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	
Glass	G1	NorthWest	Right	(E)	16	Btu/hr-sf	38	623			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	30	492	8	131		-	-	-	-	-		
	G1	North		(SE)	5	Btu/hr-sf	0	0			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	G1	NorthEast	Front	(S)	7	Btu/hr-sf	0	0			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	G1	East		(SW)	12	Btu/hr-sf	0	0			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	G1	SouthEast	Left	(W)	13	Btu/hr-sf	6	76			-	-	-	-	-	6	76		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	G1	South		(NW)	14	Btu/hr-sf	0	0			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	G1	SouthWest	Back	(N)	23	Btu/hr-sf	75	1761			-	-	-	-	-	-	15	352	30	704		-	-	-	-	-	30	704		-	-	-	-	-	-			
	G1	West		(NE)	26	Btu/hr-sf	0	0			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	G1	Sky Light			41	Btu/hr-sf	0	0			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
Door	G1	Shaded			5	Btu/hr-sf	133	710			31.34	167	36	192		-	36	192		-		-	-	-	-	30	160		-	-	-	-	-	-	-	-		
	D1	Door		21	0.17	3.51	Btu/hr-sf	10	35		5	18		-		-	-	-		-		-	-	-	5	18		-	-	-	-	-	-	-	-	-		
Above Grade Walls	D2	Door		30	0.50	15.00	Btu/hr-sf	20	300		20	300		-		-	-	-		-		-	-	-	-	-	5	18		-	-	-	-	-	-			
	W1	NorthWest		19	0.08	1.46	Btu/hr-sf	372	544		-	-	15	22	-	-	-	-	-	20	29	-	-	-	-	-	-	138	202	110	161	88	129	-	-	-		
	W1	North		13	0.08	1.00	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	NorthEast		19	0.08	1.46	Btu/hr-sf	222	324		44	64	82	120	-	-	96	140	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	W1	East		23	0.08	1.77	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	SouthEast		21	0.08	1.62	Btu/hr-sf	389	629		15	24	-	-	-	-	145	234	74	120	155	251	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	W1	South		16	0.08	1.23	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	SouthWest		21	0.08	1.62	Btu/hr-sf	499	806		-	-	-	-	-	-	-	-	97	156	98	159	-	-	-	175	283	128	207	-	-	-	-	-	-	-		
	W1	West		23	0.08	1.77	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
Basement Walls	W1	NorthWest		19	0.08	1.46	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	North		13	0.08	1.00	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	NorthEast		19	0.08	1.46	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	East		23	0.08	1.77	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	SouthEast		21	0.08	1.62	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	South		16	0.08	1.23	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	SouthWest		21	0.08	1.62	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	West		23	0.08	1.77	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W2	Grade		0	0.07	0.00	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
Other	W1	Partition		10	0.08	0.77	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W1	Garage		30	0.08	2.31	Btu/hr-sf	193	445		20	46		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	114	264	-	-	58	135		
	W3	Attic		15	0.05	0.80	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	W3	Kneewall		15	0.05	0.80	Btu/hr-sf	269	214		21	17	30	24		-	-	-	-	-	-	-	-	-	-	171	136	48	38		-	-	-	-	-			
Floor	R1	Ceiling		55	0.05	2.53	Btu/hr-sf	1870	4731		102	258	142	359	91	230	178	450	54	137	173	438	112	283	169	428	388	982	267	676	110	278	31	78	53	134	-	
	R2	Vaulted		55	0.05	2.75	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	F1	Crawl/Uncon.		11	0.05	0.58	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	F2	Garage		30	0.05	1.59	Btu/hr-sf	0	0		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
Internal	F1	Slab		0	0.10	0.00	Btu/hr-sf	1981	0		111	-	142	-	91	-	178	-	54	-	173	-	112	-	169	-	388	-	267	-	119	-	83	-	60	-	34	-
	People				255	Btu/hr	4	1020		-	-	-	-	-	1	255		-	1	255		-	-	-	-	1	255		1	255		-	-	-	-	-		
Vent	Lights (W)				3.413	Btu/hr-W	994	3393		56	191	71	242	46	157	89	304	27	92	87	297	56	191	85	290	194	662	134	457	60	205	42	143	30	102	17	58	
	Appliances (W)				3.413	Btu/hr-W	1130	3857		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	680	2,321	250	853		-	-	200	683		-	-		
	Infiltration		58.70	CFM	0.07	Btu/hr-cf		1268		67		85		55		107		32		104		67		102		311		160		71		50		36		20		
	Volume				CF		18993		999		1278		819		1602		486		1557		1008		1521		4656		2403		1071		747		540		306			
Area					SF		1981		111		142		91		178		54		173		112		169		388		267		119		83		60		34			
	Subtotal (Btu/hr)						20736		1151		1045		442		1682		457		1853		1434		3140		3659		3192		847		665		955		213			
Safety Factor							10 %		2074																													
Sensible Cooling Load (Btu/hr)							22810																															
Nominal Tons Required (75% sens. cap.)							2.53																															
System Selection						2.5 Tons	Space CFM		1000		56		50		21		81		22		89		69		151		176		154		41		32		46		10	

HEATING LOAD CALCULATION						Ceiling Height		9		9		9		9		9		9		12		9		9		9		9		9								
Components					AT (°F)	U-Value (Btu/hr-sq-Ft)	Heating Load Factor		Entire House		Foyer & Gar Entry		Dining		Hall		Bed 2		Bath		Bed 3		Breakfast		Kitchen		Great Rm		Master Bed		Master Bath		Master WIC		Laundry		Powder	
	Type	Description		Qty			Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	
Glass	G2			54	0.29	15.7	Btu/hr-sf	252	3952	31.34	491	36	564	0	-	36	564	6	94	15	235	30	470	0	-	30	470	60	940	8	125	0	-	0	-	0	-	
	G2			54	0.00	0.0	Btu/hr-sf	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
	G3			54	0.00	0.0	Btu/hr-sf	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
	D1			54	0.17	9.0	Btu/hr-sf	10	90	5	45	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	45	0										

Project:Camden Farms; Sterling Residential

Location:Jefferson, GA

Description:Finley - 2A, Slab, CBonus, ACH50

Date:March 22, 2024

By:TJH

Level(s):Second Floor

Square Feet586

Volume5274

SF/Ton781

SEER14

Typical Ceiling Height9

Kneewall Height5

Cooling Size0.75

Heating Size0.75

Best Case0.75

DX Cooling kWh882

RC Heating kWh1435

Total kWh2317

COOLING LOAD CALCULATION						Ceiling Height		9		9		9		9		9		9		9		9		9		9			
Components				CLTD (°F)	U-Value (Btu/hr-sq-Ft)	Cooling Load Factor	Entire House		Stairs		Bonus WIC		Bonus		Bonus Bath														
	Type	Description	Qty				Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr
Glass	G1	NorthWest	Right	(E)	16 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	North		(SE)	5 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	NorthEast	Front	(S)	7 Btu/hr-sf	15	102	-	-	-	15	102	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	East		(SW)	12 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	SouthEast	Left	(W)	13 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	South		(NW)	14 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	SouthWest	Back	(N)	23 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	West		(NE)	26 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	G1	Sky Light			41 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
G1	Shaded			5 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
Door	D1	Door	21	0.17	3.51 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	D2	Door	15	0.50	7.50 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Above Grade Walls	W1	NorthWest	19	0.08	1.46 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	North	13	0.08	1.00 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	NorthEast	19	0.08	1.46 Btu/hr-sf	167	244	-	-	-	167	244	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	East	23	0.08	1.77 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	SouthEast	21	0.08	1.62 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	South	16	0.08	1.23 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	SouthWest	21	0.08	1.62 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	West	23	0.08	1.77 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	NorthWest	19	0.08	1.46 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Basement Walls	W1	North	13	0.08	1.00 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	NorthEast	19	0.08	1.46 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	East	23	0.08	1.77 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	SouthEast	21	0.08	1.62 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	South	16	0.08	1.23 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	SouthWest	21	0.08	1.62 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	West	23	0.08	1.77 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W2	Grade	0	0.07	0.00 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W1	Partition	10	0.08	0.77 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Other	W1	Garage	30	0.08	2.31 Btu/hr-sf	33	75	33	75	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W3	Attic	15	0.05	0.80 Btu/hr-sf	434	345	139	111	140	111	19	15	136	108	-	-	-	-	-	-	-	-	-	-	-	-	-	
	W3	Kneewall	15	0.05	0.80 Btu/hr-sf	222	176	-	-	-	222	176	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	R1	Ceiling	55	0.05	2.53 Btu/hr-sf	216	546	87	220	50	127	33	83	46	116	-	-	-	-	-	-	-	-	-	-	-	-	-	
Roof	R2	Vaulted	55	0.05	2.75 Btu/hr-sf	523	1439	-	-	-	370	1,439	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	F1	Crawl/Uncon.	11	0.05	0.58 Btu/hr-sf	0	0	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	F1	Garage	30	0.05	1.59 Btu/hr-sf	391	622	-	-	-	391	622	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	F2	Slab	0	0.10	0.00 Btu/hr-sf	83	0	83	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Internal	People				255 Btu/hr	1	255	-	-	-	1	255	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Lights (W)				3,413 Btu/hr-W	294	1003	44	150	25	85	202	689	23	78	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Appliances (W)				3,413 Btu/hr-W	250	853	-	-	-	250	853	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Infiltration	16.3	CFM		0.067 Btu/hr-cf		352		52		30		242		28														
Vent.	Volume				CF	5274		783		450		3627		414		0		0		0		0		0		0		0	
	Area				SF	586		87		50		403		46															
Subtotal (Btu/hr)							6013		608		353		4721		330		0		0		0		0		0		0		0
Safety Factor							601																						
Sensible Cooling Load (Btu/hr)							6615																						
Nominal Tons Required (75% sens. cap.)							0.73																						
System Selection 0.75 Tons Space CFM							300		30		18		236		16		-		-		-		-		-		-		
HEATING LOAD CALCULATION																													
Components					ΔT (°F)	U-Value	Heating Load Factor	Entire House		Stairs		Bonus WIC		Bonus		Bonus Bath		0		0		0		0		0		0	
	Type	Description	Qty	Btu/hr				Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr	Qty	Btu/hr
Glass	G1		54	0.29	15.7 Btu/hr-sf	15	235	0	-	0	-	15	235	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	G2		54	0.00	0.0 Btu/hr-sf	0	0	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	G3		54	0.00	0.0 Btu/hr-sf	0	0	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
Door	D1		54	0.17	9.0 Btu/hr-sf	0	0	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	D2		54	0.50	27.0 Btu/hr-sf	0	0	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
Walls	W1		54	0.08	4.2 Btu/hr-sf	167	693	0	-	0	-	166.7	693	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	W2		54	0.07	3.6 Btu/hr-sf	0	0	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	W3		54	0.05	2.9 Btu/hr-sf	656	1877	139.2	398	140	401	240.9	689	135.8	389	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	W1	Partition	27	0.08	2.1 Btu/hr-sf	33	68	32.5	68	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
Floor	W2	Grade	27	0.07	1.8 Btu/hr-sf	0	0	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	R1		54	0.05	2.5 Btu/hr-sf	216	537	87	216	50	124	33	82	46	114	0	-	0	-	0	-	0	-	0	-	0	-	0	-
Roof	R2		54	0.05	2.7 Btu/hr-sf	370	999	0	-	0	-	370	999	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	F1		54	0.05	2.9 Btu/hr-sf	391	1119	0	-	0	-	391	1,119	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
	F2	Slab	27	0.10	2.7 Btu/hr-sf	83	224	83	224	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-	0	-
Area					SF	586		87		50		403		46		0		0		0		0		0		0		0	
	Infiltration	16.30	CFM		0.18 Btu/hr	0	951		141		81		65																