





FABRICATION MATERIALS

PT NO	DESCRIPTION	NPD (IN)	CLIENT CODE	QTY
1	PIPE ; ASME B36.10M ; BE ; A106-B ; SMLS ; GALV.,S-40	2	I155790983	5.8M
2	TEE RED ; ASME B16.9 ; BE ; A234-WPB-S ; GALV.,S-40xS-80	2X3/4	I155794624	1
3	NIPPLE ; ASME B36.10M ; PE x MTE ; A106-B ; L = 100 MM ; GALV.,S-160	3/4	I429704506	1
4	E90LR ; ASME B16.9 ; BE ; A234-WPB-S ; GALV.,S-40	2	I155791817	2

ERECTION MATERIALS

PT NO	DESCRIPTION	NPD (IN)	CLIENT CODE	QTY
5	PIPE ; ASME B36.10M ; BE ; A106-B ; SMLS ; GALV.,S-40	2	I155790983	23.8M
6	FLG THD ; ASME B16.5 ; CL150 ; RF ; A105 ; GALV.	3/4	I472177256	1
7	FLG BLIND ; ASME B16.5 ; CL150 ; RF ; A105 ; GALV.	3/4	I115473122	1
8	GSKT NON METALLIC ; ASME B16.21 ; CL150 ; RF ; RPTFE GYLON 3500 OR EQUAL ; THK 3 mm	3/4	I368194621	2
9	BLT STUD W/2 HVY NUT ; ASME B18.31.2 & B18.2.2 ; A193 GR.B7/A194 GR.2H ; W/2 WASHER; GALV. - 70 mm Length	X70	I537948375	8
10	GATE ; ASME B16.10 ; CL150 ; RF ; STD BORE, BLT BNT, OS&Y, SOL WG ; HANDWHEEL ; B62-UNS C83600 ;TRIM SAME AS BODY ;GRAPHITE PACKING	3/4	I560056231	1

PIPE SUPPORTS

PT NO	DESCRIPTION	NPD (IN)	CLIENT CODE	QTY
11	SC01-A-2-250	2	Pipe Support	11
12	GL02-2	2	Pipe Support	2
13	FR02-A-850-600-A-1	2	Pipe Support	3

WELD LIST

Joint No	Size	F/S	Weld Type	Material
F10	2"	FIELD	BW	1.1-
FS11	2"	SHOP	BW	1.1-2
FS12	2"	SHOP	BW	2-1.2
F13	2"	FIELD	BW	1.2-4.1
FS14	2"	SHOP	BW	4.1-1.3
FS15	2"	SHOP	BW	1.3-4.2
F16	2"	FIELD	BW	4.2-5.1
F17	2"	FIELD	BW	5.1-5.2
FS18	3/4"	SHOP	BW	2-3
T19	3/4"	FIELD	S	3-6

CUT PIPE LENGTH

No	Size	Length	No	Size	Length
1	2"	12000	2	2"	11740
3	2"	4933	4	2"	552
5	2"	298			

SPOOL NUMBERS

000207-PW-0003-SP01	000207-PW-0003-SP02
---------------------	---------------------

CAA-1 PROJECT
Cilegon, Banten, Indonesia



Chandra Asri

PT CHANDRA ASRI ALKALI

Confidential

ISSUE FOR REVIEW



China Chengda Engineering Co.,Ltd

Scale
1/1
@A3

Sheet
1 of 1

Project Doc Number :

Isometric drawing No:

00-42-0207-26-PW-0003-02

Contractor/Licensor Doc No:

2"-PW-0003-1C6-HC-02


Document Review Result

- ☐ Approved ☐ Reviewed with Comment
☐ Approved with Comments
☐ No Comment
☐ Rejected ☐ No Comment with Hold

Approved by :

Date :

LEGEND



Rev	Date	Description	Prepared	Checked	Approved	Authorized
1		THE INFORMATION CONTAINED IN THIS DOCUMENT IS CONFIDENTIAL AND/OR RESTRICTED, PRIVILEGED, AND ONLY FOR THE SOLE USE OF THE INTENDED RECIPIENT AND INTENDED PURPOSE. ANY FORM OF REPRODUCTION, DISSEMINATION, COPYING, DISCLOSURE, MODIFICATION AND/OR PUBLICATION IS STRICTLY PROHIBITED WITHOUT PRIOR WRITTEN CONSENT FROM PT CHANDRA ASRI ALKALI AND/OR FROM THE RELEVANT OWNER OF SUCH INFORMATION.				
ISOMATRIC NOTE:						
DESIGN TEMP.	deg C	65	OPE. TEMP.	deg C	-/AMB/-	PWHT
DESIGN PREESS.	kg/cm ² g	6	OPE. PREESS.	kg/cm ² g	-/2.5/-	PAINT SYSTEM
PT	%	-	RT	%	2	TEST PRESS.
INSULATION	CODE	HC	INSUL. THICK.	mm	30	TEST MEDIA