





FABRICATION MATERIALS

PT NO	DESCRIPTION	NPD (IN)	CLIENT CODE	QTY
1	PIPE ; ASME B36.10M ; PE ; A106-B ; SMLS,S-80	3/4	I233367988	0.7M
2	E90 ; ASME B16.11 ; CL3000 ; SW ; A105	3/4	I114596551	1
3	GATE ; VENDOR STD ; CL800 ; SW ; STD BORE, BLT BNT, OS&Y, SOL WG ; HANDWHEEL ; A105 ; TRIM CN8 ; GRAPHITE PACKING	3/4	I134685551	1

ERECTION MATERIALS

PT NO	DESCRIPTION	NPD (IN)	CLIENT CODE	QTY
4	NIPPLE ; ASME B36.10M ; PE x MTE ; A106-B ; L = 100 MM ; SMLS,S-160	3/4	I114595765	1
5	CAP ; ASME B16.11 ; CL3000 ; FTE ; A105	3/4	I185034517	1

WELD LIST					CUT PIPE LENGTH					
Joint No	Size	F/S	Weld Type	Material	No	Size	Length	No	Size	Length
F12	3/4"	FIELD	BW	1.1-*	1	3/4"	397	2	3/4"	264
FS13	3/4"	SHOP	SW	1.1-2						
F14	3/4"	FIELD	SW	2-1.2						
FS15	3/4"	SHOP	BW	1.2-3						
F16	3/4"	FIELD	BW	3-4						

SPOOL NUMBERS					
000207-WV-3520U-SP01			000207-WV-3520U-SP02		

CAA-1 PROJECT
Cilegon, Banten, Indonesia



Chandra Asri

PT CHANDRA ASRI ALKALI

Confidential

ISSUE FOR REVIEW



China Chengda Engineering Co.,Ltd

Scale
1/1
@A3

Sheet
1 of 1

Project Doc Number :

Isometric drawing No:
Contractor/Licensor Doc No:

00-42-0207-26-WV-3520U-02

0.75"-WV-3520U-C01-02


Document Review Result

- ☐ Approved
- ☐ Reviewed with Comment
- ☐ Approved with Comments
- ☐ No Comment
- ☐ Rejected
- ☐ No Comment with Hold

Approved by :

Date :

LEGEND



Rev	Date	Description	Prepared	Checked	Approved	Authorized
THE INFORMATION CONTAINED IN THIS DOCUMENT IS CONFIDENTIAL AND/OR RESTRICTED, PRIVILEGED, AND ONLY FOR THE SOLE USE OF THE INTENDED RECIPIENT AND INTENDED PURPOSE. ANY FORM OF REPRODUCTION, DISSEMINATION, COPYING, DISCLOSURE, MODIFICATION AND/OR PUBLICATION IS STRICTLY PROHIBITED WITHOUT PRIOR WRITTEN CONSENT FROM PT CHANDRA ASRI ALKALI AND/OR FROM THE RELEVANT OWNER OF SUCH INFORMATION.						
ISOMATRIC NOTE:						
DESIGN TEMP.	deg C	65	OPE. TEMP.	deg C	-/AMB/-	PWHT
DESIGN PREESS.	kg/cm ² g	8	OPE. PREESS.	kg/cm ² g	-/4/-	PAINT SYSTEM
PT	%	10	RT	%	5	TEST PRESS.
INSULATION	CODE	-	INSUL. THICK.	mm	-	TEST MEDIA