






## **Preliminary and Primary Wastewater Treatment Primary Sedimentation for Wastewater/Sewage Treatment** Exactly same as secondary sedimentation for water treatment in most respects However. 1. Particles removed in this case are mostly organic particles of density 1200 kg/m<sup>3</sup> 2. SOR = 32 $m^3/m^2/d$ , organic particles: 60 $\mu$ m, inorganic particles: 20 μm 3. SOR = 48 m $^3$ /m $^2$ /d, organic particles: 75 $\mu$ m, inorganic particles: 25 μm 4. Type II settling, hence smaller particles are also removed 5. SS removal: 50 - 70 %; BOD<sub>5</sub> removal: 25 – 40 % CE412A Design of Water Treatment and Waste Disposal Systems Dr Vinod Tare






























































































#### SOT calculation: (Generally specified by the manufacturer)

Fill up a 5x5x3 m or 6x6x4 m tank (depending on aerator size) with tap water

Aerate overnight. Measure DO in the morning. This is  $[\mathcal{O}_2]_l^s$  . Measure temp.

Add sodium sulfite to de-aerate water, i.e.,  $[O_2]_1 = 0.0$ 

Aerate from t = 0 to t = t. Measure  $[O_2]_1$  at various times during aeration.

Lecture 1

CE412A
Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

# Surface Aerator: Design Procedure (Continued) $\frac{d[O_{2}]_{l}}{dt} = K_{L}.a\{[O_{2}]_{l}^{s} - [O_{2}]_{l}\}$ Semi-Log Scale Integrating, $\int\limits_{\left[O_{2}\right]_{l}}^{0}\frac{d{\left[O_{2}\right]_{l}}}{\left\{ \left[O_{2}\right]_{l}^{s}-{\left[O_{2}\right]_{l}}\right\} }=\int\limits_{t}^{o}K_{L}.a.dt$ $ln\left\{\frac{[O_{_{2}}]_{l}^{s}}{[O_{_{2}}]_{l}^{s}-[O_{_{2}}]_{l}}\right\}=K_{_{L}}.a.t$ $\frac{d[O_2]_l}{dt} = k_L. a. ([O_2]_l^s - [O_2]_l)$ $V.\frac{d[O_2]_l}{dt} = k_L.a.\,([O_2]_l^s - [O_2]_l).V$ $(K_L.a)_{20} = \frac{(K_L.a)_T}{(1.02)^{T-20}}$ $SOT = (K_L.a)_{20}.[O_2]_l^{s_{20}}.(V)$ CE412A Design of Water Treatment and Waste Disposal Systems Dr Vinod Tare

### Energy requirements for maintaining completely mixed conditions in the aeration tank

For an aeration tank of volume V, the P/V ratio for maintaining completely mixed conditions is 15 - 20 W/m<sup>3</sup>

Hence in actual design power requirement in an aeration tank must be calculated both from O2 requirement and mixing perspectives, and the larger value adopted.

In many cases, the mixing requirement becomes the controlling factor for provision of power to the aeration tank

CE412A
Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

### Example Problem: Aerator Design

Given the oxygen requirement of 8400 kg/d, design the aeration system for an ASP using turbine aerators. Assume that two aeration tanks will be provided in parallel and depth of the tanks will be 4 m. Total volume of aeration tanks is 4320 m3. No nitrification occurs in the aeration tank. Turbine Aerators are available with power rating 10, 25, 50 KW with area of influence being 36 m<sup>2</sup>. Manufacturers specify that the oxygen transfer capacity of these aerators is 2.0 Kg O<sub>2</sub>/kW-h under standard conditions. Based on this information, design an adequate aerator arrangement for each aeration tank. The operating temperature of the aeration tank is expected to be 30°C. Saturation concentration of oxygen in water at 20°C is 9.1 mg/L and at 30°C is 7.5 mg/L.

$$\alpha = \frac{(K_\perp a)_T^W}{(K_\perp a)_T^F} = 0.8 \qquad \beta = \frac{C_s \ (wastewater)}{C_s \ (tapwater)} = 0.9 \qquad \left(K_\perp . a\right)_T^F = \left(K_\perp . a\right)_2^F, \qquad \gamma = 1.02^{(T-20)}$$

CE412A
Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

## Given SOT: To Find the Actual Oxygen Transfer Efficiency (AOT)

hoth  $K_L.a$  and  $[O_2]_l^s$  depend on temperature

$$\begin{split} \alpha &= \frac{(K_L, \alpha)_T^W}{(K_L, \alpha)_T^F} = 0.8; \ \beta &= \frac{[O_2^W]_1^5}{[O_2^F]_1^5} = 0.9 \\ (K_L, \alpha)_{20} &= \frac{(K_L, \alpha)_T}{(1.02)^{T-20}}; \ T \ \text{in celcius} \end{split}$$

 $[O_2]_I^S$  decreases with tempearture, obtained from tables

 $[O_2]_l = 1 \text{ mg/L or } 3 \text{ mg/L (in case of nitrification)}$ 

 $SOT = (K_L. a)_{20}^F. [O_2^F]_I^{S_{20}}. (V)$  Generally 1.5 – 2.0 kg O<sub>2</sub> / h/KW

 $AOT = (K_L. a)_T^W.\{[O_2^W]_l^{s_T} - [O_2]_l\}.(V)$ 

 $AOT = (K_L, a)_{20}^F \cdot (\alpha \cdot [1.02]^{T-20}) \{ \beta \cdot [O_2^F]_l^{S_T} - [O_2]_l \} \cdot (V)$ 

CE412A
Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

## Solution

c/s area of each tank =  $4320/4/2 = 540 \text{ m}^2$ 

Area of influence of each aerator = 36 m<sup>2</sup>

Let length of each tank be 30 m and breadth be 18 m. Hence aerators are provided in a 5x3 grid

SOT =  $2.0 \text{ kg O}_2/\text{h/KW}$ ; Find AOT at  $30^{\circ}\text{C}$ 

 $[O_2^F]_l^{S_{30}} = 7.5 \text{ mg/L}$   $[O_2]_l = 1.0 \text{ mg/L}$ 

 $[O_2^F]_l^{S_{20}} = 9.1 \text{ mg/L}$ 

 $= 1.232 \text{ kg } O_2/h/KW$ 

 $SOT = (K_L. a)_{20}^F. [O_2^F]_l^{s_{20}}. (V)$  $2 = (K_L. a)_{20}^F. (V). 9.1$  $AOT = (K_L.a)_{20}^F.([0.8].[1.02]^{30-20})\{[0.9].[7.5] - 1\}.(V)$ 

 $AOT = (K_L.a)_{20}^F.(V).(5.607) = \frac{2}{9.1}.(5.607)$ 

CE412A

Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

#### Solution ...... continued

 $AOT = (K_L.a)_{20}^F.(V).(5.607) = \frac{2}{9.1}.(5.607) = 1.232 \text{ kg } 0_2/h/KW$ 

Oxygen transfer per aerator = 4200/15/24 = 11.67 kg/hr;

Hence, Power Reqd. = 11.67/1.232 = 9.56 KW; Provide 15 no. aerators@10KW/tank

Power Reqd. for mixing/tank = 540.(4).(20)/1000 = 43.2 KW

Power provided for aeration/tank = 15.(10) = 150 KW. Hence, completely mixed conditions will prevail.

CE412A
Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

#### Nutrient (N and P) Requirement:

Nitrogen in wastewater is generally expressed as TKN ( mg/L as N). TKN (as N, mg/L) = Organic-N (as N, mg/L) + Ammonia-N (as N, mg/L)

Phosphorus in wastewater is generally expressed as total – P (mg/L as P) Total P (as P, mg/L) = Org-P (as P, mg/L) + Condensed P (as P, mg/L) + Ortho-P (as P, mg/L)

The BOD<sub>5</sub> (in mg/L): TKN (in mg/L as N): Total-P (in mg/L as P) ratio in domestic wastewater is ~ 100 : 5 : 1

During BOD degradation: Organic -N is converted to Ammonia-N Organic-P and Condensed-P are converted to Ortho-P

CE412A
Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

## Nutrient (N and P) Requirement:

In addition to organic carbon and oxygen, all microorganisms require N and P to grow.

Wastewater generally contains sufficient nutrients (in fact excess) from microorganism growth.

Biomass formula (dry basis): C<sub>60</sub>H<sub>87</sub>O<sub>23</sub>N<sub>12</sub>P; Formula Weight: 1382 For the growth of 1382 g biomass, 168 g N and 31 g P is required

Nutrient Requirement: 0.121 g N and 0.022 g P per g biomass produced (or

Hence the N and P concentration will decrease by this amount in the aeration tank

> $\Delta N (kg/d) = 0.122 \Delta X (kg/d) = Q (m^3/d) * TKN (kg/m^3)$  $\Delta P (kg/d) = 0.022 \Delta X (kg/d) = Q (m^3/d) * TP (kg/m^3)$

CE412A
Design of Water Treatment and Waste Disposal Systems

Settleability of Activated Sludge Solids

One of the factors essential to the performance of the activated sludge process is effective flocculation of the sludge, with subsequent rapid settling and compaction. Two types of bacteria are found in ASP sludge: 1) flocforming, and 2) filamentous bacteria

Normal flocs: A balance between floc-forming and filamentous bacteria results in strong flocs that keep their integrity in the aeration basin and settle well in the sedimentation tank (High BSRT).


Pin-point flocs: In these flocs, filamentous bacteria are absent or occur in low numbers. This results insmall flocs that do not settle well (Low BSRT).

Filamentous bulking: Filamentous bulking is caused by the predominance of filamentous organisms. The filaments interfere with sludge compaction. (very high BSRT)

CE412A
Design of Water Treatment and Waste Disposal Systems

Dr Vinod Tare

# Activated Sludge: High Growth, Standard and Extended Aeration process



CE412A
Design of Water Treatment and Waste Disposal Systems Dr Vinod Tare High-growth (Aerated Lagoon) versus Low-growth (Extended Aeration)

What are the characteristics of a high-growth ASP system ??

In such a system,  $\textbf{q}_c$  is low. Hence  $\mu$  and q are high, S is relatively high. ΔX is high, hence O<sub>2</sub> requirement is low, but nutrient requirement is high. Chance of forming pin-point flocs with poor settling characteristics.


What are the characteristics of an extended growth ASP system??


In such a system,  $q_c$  is high. Hence  $\mu$  and q are low, S is relatively low.  $\Delta X$  is low, hence O<sub>2</sub> requirement is high, but nutrient requirement is low. The inert matter concentration (C) in the aeration tank may be high. Chance of forming filamentous bulking sludge with poor settling characteristics.


CE412A


Design of Water Treatment and Waste Disposal Systems


Dr Vinod Tare















Dr Vinod Tare



## SST or SC Design

Area and Depth Choice:

- 1. Clarification Criteria  $\Rightarrow u = g c^{-h}$   $g = 2 \times 10^{10}$ h = 2.9521
- 2. Solids Concentration in Under Flow
- 3. Retention Time < 2.5 to 3 h

SOR for Limiting Solids Flux is given by following expression:

$$\frac{Q}{A} = \frac{g(h-1)(\frac{h}{h-1})^h(R)^{h-1}}{(C_0)^h(1+R)^h}$$

Lecture 1 Design of Water Treatment and Waste Disposal Systems