

3 Battery System Report

Battery Type: 12FIT180FT

Number of Monoblocs: 8

Nominal Capacity: 180 Ah

Installation Date: 2022-08-02

Reference Voltage: 54.5

Discharge Date: 2026-05-26

Battery Temp [°C]: 24

Discharge Current [A]: 37

End Voltage [V]: 1.9

3.1 Battery Discharge Test - String 1

Time	Reference Voltage [V]	30 min	60 min	90 min	120 min	150 min	180 min
Cell 1 [V]	13.51	12.32	12.23	12.00	11.99	11.91	11.74
Cell 2 [V]	13.58	12.25	12.16	12.04	11.91	11.79	11.55
Cell 3 [V]	13.56	12.27	12.18	12.06	11.93	11.82	11.63
Cell 4 [V]	13.56	12.27	12.18	12.06	11.93	11.82	11.63
Total Volt. [V]	54.21	49.11	48.75	48.16	47.76	47.34	46.55
Cap. [Ah]	-	18.50	37.00	55.50	74.00	92.50	111.00
Temp. [°C]	24.00	24.00	24.00	24.00	24.00	30.00	28.00

Battery Discharge Curve - String 1

