

5 Air Conditioning Service Protocol

5.1 Device Information

Device Information: Vertiv Liebert HPF

Device Type:

Refrigerant: R 410A

Serial Number 1: 24266020003

Serial Number 2:

Start Date: 2026-05-26

Stop Date: 2026-05-26

Location:

5.2 Scope of Work

Activity	Status	Activity	Status
Installation	⊖ NO ACTION	Installing a leak detection system	⊖ NO ACTION
Maintenance or servicing	✓ OK	Tightness control	✓ OK
Leak detection system inspection	⊖ NO ACTION	Recovery	⊖ NO ACTION
Repair	🔧 REPAIRED	Repair of leaks	⊖ NO ACTION
Liquidation	⊖ NO ACTION	Other: cleaning & disinfection	✓ OK

5.3 Device Settings: Before vs After Service

Parameter	Before Service	After Service
Device Status	🔌 WORKING	🔌 WORKING
Temperature SET [°C]	22.00	22.00
Operation Mode	RETURN	RETURN
Other Settings		dT1 type SET

5.4 Operating Parameters

Parameter Name	Cooling Value	Heating Value
Suction Pressure (P_s) [bar]	10.49	
Discharge Pressure (P_d) [bar]	18.40	
Superheat (SH) [K]	14.00	
Subcooling (SC) [K]	-	
Inlet air temp. (T_{in}) [°C]	36.80	
Outlet air temp. (T_{out}) [°C]	22.30	
→ Air temp. diff. (ΔT) [K]	13.50	
Ambient temp. (T_{amb}) [°C]	30.80	
Voltage [V]	238;238;236	
Current [A]	5,87;6,14;6,18	
Operating Status	✓ OK	⊖ NO ACTION

5.5 Maintenance Tasks

Activity / Checkpoint	Status
Checking the settings	✓ OK
Cleaning the filter and exchanger in the indoor unit	✓ OK
Cleaning the heat exchanger in the outdoor unit	✓ OK