

## Drainage Resolution Plan

1700 S. Lamar —  
Mixed-use Site Plan  
Review April 24, 2026

This resolution plan addresses the major design issues identified during the **drainage** review. Items are ranked by impact on the project schedule.

### 1. Resolve detention pond capacity shortfall

---

**Sheets:** 4, 5

The proposed detention pond falls 1,200 ft<sup>3</sup> short of the 25-yr storm requirement. Increase the basin footprint by 8% or deepen the basin by 0.5 ft to recover capacity. Coordinate with the arborist on the eastern oak grove before committing to a footprint change.

**Comments:** 3, 7, 11

### 2. Add storm sewer at SE corner

---

**Sheets:** 6

No collection point currently exists at the SE corner; runoff sheets onto the ROW. Add a Type 2 inlet tied to the existing 18" line.

**Comments:** 9

### Coverage Summary

---

Addressing items 1 and 2 covers ~85% of the open drainage comments. Items 3-5 are minor and can be batched into the next resubmittal.