

UNIVERSITAT POLITÈCNICA DE CATALUNYA

DEPARTAMENT D'ENGINYERIA ELÈCTRICA



Departament d'Enginyeria Elèctrica



UNIVERSITAT POLITÈCNICA DE CATALUNYA



CITCEA - Centre d'Innovació Tecnològica
en Convertidors Estàtics i Accionaments

Doctoral Thesis

Flexibility services for distribution network operation

Íngrid Munné Collado

Thesis advisors:

Dr. Andreas Sumper (UPC, Spain)

Dra. Mónica Aragüés Peñalba (UPC, Spain)

Examination Committee:

Prof. XXXXXXXX (XXXXXX)

Prof. XXXXXX (UPC, Spain)

Prof. XXXXXXXX (XXXXXX)

Thesis reviewers:

Prof. XXXXX (XXXX)

Prof. XXXXXXXX (XXXXXX)

Barcelona, June 2021

Universitat Politècnica de Catalunya
Departament d'Enginyeria Elèctrica
Centre d'Innovació Tecnològica en Convertidors Estàtics i Accionaments
Av. Diagonal, 647. Pl. 2
08028, Barcelona

Copyright © Íngrid Munné Collado, 2020

Cover design: Marta Bellés Petit
First printing, June 2021

"Oh, how much is left to learn"

Ziggy Alberts

*To Sílvia,
Joan and Jèssica.*

Acknowledgements

This thesis has been supported by the Universitat Politècnica de Catalunya and CITCEA through the following projects and other entities:

- EMPOWER Local electricity retail markets for prosumer smart grid power services project. This project received funding from the European Union's Horizon 2020 Research and Innovation programme under Grant Agreement No 646476.
- INVADE Smart system of renewable energy storage based on integrated EVs and batteries to empower mobile, distributed and centralised energy storage in the distribution grid. This project received funding from the European Union's Horizon 2020 Research and Innovation programme under Grant Agreement No 731148.
- BD4OPEM This research is being supported by the European Union's Horizon 2020 Research and Innovation program under the project "Big Data for Open Innovation Energy Marketplace - BD4OPEM" (Grant no. 872525).
- The European Institute of Innovation & Technology (EIT) InnoEnergy Ph.D. School
- Danish Technical University (DTU), Denmark.

Abstract

Storytelling PhD

- What is the current situation?
 - Energy Transition - Clean Energy Package
 - Increase on electricity consumption
 - decommissioning of nuclear power plants
 - Importance on society awareness on sustainability, as well as prices in some countries for access to electricity - What is our current carbon footprint?
- What are the problems that we identify?
 - some of the solutions for the energy transition can lead to congestion in distribution networks, due to the placement of DERs in MV and LV networks.
 - Are we sure that DERs are completely sustainable? Are we really sure that smart grids are completely sustainable, in each and every country?
- Possible solutions
 - Enhance the development of carbon-free technologies by implementing sustainable solutions - Assessment of the environmental impact of electricity production by means of LCA to help in the development of energy policies and planning, as well as including LCA in end-user optimization for achieving lower carbon footprints.
 - Deployment of demand-side flexibility services by means of end-users flexible assets.
- Thesis contributions
 - Assessment tool for evaluating the environmental impact of electricity markets using hourly LCA, by means of Life Cycle Assessment
 - Definition of Flexibility: Characterization, modeling, implementation and evaluation

- Possible use cases of demand-side flexibility: Flexibility services for DSOs.

Resum

Contents

List of Figures	xv
List of Tables	xvii
1 Introduction	1
1.1 Smart grids	1
1.1.1 Distributed Energy Resources	1
1.2 Distribution networks: challenges	1
1.3 Electricity markets	1
1.4 Regulation framework and new agents in the energy transition	1
1.4.1 Local electricity markets	1
1.5 Sustainability of smart grids and DERs	1
1.6 Objectives and scope	2
1.7 Thesis related work and activities	3
1.8 Thesis outline	4
2 Flexibility Services	5
2.1 The importance of flexibility	5
2.2 Regulatory framework for flexibility provision	5
2.2.1 Flexibility definition	5
2.2.2 Local Flexibility Markets	5
2.3 Flexibility definition	5
2.3.1 market oriented	5
2.3.2 System oriented	5
2.4 Mathematical formulation for flexibility definition	5
2.5 Discussion	5
2.6 Conclusion	5
3 Aggregated Flexibility Forecast	7
3.1 Introduction	7
3.1.1 Use cases/Business models for flexibility services and flexibility forecast	7
3.1.2 Literature review on flexibility forecast	7

Contents

3.1.3 Contribution	7
3.2 Algorithms proposed	7
3.3 Methodology	8
3.3.1 Datasets	8
3.4 Load Categorization and Flexibility definition	8
3.4.1 Mathematical formulation	8
3.4.2 Simulation	8
3.5 Results	8
3.6 Discussion	8
3.7 Conclusions	8
4 OPF for Congestion management in MV distribution networks	9
4.1 Introduction	9
4.1.1 Use cases/Business models for congestion management	9
4.1.2 Standards and protocols for flexibility provision between aggregators and DSOs	9
4.1.3 Literature review on congestion management tools - OPF	9
4.1.4 Contribution	9
4.2 Mathematical formulation for Flexibility request calculation .	9
4.3 Methodology	10
4.3.1 Datasets - Network Data	10
4.3.2 Mathematical formulation	10
4.3.3 Simulation	10
4.4 Results	10
4.5 Discussion	10
4.6 Conclusions	10
5 The Potential Role of Flexibility for Sustainable Energy Transition	11
5.1 Environmental Assessment of Smart Grids	11
5.2 LCA Applied on Electricity Production	11
5.2.1 Peak-Hourly Life Cycle Assessment (PH-LCA) Methodology	11
5.2.2 Goal and Scope	11
5.2.3 Life Cycle Inventory	11
5.2.4 Life Cycle Impact Assessment	11
5.3 Case Study: INVADE H2020 project Pilot-Sites Electricity Grid Mixes	11
5.4 Discussion	11
5.5 Conclusion	11

5.6	Introduction	11
5.7	LCA Applied on Electricity Production	14
5.7.1	Peak-Hourly Life Cycle Assessment (PH-LCA) Methodology	15
5.7.2	Goal and Scope	15
5.7.3	Life Cycle Inventory (LCI)	19
5.7.4	Life Cycle Impact Assessment (LCIA)	21
5.8	Case Study: INVADE H2020 Project Pilot-Sites Electricity Grid Mixes	22
5.8.1	INVADE Project Description	22
5.8.2	Overview of the Installed Capacity of Pilot Site Countries	22
5.8.3	LCIA: GWP Results	22
5.9	Discussion	34
5.10	Conclusions	37
6	Conclusions	39
6.1	General conclusions	39
6.2	Contributions	39
6.3	Future work	39
Bibliography		41
A Publications		49

List of Figures

5.1	Life cycle assessment (LCA) steps according to ISO 14040, 14044, and 14067.	16
5.2	LCA methodology for peak hours electricity generation.	20
5.3	Monthly peak hours GWP compared with average through the year (dotted line) in Bulgaria.	26
5.4	Percentage use of resources throughout the year compared with monthly GWP in Bulgaria, both related to peak hours. .	27
5.5	Monthly peak hours GWP compared with average through the year (dotted line) in Germany.	27
5.6	Percentage use of resources throughout the year compared with monthly GWP in Germany, both related to peak hours.	28
5.7	Monthly peak hours GWP compared with the annual average (dotted line) in the Netherlands.	30
5.8	Percentage use of resources throughout the year compared with monthly GWP in the Netherlands, both related to peak hours.	30
5.9	Monthly peak hours GWP compared with average through the year (dotted line) in Norway.	31
5.10	Percentage use of resources throughout the year compared with monthly GWP in Norway, both related to peak hours. .	32
5.11	Monthly peak hours GWP compared with average through the year (dotted line) in Spain.	33
5.12	Percentage use of resources throughout the year compared with monthly GWP in Spain (both related to peak hours). . .	33

List of Tables

5.1	Electricity grid mix LCA goal and scope structure.	16
5.2	Electricity installed capacity in the targeted countries for the year 2018.	23
5.3	Emission factors of power production technologies. Extracted from [43].	24
5.4	Percentage of resources used during peak and off-peak hours in Bulgaria [?].	25
5.5	Percentage of resources used during peak and off-peak hours in Germany [?].	27
5.6	Percentage of resources used during peak and off-peak hours in the Netherlands [?].	29
5.7	Percentage of resources used during peak and off-peak hours in Norway [?].	31
5.8	Percentage of resources used during peak and off-peak hours in Spain [?].	33
5.9	Summary of results between LCA and peak-hourly life cycle assessment (PH-LCA).	35

Chapter 1

Introduction

Explicar el problema al qual ens estem adreçant

1.1 Smart grids

1.1.1 Distributed Energy Resources

1.2 Distribution networks: challenges

1.3 Electricity markets

incloure aquí capítol del llibre de local and micro power markets? Power market fundamentals

1.4 Regulation framework and new agents in the energy transition

entregable que vam fer amb el pau Plana TFG

1.4.1 Local electricity markets

incluir aquí capítol del llibre de local and micro power markets? Power market fundamentals

1.5 Sustainability of smart grids and DERs

Explicació sobre que entenem per sostenibilitat. Quina relació hi ha entre sostenibilitat i smart grids local markets

1.6 Objectives and scope

1.7 Thesis related work and activities

1.8 Thesis outline

Chapter 2

Flexibility Services

2.1 The importance of flexibility

2.2 Regulatory framework for flexibility provision

2.2.1 Flexibility definition

inoure aqui la definicio que vam treballar amb el pau Plana de segons qui vol la flex com es la definicio

2.2.2 Local Flexibility Markets

2.3 Flexibility definition

inoure aqui la idea de diferents definicions de flexibilitat

2.3.1 market oriented

2.3.2 System oriented

2.4 Mathematical formulation for flexibility definition

inoure aqui idea review hussain sobre flexibility review

2.5 Discussion

2.6 Conclusion

Chapter 3

Aggregated Flexibility Forecast

3.1 Introduction

RESEARCH QUESTION: Feina que estic fent a DTU

3.1.1 Use cases/Business models for flexibility services and flexibility forecast

3.1.2 Literature review on flexibility forecast

3.1.3 Contribution

- non-intrusive approach
- less data required (15 kHz for NILM algorithms). Here we can work with 1 minute data
- no submetering (only main smart meter data)
- total aggregated load forecast
- from the total load forecast, we forecast the flexibility UP and flex DOWN, as well as the INFLEXIBLE load
- flexible capacity band (power band) forecast

3.2 Algorithms proposed

- Hidden Markov Model
- combinatorial optimization
- Factorial hidden markov model?

3.3 Methodology

3.3.1 Datasets

Synthetic Data - Load Profile Generator

Real Data - Pecan Street Dataport

3.4 Load Categorization and Flexibility definition

3.4.1 Mathematical formulation

3.4.2 Simulation

3.5 Results

3.6 Discussion

3.7 Conclusions

Chapter 4

OPF for Congestion management in MV distribution networks

4.1 Introduction

RESEARCH QUESTION: INCLOURE FEINA DEL PAPER DEL CIRED

- NUVVE Congestion management
- pilot estabanell INVADE - BD4OPEM
- altres pilots

4.1.1 Use cases/Business models for congestion management

incluir aqui diagrama interaccio de l'INVADE-CIRED Possibilitat d'incloure els use cases que estem fent pel BD4OPEM

4.1.2 Standards and protocols for flexibility provision between aggregators and DSOs

OPENADR - USEF?

4.1.3 Literature review on congestion management tools - OPF

4.1.4 Contribution

4.2 Mathematical formulation for Flexibility request calculation

- OPF (Python)

4.3 Methodology

4.3.1 Datasets - Network Data

4.3.2 Mathematical formulation

4.3.3 Simulation

4.4 Results

4.5 Discussion

4.6 Conclusions

Chapter 5

The Potential Role of Flexibility for Sustainable Energy Transition

5.1 Environmental Assessment of Smart Grids

5.2 LCA Applied on Electricity Production

5.2.1 Peak-Hourly Life Cycle Assessment (PH-LCA) Methodology

5.2.2 Goal and Scope

5.2.3 Life Cycle Inventory

5.2.4 Life Cycle Impact Assessment

5.3 Case Study: INVADE H2020 project Pilot-Sites Electricity Grid Mixes

5.4 Discussion

5.5 Conclusion

5.6 Introduction

Climate change has pushed the electricity grid in an evolution towards smart grids by including distributed energy resources (DERs) and the Internet of Things (IoT) [1]. At the same time, the increase in electricity consumption is directly related to a significant contribution of the electricity supply to the carbon footprint, since CO₂ emissions in the power sector increased by 2.5% as a result of a 4% rise in the global energy demand (GED) [2].

Renewable energy sources (RESs) are helping the energy transition by increasing their share in the energy mix. As stated by Pleßmann et al. in [3], a transition from a conventional to a renewables-based power supply system is possible for the EU, even considering nuclear power phase-out. Despite this, the variability of these resources requires flexibility in the energy system. The goal is to decarbonize the electricity sector, reducing the power system's environmental impact by shifting the consumption to those time periods where electricity from renewable sources is produced. This is currently being implemented with the integration of energy storage systems, the activation of demand response (DR) mechanisms, and the development of flexibility markets [4, 5]. Demand-side management (DSM) activities can be key for energy strategy and policy development. Nilsson et al. [6] proposed an interdisciplinary framework to evaluate demand response based on price and environmental signals. Gerbaulet et al. [7] proved that the integration of storage and DSM, as well as other mechanisms, could lead to a decarbonization of the entire energy sector by 2050. This is also supported by Child [8], considering also the integration of flexibilityservices and interconnections. All energy agents can benefit from flexibilityservices, as defined in [9], where distribution system operators (DSOs), balance responsible parties (BRPs), and prosumers are the main stakeholders of the flexibilityplatform.

This shift in the energy mix entails an environmental burden, requiring an analysis of the resources used during daily high-demand time periods, as well as their effects on the environment. Traditionally, peak hours (PH) were covered by using conventional sources such as coal or natural gas, since renewable sources had a low capacity factor [10]. Policies in terms of energy planning and grid expansion attempt to tackle climate change by restricting greenhouse gas (GHG) emissions in the electricity sector, since GHG emissions are closely linked to the production and use of energy [11]. However, each national electricity mix has unique characteristics based on the resources located inside the borders as well as geo-political conditions, and this must also be considered when defining energy policies [12–17].

GHG emissions accounted by the electricity sector are calculated based on techniques that include absolute carbon emissions and average carbon intensity, as stated by Khan in [18]. This was the case in [19], which assessed the Belgian low-voltage electricity mix using life cycle assessment (LCA) approaches, resulting in average environmental impacts, to check the quality of the datasets from the European Network of Transmission System Operators for Electricity (ENTSO-E). Additionally, ecoinvent 3.1. Average CO₂ emissions were also developed in [20, 21]. However, these studies did not analyze the temporal variability of CO₂ based on the resources used to cover the

national demand when the demand reaches maximum values. On the contrary, the absolute emissions approach quantifies the total amount of CO₂; it is usually used in national and international studies for tracking changes in emissions, comparing scenarios and developing GHG regulation [22–25]. However, these approaches are not useful for accounting the electricity produced with the temporal variation of resources (and hence, emissions).

Earlier studies considered the time-varying dependence of electricity production to assess the potential environmental impacts. The hourly life cycle footprint of electricity generation in Belgium using LCA was first assessed by Messagie et al. in [26]. However, they calculated the average carbon emissions for each specific month, and hence peak hours resources could not be evaluated. Nilsson et al. [27] analyzed the change in residential electricity consumption through the possibility for the final customer to visualize the electricity prices in real-time. A similar path was followed by Cubi et al. [28] in Canada, assessing the building environmental impacts related to the variability of the resources used during the day-time. Khan et al. [29] approached the electricity mix environmental impacts with an analysis in which peak hours and off-peak hours were compared, leading to useful results for policy makers regarding Bangladesh's grid. This method was followed by Khan et al. in [30] to evaluate GHG emissions in New Zealand. The hourly-defined life cycle assessment (HD-LCA) approach was put forth in [31], with the enhancement that the hourly electricity supply was environmentally evaluated. As a result, electric vehicle (EV) charging processes could be scheduled according to the time variability of GHG emissions. In [32], Rangaraju et al. emphasized the importance of considering the temporal resolution of EV charging in LCA, by combining the electricity mix time variability and charging time frames. The geographical and temporal variation of marginal electricity generation can affect the environmental impacts of an energy system, as well as policy decisions, as stated by Olkkonen and Syri in [33]. In addition, the time-varying nature of marginal electricity generation sources should be taken into account for relevant LCA models.

All the previously mentioned works studied how to assess the environmental impacts of electricity systems, but none assessed peak hours for flexibility objectives, considering peak hours as the most expensive and resource-intensive time periods. Furthermore, none of them used hourly attributional LCA in which the time variability is considered, nor did they compare this methodology to traditional LCA and yearly average values. There is a knowledge gap in the environmental assessment of peak hours' electricity generation, and more specifically in using LCA approaches for analyzing the flexibility potential of electricity production. The contribution of this paper is

the definition of a general methodology for the environmental impact assessment of peak-hourly electricity generation by means of attributional LCA, using statistical data of electricity generation. Additionally, this methodology was implemented in an evaluation offive different countries through the ENTSO-E Transparency Platform and GaBi® Software database, leading to peak-hourly national carbon intensity curves and share of resources. The results and discussion of this analysis can provide some guidance to energy policy makersas well as energy services companies (ESCOs) and aggregators in taking decisions on how flexibility and DR strategies should be designed, quantified, and rewarded, considering not only economic savings but also CO₂ cuts.

5.7 LCA Applied on Electricity Production

There are different approaches to assessing the environmental impact of electricity production. As stated by Khan in [34], six different methodologies have been used in the literature for electricity generation systems. Life cycle assessment (LCA) is one of the most established methods, and is widely used for comparing different generation technologies. The aim of LCA is to assess the potential environmental impacts of a product or system throughout its entire life cycle, by providing both absolute and average values of the environmental impact. That means that LCA can also be used to assess the time-variability of resources in electricity mixes, and is suitable for evaluating the environmental impact of peak hours electricity production. GarcÃa et al. studied the possible changes in the Spanish electricity production mix to assess and guarantee the European Commission Directives accomplishments and CO₂ cuts [35]. Consequential LCA was used by Lund et al. [36] to set a business as usual (BAU) projection of the Danish energy system, focusing on the marginal production unit with particular attention to day–night and summer–winter variations. Jones et al. used the same approach combined with a net energy analysis to describe the future environmental outcomes of distributed electricity production in the United Kingdom [20]. Thomson et al. analyzed [37] the GHG emissions displacement provided by wind power in the marginal generation of Great Britain, considering the uncertainty of the production. Howard et al. [38] developed an LCA model to calculate the GHG emissions considering a timeline from 2011 projected until 2025, considering the grid operation, the integration of wind turbines, and power plants' addition and dismantling. Garcia et al. [39] described the average electricity grid mix in Portugal looking at seven different impact indicators.

The same authors improved their study by looking at GHG emissions implications for EVs, including time constraints regarding electricity peaks of production [40].

The common point of the previously cited papers is that the LCAs of electricity grid mixes account for the yearly average electricity production of a certain country. To understand the environmental impacts related to the resources used during peak hours, a time-varying approach should be implemented, as highlighted by Curran et al. in [41]. According to methodological reviews of LCA electricity mixes [42, 43], the difference between average yearly and shorter time periods could be significant, especially when there is a consistent difference in the strategy used to cover peak hours in comparison with the base load. At the same time, the electricity demand changes depending on seasons, weather, and resources availability, and consequently the mixes used during base load and peak hours can differ significantly.

Consideration of the time dependency of GHG emissions due to electricity production is the novelty proposed by this paper in comparison to previous literature [20, 35–40, 44]. To the best of our knowledge, there is no such analysis regarding the electricity production in Bulgaria, Germany, the Netherlands, Norway, or Spain. In this study, the most complete data were analyzed, including the entire year 2018. Because demand response and flexibility are two main important topics regarding electricity production, this study aimed to improve upon the knowledge about the resources used during peak time periods, and to investigate possible alternatives.

5.7.1 Peak-Hourly Life Cycle Assessment (PH-LCA) Methodology

There are four different stages in an LCA model, according to [45, 46]: (i) goal and scope definition; (ii) life cycle inventory (LCI); (iii) life cycle impact assessment (LCIA); and (iv) interpretation. **LCA is an iterative process, being all the steps interconnected, as shown in Figure 5.1.** Section 5.7.2 defines the goal and scope for this study. The life cycle inventory and life cycle impact assessment are developed in Section 5.7.3 and Section 5.8.3, respectively. Finally, the interpretation is developed in Section 5.9.

5.7.2 Goal and Scope

The goal and scope definition of an LCA provides the intended application of the analysis, describes the product system boundaries, and defines the functional unit [47], determining and guiding the choices to be made in




Fig. 5.1: **Life** cycle assessment (LCA) steps according to ISO 14040, 14044, and 14067.

Table 5.1: Electricity grid mix LCA goal and scope structure.

Goal	Intended Application	Explorative study
	LCA Typology	Attributional LCA
	Purpose of the Study	Provide the reader knowledge to understand the environmental impacts of peak hours' electricity production
	Comparative Analysis	This is not a comparative analysis between countries. Comparison between average and peak-hourly (PH) global warming potential (GWP) values.
Scope	Function of the System	The targeted country's electricity grid mixes are in charge of producing the electricity needed to meet the national load in any instant
	Functional Unit	1 kWh [27, 29, 30]
	Reference Flow	Energy flow (kWh) of electricity
	Description of the System	Bulgaria, Germany, The Netherlands, Norway, and Spain (Section 5.8)
	System Boundaries	Cradle to Gate
	Allocation Procedures	Detailed in Section 5.7.1
	Impact Assessment Method	CML 2015 [48]. Impact category : GWP (kg CO ₂ -eq/kWh)
	Data Requirements	Secondary data provided by ENTSO-E Transparency Platform

other stages of the analysis. Table 5.1 defines the goal and scope for this study. In this article, the attributional LCA approach was applied for peak hours, developing a new LCA methodology named peak-hourly life cycle assessment (PH-LCA). As a result of this study, comparison between the environmental impacts of average and peak-hours electricity produced in an entire year can be analyzed.

The functional unit for the environmental impact assessment is defined as one kWh of electricity produced and delivered to the grid, which is in line with previous studies of the environmental impacts of electricity generation [19, 26–30]. The impact category chosen for the assessment was global warming potential (GWP), using the CML 2015 life cycle impact assessment method [48].

System Boundaries

The system boundaries limit the LCA framework by defining the resource inputs and the emissions outputs of the system, excluding those that are out

of the LCA's scope. The included limitations should derive from the available hourly data from the statistical source used for the analysis (in this research, the ENTSO-E TP). Soimakallio et al. [42] describe the challenges of performing an LCA about electricity mixes, suggesting the main factors and variables to consider as system boundaries. Elements such as grid losses, electricity import/export, power plant consumption, and environmental impact allocation procedures are described in the following subsections.

Grid Losses

Specifically in this LCA, the background system includes all the previous steps of the final electricity production process, like the extraction of the fuel, its refinement, and its transportation to the power plant. The foreground system is related to the effective production of 1 kWh inside the power plant. For the background system, the software tool dataset used for this research includes imported electricity from neighboring countries and transmission/distribution losses (e.g., the electricity mix of the country which exports the fuel, the losses in transportation, etc.). However, the foreground system does not include the same values, meaning that it does not contain the exports of the produced electricity in other countries, the imports of electricity from bordering nations, or the grid losses to distribute the produced electricity [?]. According to [42], the difficulties in how grid losses should be allocated between high-, medium-, and low-voltage consumers make the process excessively complicated for the losses contribution in the final results, especially in terms of GHG emissions. This is why grid losses (distribution, transmission) of the targeted countries are not considered in this model. Contrariwise, transformation losses are part of the model because these values can be estimated through the efficiency of the power plants.

Import/Export

Another subject of discussion is the amounts of imported and exported electricity from neighboring countries, as mentioned in the previous subsection. In ENTSO-E TP, the classification named *Actual Generation per Production Type* includes the natural resources used for the electricity production, and refers to the amount of fuels utilized including the import of these substances from other countries. However, it does not include the already-produced electricity imports between bordering countries. These data are integrated in a different class in the ENTSO-E TP platform, as *cross-border physical*

flows, which is not taken into account in this study. In fact, incorporating electricity imports and exports in a national grid mix could lead to inaccuracy and imprecision when dealing with GWP calculations, because it is not possible to know from which power plants the electricity comes from. As a result, the analysis of Nillson et al. in [27], which contains Swedish electricity imports, could include minor defects compared to a baseline where exchanges are not considered. Considering only the geographical borders avoids any possible misconception, as was also done by Khan [29]. Cubi et al. [28] do not specify if imports and exports were counted, and Khan et al. [30] did not include them. Furthermore, in a recent paper by Moro et al. [44], four out of five targeted countries of this study (Bulgaria, Germany, Spain, and the Netherlands) had a very low carbon intensity variation of the electricity production after trading with other countries (-2% , $+2\%$, -6% , and -1% respectively).

Power Plants' Consumption

Regarding the electricity consumption of power plants themselves, these values were taken from the official statistics of the IEA (International Energy Agency) through the LCA software tool, and so they were included in the model [?]. Specifically, the power consumed in pumping the water in hydro pumped storage (PHS) power plants was considered when data from TP were available. The sources of electricity for the pumps were assessed according to the average national electricity mix presented in this study.

Combined Heat and Power Plant Emission Allocation Procedures

Finding the suitable allocation factor can sometimes be problematic, and can have a significant impact on the LCA results. According to [45], allocation should be avoided whenever possible. Combined heat and power plants (CHP) produce two outputs, and so it is necessary to allocate the environmental impacts of just the electricity production. LCA software tools present a database for every resource used in CHP power plants, such as natural gas, biogas, heavy fuel oil, hard coal, lignite, and biomass. In the used database, there are data regarding the share of electricity, the overall efficiency, and the share of electricity to thermal energy within a CHP plant. According to the description of the dataset, for the CHP production, allocation by exergetic content is considered. Whenever there seemed to be a lack of data regarding the amount of produced heat or the efficiency of CHP plants in a country's database, the research found that this was due to

the low percentage of produced heat relative to the total energy originated, which was rounded down to 0.0 since it is usually only about 0.01 [?]. Therefore, the allocation of CHP plants was considered as a part of the analysis only when data were available (Bulgaria, Germany, and the Netherlands).

5.7.3 Life Cycle Inventory (LCI)

LCI can be understood as a model of the product system which fulfills a function that is quantified in the functional unit. It requires hypothesis definition, data collection, and data modeling, resulting in an inventory table with all the environmental interventions. The objective of the LCI is to quantify the resources used and the emissions and waste per functional unit [47]. Traditional LCA approaches quantify the resources, emissions, and wastes on average per functional unit. However, when the aim is to quantify the environmental impacts on peak hours to develop flexibility services, this approach is not enough. The time variability of the electricity production is a fundamental issue to consider in order to correctly assess the GWP during different time slots. To achieve that objective, a new methodology named peak-hourly LCA is defined in Figure 5.2, and it is compared to the traditional approach of LCA for electricity production.

The methodology followed for this study is based on the identification of electricity production peak hours for every day of the year, compared to the base load. Every single peak hour, extracted from a statistical source, was analyzed to define the resources used to meet the greatest electricity demand of the day. The electricity mix was normalized into the functional unit of 1 kWh. Then, the resultant GHG emissions, and therefore the GWP impact indicator values, were calculated. To compare the obtained results for peak-hours to average values, the traditional LCA approach was also implemented. In this case, all the hours of the year 2018 were considered. Accordingly, peak hours GWP values were compared with the average, resulting in monthly results to highlight the seasonal variations.

The scope of this comparison is based on individuating the differences in the use of various resources to meet the electricity demand in different time frames. A similar approach is followed in [28–30], but the results are presented in order to show the link between electricity demand and carbon intensity and not to compare peak hour values with a fixed average. In [27], the aim is to determine the hourly time slot where the highest CO₂ intensity takes place throughout the year. This approach may hide the seasonality between summer and winter, since the peak hour time slot differs from season to season. In this paper, the hourly analysis enhances the differentiation of




Fig. 5.2: LCA methodology for peak hours electricity generation.

GHG emissions from peak hours and off-peak hours.

This paper bases its results on the data extracted from the Transparency Platform (TP) of the European Network of Transmission System Operators for Electricity (ENTSO-E), as well as the GaBi® Software database. The software allows the carbon intensity of every source to be assessed, considering the electricity produced as input. The related database is essential to differentiate the impact of each technology in different nations, having variable country-based data in which the same power plant can have different emission factors according to the country in which it is based.

The ENTSO-E TP database is based on hourly time periods. Hence, it is possible to determine the time slots where peak consumption takes place. A critical review of the ENTSO-E TP from 2018 in [?] points out a number of simplifications, but at the same time the review highlights that it is the single most important data source for European researchers. For this study the consistency of the data is guaranteed, supported by the fact they were compared, when possible, with the statistics from each national Transmission System Operator (TSO). As a result, the most complete and available data were used for the analysis, referring to the entire year 2018.

The databases available for the development of electricity grid mixes analysis have limitations that hinder the accurate development of the model. For this reason, certain assumptions and hypotheses were considered. Even if from the ENTSO-E TP, the data for hydro production are divided into categories such as hydro pumped storage, hydro run-of-river and poundage, and hydro water reservoir; these were all merged together in this work. The reference value for hydro power plants is the carbon intensity provided by the database, which makes a mean between the different types of hydro technologies. The same procedure was used to calculate the environmental impacts of wind power production, grouping onshore and offshore wind only for Germany and the Netherlands (the two countries which have both technologies). ENTSO-E shows data including solar thermal and solar photovoltaic electricity in the same box (i.e., *Solar*), without any distinction. Thus, the model was developed incorporating the data in the Electricity from photovoltaics GaBi® Software model.

5.7.4 Life Cycle Impact Assessment (LCIA)

Life cycle impact assessment (LCIA) yields indicators that evaluate the product life cycle on a functional unit basis, considering one or several impact categories. For the purpose of this study, the impact category used to assess the potential environmental impact of the electricity production was the

global warming potential, measured in kg CO₂-eq/kWh. Section 5.8 provides the results of the LCIA stage.

5.8 Case Study: INVADE H2020 Project Pilot-Sites Electricity Grid Mixes

5.8.1 INVADE Project Description

The methodology described in Section 5.7 was applied under the H2020 INVADE project to assess the potential environmental impact of large-scale pilots integrating DERs and EVs, by means of a cloud-based platform for the provision of flexibility services. Denominated *Integrated electric vehicles and batteries to empower distributed and centralized storage in distribution grids*, this project belongs to the *Low-Carbon Energy* call of the Horizon 2020 Work Program 2016–2017. This project is based on five pilot sites located in five different countries, which are environmentally assessed in the following section.

5.8.2 Overview of the Installed Capacity of Pilot Site Countries

The installed capacity represents the total amount of power in MW that is installed in a country. It determines the resources the country has available to meet the demand, representing the number of power plants that can be used for electricity generation in a targeted country. As can be seen in Table 5.2, the targeted countries of the H2020 INVADE project have different installed capacities. These data represent the percentage of power plants which can produce electricity in the country divided by source used, and are not directly related to the power generation. For example, in Spain the maximum hourly power request in 2018 was 42 GW, but the country has nearly 105 GW of installed capacity. This means that even if the power plants which are run by natural gas represent the major share of the installed capacity (29.3%), it does not necessarily mean that the highest share of electricity production in 2018 was from natural gas, as determined in Section 5.8.3.

5.8.3 LCIA: GWP Results

This section presents the results of the performed LCA. As mentioned in Section 5.7.3, the GWP impact factors of each technology are dependent on the country they are based in. However, to frame the studied context, Table

Table 5.2: Electricity installed capacity in the targeted countries for the year 2018.

	Main	Flexible Hydro Power	Other
Bulgaria - (12,708 MW)	Lignite (33.7%) Hydro (25.2%) Nuclear (15.5%)	Pumped storage (6.8%) Reservoir (14.2%)	Solar Natural Wind Other
Germany - (221,020 MW)	Wind (26.6%) Solar (19.6%) Natural gas (14.3%)	Pumped storage (4.2%) Reservoir (0.5%)	Hard Lignite Hydro Other
Netherlands - (30,531 MW)	Natural gas (57.6%) Hard coal (14.5%) Wind Onshore (11.5%)	Pumped storage (0%) Reservoir (0%)	Solar Wind Waste Other
Norway - (33,755 MW)	Hydro (93.2%) Wind Onshore (3.5%)	Pumped storage (10.8%) Reservoir (78.5%)	Thermal
Spain - (104,975 MW)	Natural gas (29.3%) Hydro (24.7%) Wind Onshore (21.7%)	Pumped storage (5.4%) Reservoir (18.22%)	Hard Nuclear Solar Other

-88in

Source: ENTSO-E TP [?]. * The installed capacity data from Norway in ENTSO-E TP were not sufficient. More detailed data come from [?].

Table 5.3: Emission factors of power production technologies. Extracted from [43].

Energy Source	GWP (kg CO ₂ -eq/kWh)
Hard coal	0.66–1.05
Lignite	0.8–1.3
Natural gas, single cycle	0.61–0.85
Natural gas, combined cycle	0.36–0.59
Oil	0.53–0.9
Nuclear	0.003–0.035
Biomass	0.008–0.13
Hydropower	0.002–0.02
Solar photovoltaic (PV)	0.013–0.19
Wind	0.003–0.041

5.3 shows the average life cycle emission factors for electricity generation from the most used technologies in Europe, according to Turconi et al. [43].

The values in Table 5.3 include upstream and downstream processes and thus all the steps involved in the electricity generation, like the construction of the power plants and Operations and Maintenance (O&M) procedures. The ranges of the values are wide, because the 167 case studies analyzed have different system boundaries and methodologies [43]. Even so, the software used in this study has a specific country-based database for each technology, conferring the results a significant precision. As it is possible to see from Table 5.3, even renewable sources have non-zero GWP values. This is due to indirect emissions, especially related to the manufacturing of the components for the construction of renewable power plants, which are taken into account in this study.

Two types of graphs (Figures 5.3 -5.12), area and line plots, are presented in the following sections to facilitate the comprehension of the results. Area plots, represented by odd Figures 5.3, 5.5, 5.7, 5.9, 5.11, show the GWP value of each resource used only during peak hours in the related country's grid mix. The outcomes are shown month by month and are compared with the average GWP value (represented by a dotted line), which takes into account all the hours of the year. This is why the dotted line does not coincide with the average of the values of the 12 months.

However, it is possible that resources such as hydro and nuclear, even though they have a great share of the electricity production, could not appear in the graph because of their low carbon impact factors (Table 5.3).

Table 5.4: Percentage of resources used during peak and off-peak hours in Bulgaria [?].

Lignite	Nuclear	Hydropower	Natural Gas	Wind	Solar	Others
42.29%	34.78%	11.42%	4.26%	2.75%	2.60%	1.90%

Line plots, represented by even Figures 5.4, 5.6, 5.8, 5.10, and 5.12; correspond to the variation in the percentage of use of the most representative sources during the year, compared with the monthly peak hours GWP variations. All the previous listed figures were made with our own calculations and estimations through MATLAB®. All data sources have already been mentioned in the text, namely the GaBi® Software professional database and the ENTSO-E TP. Every energy source grouped under the label “Others” was calculated in terms of carbon intensity in the same way as the other main sources. Nevertheless, their weights were too low to be represented on the chosen plot typology, and for that reason the results are merged in a single and more general group.

Bulgaria

The electricity demand of this southeastern European country during the year is mainly covered by lignite and nuclear power, as explained in Table 5.4. The high percentage of hydro power capacity (Table 5.2) is reflected in the consistent use of hydro power plants. Solar and wind power together represented just 5.35% of the total electricity production in Bulgaria in 2018. The total electricity produced during the year was equal to 45.2 TWh.

Consequently, the GWP during peak hours was mainly based on lignite (Figure 5.3). The GWP during peak hours was higher than the average from September to December because of higher use of lignite and a lower use of flexible hydro to cover the peak demand (+6.65% more on average). From Figure 5.4, it is possible to see the direct correlation between the use of lignite and hydropower during peak hours and the GWP. Hydropower and lignite are the only two represented resources because they were the only ones with a significant variation in their usage throughout the year. When there was the possibility to use the hydro reservoirs and the hydro pumped storage, the GWP decreased in comparison with the average. The months in which the power production during peak hours was greater than the average showed higher values of GWP. The reason is that nuclear power represents




Fig. 5.3: Monthly peak hours GWP compared with average through the year (dotted line) in Bulgaria.

a huge and constant portion of the base production (34.78% throughout the year), and the less extra power is needed, the less fossil fuels are used to generate it. The two presented curves of lignite and hydro in Figure 5.4 have exactly the opposite trends. April is a symbolic month, with the highest share usage of hydro and the lowest of lignite, leading to the lowest GWP of the year (0.397 kg CO₂-eq/kWh). The reasons behind this event are related to the low power production in April and possibly to the abundance of water resources.

Germany

Germany has a national production mix which relies on different sources. Regarding the base load, lignite and hard coal, respectively 24.46% and 13.72%, were the most used fossil fuels. The use of lignite throughout 2018 was almost constant, as shown in Figure 5.5. Wind farms had the highest share of capacity in the country and a total share of production of 20.63%, as presented in Table 5.2 and Table 5.5. Nuclear still had a regular contribution (13.64%), while solar (7.83%) and biomass (7.63%) power plants surpassed the use of natural gas (6.41%) in 2018. Hydropower accounted for just 2.81% of the total electricity production. The total electricity produced during the year in the country was equal to 2183.6 TWh.

5.8 Case Study: INVADE H2020 Project Pilot-Sites Electricity Grid Mixes




Fig. 5.4: Percentage use of resources throughout the year compared with monthly GWP in Bulgaria, both related to peak hours.

Table 5.5: Percentage of resources used during peak and off-peak hours in Germany [?].

Lignite	Wind	Hard Coal	Nuclear	Solar	Biomass	Natural Gas	Hydro	Others*
24.42%	20.63%	13.72%	13.64%	7.83%	7.63%	6.41%	2.81%	2.91%

-88in

*Others includes: coal gas derived, fossil oil, geothermal, other renewables, waste.




Fig. 5.5: Monthly peak hours GWP compared with average through the year (dotted line) in Germany.




Fig. 5.6: Percentage use of resources throughout the year compared with monthly GWP in Germany, both related to peak hours.

According to the LCIA, the GWP during peak hours was higher than the average only in February (+5.2%) and November (+4.52%) (Figure 5.5). This was due to the highest percentages of the use of hard coal (+29.15% in average) and natural gas (+26.1% in average) during the entire year, and also the higher use of lignite in comparison with the other months. From Figure 5.5, April and May were the months with the lowest GWP (−23.95%), because of the lower use of fossil fuels compared to the average. This strategy was applicable considering that both months had peaks of demand much lower than the average, with the power requested during peak hours being around 5.45% lower compared to the other months. This means that the base power from nuclear power plants (which is almost constant throughout the year) had a more important role than during the months in which the production was higher and so fewer fossil fuels had to be used. It is interesting to look at solar and wind power trends: electricity production from solar power was clearly higher during the summer months, while the wind production had its maximum in the winter months (Figure 5.5). These two facts lead the peak hour GWP to be lower than the average for 10 out of 12 months. February and November, the two exceptions, saw a larger use of fossil fuels compared to the other months.

The Netherlands

In the Netherlands, the use of natural gas for electricity production represented 67.85% of the total. It was the most important resource affecting the GWP value. Nuclear power helped to cover a small percentage of the base

Table 5.6: Percentage of resources used during peak and off-peak hours in the Netherlands [?].

Natural Gas	Wind	Nuclear	Solar	Biomass
67.85%	19.48%	6.61%	5.48%	0.58%

load (6.61%), while the lack of hydropower capacity influenced the electricity generation strategy. The overall production percentages are presented in Table 5.6. The total electricity produced during the year in the country was equal to 224.8 TWh.

Through the analysis related to the ENTSO-E data [?], the yearly average value was 0.287 kg CO₂-eq/kWh. In the study performed by Moro et al. [44], the average outcome for the GWP was 0.558 kg CO₂-eq/kWh. The reason behind this difference lies in the fact that hard coal electricity production in the Netherlands was not mentioned by the ENTSO-E TP for 2018. However, hard coal has still a considerable percentage in the energy mix, as is notable in Table 5.2. This lack of data reduces the accuracy of the GWP results, but not the effect of the other resources on peak hours. As is notable from Figure 5.7, hard coal is not specified.

As can be seen in Figure 5.8, the GWP line follows the natural gas use curve. The valley formed by the dotted line from March to June is linked to a similar one drawn by the natural gas curve. From April until July, the amount of electricity produced through solar power plants during peak hours was higher than the yearly average, resulting in an increase of +39.7% on average, affecting positively the GWP. The lowest values for wind production corresponded to the highest values of the GWP (Figure 5.7), as in February, when the production from wind power was 49.94% lower than the yearly average. The changes in the use of resources through the year were limited, and this is why there were no major changes in monthly GWPs. The Netherlands was the country with the lowest observed fluctuations in terms of GWP, being in the range between 0.256 and 0.303 kg CO₂-eq/kWh (respectively -10.9% and +5.6% in comparison with the yearly average value of 0.287 kg CO₂-eq/kWh). As already observed in the case of Germany, solar and wind power had opposite concavities. When the availability of solar and wind power during peak hours was higher than the average, lower values of GWP were obtained.




Fig. 5.7: Monthly peak hours GWP compared with the annual average (dotted line) in the Netherlands.




Fig. 5.8: Percentage use of resources throughout the year compared with monthly GWP in the Netherlands, both related to peak hours.

Table 5.7: Percentage of resources used during peak and off-peak hours in Norway [?].

Hydro Reservoir	Hydro Run-of-River	Wind Onshore	Natural Gas	Others
87.93%	6.87%	2.32%	2.10%	0.77%




Fig. 5.9: Monthly peak hours GWP compared with average through the year (dotted line) in Norway.

Norway

As mentioned in Table 5.7, Norway bases its electricity needs on hydropower. The high percentage of water reservoirs and pumped hydro storage (87.93%) allows the Nordic country to manage the generation in a flexible manner. Thanks to this, the GWP value related to the produced electricity was much lower compared to the other studied countries, being around an order of magnitude less. Although it is beneficial for the flexibility of the generation, Norway is a good example of a country in which pumped hydro is not actually valuable because of the high presence of naturally charged reservoirs. The pumped storage technology was just a small percentage compared with the conventional hydropower (see Table 5.2). Its use is historically based in the months of June and July [?]. Regarding the case study of 2018, a greater use in May was also observed. PHS is used to store the electricity that comes from conventional thermal power plants, leading to higher GWP values during those months, as presented in Figure 5.9. The total electricity production in Norway in 2018 was 146.8 TWh, with 116.8 TWh from reservoirs and pumped storage was mainly made by natural gas, wind, and waste power plants. This is why the GWP line follows the “Others” resources use curve for the majority of the year 2018. Whenever there was more production from waste (+42.5% in average) and natural gas (+18.9% on average), the GWP



Fig. 5.10: Percentage use of resources throughout the year compared with monthly GWP in Norway, both related to peak hours.

was higher than the average (Figure 5.10). Curiously, the months of May, June, and July were also the ones with the lowest power generation during peak hours. During the month of August, the amount of power required for the nation's needs was close to the yearly average, but fewer thermal power plants were used while hydropower plants were even more exploited than usual, leading August to be the month with the lowest GWP of the year, with a value of 0.0172 kg CO₂-eq/kWh. Nevertheless, the monthly changes in the use of all the resources was always lower than 2% and this is why also the GWP did not differ substantially.

Spain

Spain has several different resources with a great share in the electricity production, like Germany. Natural gas and hard coal were the fossil fuels used at higher rates, with percentages of 20.91% and 13.29% respectively. Nuclear power plants accounted for 22.46% of the total yearly electricity production, and wind onshore power represented a consistent share (20.21%). Solar production was also present during night hours because of some concentrated solar power plants with molten salts. Table 5.8 shows the resources used during the year in descending order. The total electricity produced during the year in the country was equal to 242.7 TWh. Figure 5.11 demonstrates that natural gas and hard coal were the main drivers of a high GWP, and the less they were used, the lower the indicator was. Figure 5.12 shows that during the month of March there was a minimum of the GWP value (0.157 kg CO₂-eq/kWh, due to a high production of wind power which reached 30% of the share of production and at the same time an increase in the use of hydro storage and solar power plants. The two

5.8 Case Study: INVADE H2020 Project Pilot-Sites Electricity Grid Mixes

Table 5.8: Percentage of resources used during peak and off-peak hours in Spain [?].

Nuclear	Natural Gas	Wind	Hard Coal	Hydro	Solar	Lignite	Biomass	Others*
22.46%	20.91%	20.21%	13.29%	13.22%	4.69%	1.28%	1.25%	2.32%

*Others includes: fossil oil, other renewables, and waste.




Fig. 5.11: Monthly peak hours GWP compared with average through the year (dotted line) in Spain.




Fig. 5.12: Percentage use of resources throughout the year compared with monthly GWP in Spain (both related to peak hours).

maximum GWP points recorded in September and November, both 0.341 kg CO₂-eq/kWh, were due to a decrease in solar electricity production and a consequential increase of fossil fuels to meet the demand needs (Figure 5.12). Spain was the analyzed country with the highest fluctuations among the different months of the year. March had the lowest GWP, being 44.2% lower than the average value. On the contrary, September and November had the greatest GWP values, specifically 21.3% higher than the annual average value of 0.281 kg CO₂-eq/kWh.

5.9 Discussion

The effects of temporal variability on GWP values confirmed their importance in this study. Impact indicators can differ substantially depending on the amount of power produced, the season, and the resources used throughout the year. The expectation to obtain higher GWP values during peak hours in comparison with the annual average value was not completely confirmed here. In fact, many factors can cause variations in the GWP during different periods, such as the marginal technology used in peak hours and the baseline technology, which can make a difference in the overall GWP value. For this reason, it is important to consider not only economic savings but also environmental aspects when defining DR and flexibility strategies.

During low-demand times (e.g., night hours), the power requested is lower than during peak hours, and consequently it is logical that the GWP value should be lower than the average, because less resources are used to produce the electricity. In contrast, it should be noted that the comparison was always made taking into account the functional unit equal to 1 kWh. Hence, the time slots were not compared with their absolute production values but with relative ones, normalized to 1 kWh. For example, an hour with a power generation of 2000 MW can have a higher GWP value than a 5000 MW one, since it depends on the resources used to meet the demand. In summary, GWP is usually higher not because more electricity is produced, but because more fossil fuels are used to reach the maximum production.

Table 5.9 summarizes the results obtained with the traditional LCA and PH-LCA approaches in each specific country. Countries with a consistent share of flexible hydropower in their capacity portfolio such as Bulgaria, Norway and Spain mainly used this resource to meet the peak hours demand because of its rapidity in producing electricity and its low marginal cost. As a result, lower GWP figures were obtained compared to the yearly average. During the months in which the GWP was higher than the comparable value,

Table 5.9: Summary of results between LCA and peak-hourly life cycle assessment (PH-LCA).

Approach	Country / Indicator	Bulgaria (kg CO ₂ -eq/kWh)	Germany (kg CO ₂ -eq/kWh)	The Netherlands (kg CO ₂ -eq/kWh)	Norway (kg CO ₂ -eq/kWh)	Spain (kg CO ₂ -eq/kWh)
Traditional LCA	Yearly average GWP	0.617	0.476	0.287	0.0287	0.281
	Minimum GWP on PH (month) (April)	0.397	0.362	0.256	0.0172 (August)	0.157 (March)
Attributional PH-LCA	Maximum GWP on PH (month) (October)	0.717	0.502 (February)	0.303 (August)	0.0335 (May)	0.341 (September) (November)
	PH Resources	Lignite Hydro	Solar Lignite Wind	Natural gas Solar Wind	Hydro Natural gas	Wind Natural gas Hydro
	Average – PH difference [%]	–35.7% and +16.21%	–23.9% and +5.2%	–10.9% and +5.6%	–40.1% and +16.7%	–44.2% and +21.3%

it was demonstrated that the more conventional power plants were powered to reach the demand during the spikes of production, because of nationwide lacks in rainfall and water shortages.

Germany and the Netherlands mainly had their peak hours production during times in which wind and/or solar power were efficiently running, also leading to lower GWP values. Particularly in Germany, the good alternation of sunny and windy days, the first ones during the summer months and the second ones during winter, were advantageous for the national electricity grid. Regarding the Netherlands, the almost constant usage of natural gas to match the national electricity request throughout the year did not lead to substantial changes in the monthly GWP values. In addition, countries which do not have the geographical morphology to host PHS plants could investigate the potential of centralized and distributed energy storage to shave the generation electricity curve and provide flexibility to the electricity grid.

The results of this study show that by considering the environmental impact of electricity generation, flexible resources such as EVs, water boilers, or batteries can be scheduled according to carbon intensity, reducing their environmental impacts, which is in line with the findings of Baumann et al. [31]. At present, DR strategies and flexibility services are implemented following price signals, for the purpose of achieving economic savings for the end-user. However, if decarbonization is the main objective of these initiatives, flexibility potential should be environmentally assessed. By implementing peak-shaving or load-shifting strategies from peak hours to off-peak hours, the flexibility potential can be quantified in CO₂ savings, using the maximum peak-hourly GWP value and the average GWP for the same functional unit. According to Table 5.9, the flexibility potential was around 16% in Bulgaria and Norway, greater than 5% in Germany and The Nether-

lands, and 21.3% in Spain, being the country with the maximum flexibility potential.

The stability of the EU energy sector can be confirmed by looking at the general degrowth in the electricity prices according to the latest report of the EU Agency for the Cooperation of Energy Regulators (ACER) [?]. This trend has caused a reduction in electricity generation peaks and valleys. Nevertheless, the authors do not think that this would be an obstacle for the exploitation of large-scale batteries and other storage systems (e.g., PHS). On the other hand, the current EU Emissions Trading System does not lead to higher prices for fossil power plant owners [?], which is why gas turbines are still a competitive and trusted choice to cover the peak demand in some countries.

The presented study is replicable in other countries, following the same methodology and using statistical data sources from electricity generation. The only obstacle may be the lack of hourly data regarding the national electricity generation and missing data about the different power plants, especially their carbon intensity per kWh produced. Life cycle inventory data sourcing has been complex since ENTSO-E is the only platform available for collecting data from national grid mixes on an hourly basis. Besides, the aggregation between data coming from ENTSO-E and data from the GaBi® Software professional database could add uncertainty to these results, adding limitations to the study. Furthermore, the traditional LCA approach was implemented in order to compare the environmental impact of peak hours' electricity production with the general trend, obtaining a yearly average GHG value. Other methodologies using monthly, daily, or off-peak comparisons could be further developed in the next steps of this analysis in order to maximize the flexibility potential accuracy in optimization models.

Regarding the methodology, prior literature review states that time-varying environmental assessment and LCA approaches are the methods that should be considered when assessing the GHG emissions from the electricity sector [18, 26, 31, 34], aligned with the methodology presented in this publication. However, uncertainties in LCA initiatives may affect strategic plans and government policies, as stated by [?]. LCA models should resemble emissions in the real world. In this paper, data were gathered from the statistical database of the ENTSO-E, which collects data directly from the different TSOs, and ensures the quality and validation of data coming from real sources, according to [?]. Additionally, databases used under the LCI for electricity modeling in this research paper (i.e., GaBi® Software Professional Database and ecoinvent 3.1) are validated by external entities and publications [19, 45].

5.10 Conclusions

This study proposed a general peak-hourly LCA methodology to environmentally assess electricity production by calculating the carbon footprint based on GWP values throughout one year of study. This methodology can be implemented using statistical sources of hourly electricity production and energy sources databases. To develop the case study, the ENTSO-E TP was considered, which is currently the database with most reliable data in electricity generation. Then, the proposed methodology was applied to all the pilot sites of the INVADE H2020 project that are integrating DERs and flexible loads to provide flexible services. The study is based on an hourly analysis to ensure that peak hours can be assessed in terms of GWP. This paper presented the results of the GWP impact category of five different pilot-site countries belonging to the project. Bulgaria was the studied country with the highest yearly average GWP ($0.617 \text{ kg CO}_2\text{-eq/kWh}$), led by lignite-based power plants but with a hydro power potential widely used to meet the peak demand. Germany showed a high potential in renewable use during peak hours, but the base load was still covered by fossil fuels like lignite and hard coal, leading to a yearly average GWP of $0.476 \text{ kg CO}_2\text{-eq/kWh}$. The Netherlands had the lowest fluctuations in terms of monthly GWP during peak hours, being in the range between 0.256 and $0.303 \text{ kg CO}_2\text{-eq/kWh}$ (respectively -10.9% and $+5.6\%$ in comparison with the yearly average value of $0.287 \text{ kg CO}_2\text{-eq/kWh}$), displaying the use of the same strategy in the electricity generation mix for both peak and base loads. Norway had high relative but limited variations, considering the changes in the monthly GWP affected the yearly average value ($0.0278 \text{ kg CO}_2\text{-eq/kWh}$) in a scale of $10^{-3} \text{ kg CO}_2\text{-eq/kWh}$ and so the peak hours had a limited influence on the environmental impacts of electricity production in the country. In Spain, the monthly GWP changed substantially throughout the year, especially in September when the value increased by $+21.3\%$ compared to the yearly average ($0.281 \text{ kg CO}_2\text{-eq/kWh}$) and in March when the carbon intensity during peak hours had a difference in percentage of -44.2% compared to yearly average. The differentiation between resources used in peak hours and off-peak hours was highlighted and discussed, helping to understand the overall GWP value. We determined that seasonality is an important factor in terms of resources utilization and thus in GWP. The comparison between peak-hourly LCA and traditional LCA results proved that the average approaches fell short in quantifying the environmental impacts of time-varying systems, as is the case of electricity production.

Using time-varying carbon prices based on temporal carbon intensity variations could be a good approach for designing carbon pricing strategies, enhancing the transition towards a low-carbon energy system. When defining and implementing DSM strategies, not only economic benefits should be considered, but also the environmental impacts or savings thanks to load shifting and peak-shaving. Flexibility should be quantified in terms of carbon intensity, since not all countries use the most polluting resources as natural gas or coal for covering peak-hours demand.

Other aspects could be investigated further, such as analyzing the potential environmental impacts of electricity grid mixes, but by adding other indicators apart from GWP, like human health impact, resource depletion, and ecotoxicity. Additionally, the integration of centralized energy storage (CES) in the grid could be environmentally assessed by means of a consequential LCA, analyzing the shift in the generation profile, conceivably shifting the peak hours in the curve, developing a new scenario where electricity production and consumption do not have the same profile, but also considering the environmental impact of the CES life cycle. The same approach could be applied to assess the possible variations of renewable sources power output, considering uncertainty. Furthermore, the optimization in the use of flexible hydropower to reduce the environmental impacts of the electricity generation is a topic of wide interest that could be further studied.

Chapter 6

Conclusions

This thesis gathers several studies related to flexibility services, and each chapter outlines specific conclusions based on the results. Despite, the present chapter exposes the main conclusions of the thesis, summarizes the main contributions and draw further research required for the resolution of remaining questions.

6.1 General conclusions

6.2 Contributions

The main contributions are listed below:

- Chapter XXX:
 - XXXX
 - XXXX
- Chapter XXX:
 - XXXX
 - XXXX
- Chapter XXX:
 - XXXX
 - XXXX

6.3 Future work

- Chapter XXX:
 - XXXX

Chapter 6 Conclusions

- XXXX
- Chapter XXX:
 - XXXX
 - XXXX
- Chapter XXX:
 - XXXX
 - XXXX

Bibliography

- [1] European Commission, “Energy Roadmap 2050,” *Publications Office of the European Union*, no. April, p. 5, 2012. [Online]. Available: <http://www.roadmap2050.eu/> 11
- [2] (IEA), “International energy agency. global energy and co2 status report 2017,” pp. 3–4, 2018. [Online]. Available: <https://www.iea.org/publications/freepublications/publication/GECO2017.pdf> 11
- [3] G. Plessmann and P. Blechinger, “How to meet eu ghg emission reduction targets? a model based decarbonization pathway for europe’s electricity supply system until 2050,” *Energy Strategy Reviews*, vol. 15, pp. 19 – 32, 2017. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S2211467X16300530> 12
- [4] USEF Foundation, *USEF: The Framework Explained*, 2015. [Online]. Available: <http://www.usef.info/Framework/Download-the-Framework.aspx> 12
- [5] I. Munné-Collado, E. Bullich-Massagué, M. Aragüés Peñalba, and P. Olivella-Rosell, *Local and Micro Power Markets*. John Wiley & Sons, Ltd, 2019, ch. 2, pp. 37–96. [Online]. Available: <https://onlinelibrary.wiley.com/doi/abs/10.1002/9781119434573.ch2> 12
- [6] A. Nilsson, D. Lazarevic, N. Brandt, and O. Kordas, “Household responsiveness to residential demand response strategies: Results and policy implications from a swedish field study,” *Energy Policy*, vol. 122, pp. 273 – 286, 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0301421518304890> 12
- [7] C. Gerbaulet, C. von Hirschhausen, C. Kemfert, C. Lorenz, and P.-Y. Oei, “European electricity sector decarbonization under different levels of foresight,” *Renewable Energy*, vol. 141, pp. 973 – 987, 2019. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0960148119302538> 12

Bibliography

- [8] M. Child, C. Kemfert, D. Bogdanov, and C. Breyer, “Flexible electricity generation, grid exchange and storage for the transition to a 100energy system in europe,” *Renewable Energy*, vol. 139, pp. 80 – 101, 2019. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0960148119302319> 12
- [9] P. Olivella-Rosell, P. Lloret-Gallego, I. Munné-Collado, R. Villafafila-Robles, A. Sumper, S. d. Ottessen, J. Rajasekharan, and B. A. Bremsdal, “Local flexibility market design for aggregators providing multiple flexibility services at distribution network level,” *Energies*, vol. 11, no. 4, 2018. [Online]. Available: <https://www.mdpi.com/1996-1073/11/4/822> 12
- [10] S. A. Neves, A. C. Marques, and J. A. Fuinhas, “On the drivers of peak electricity demand: What is the role played by battery electric cars?” *Energy*, vol. 159, pp. 905 – 915, 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S036054421831274X> 12
- [11] H. W. Sinn, “Public policies against global warming: A supply side approach,” *International Tax and Public Finance*, vol. 15, no. 4, pp. 360–394, 2008. 12
- [12] H. Murdock, “Renewable energy policies in a time of transition,” Tech. Rep., 2018. 12
- [13] K. Dahal, S. Juhola, and J. Niemela, “The role of renewable energy policies for carbon neutrality in helsinki metropolitan area,” *Sustainable Cities and Society*, vol. 40, pp. 222 – 232, 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S2210670718300532> 12
- [14] T. Levin, J. Kwon, and A. Botterud, “The long-term impacts of carbon and variable renewable energy policies on electricity markets,” *Energy Policy*, vol. 131, pp. 53 – 71, 2019. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0301421519301600> 12
- [15] R. Best and P. J. Burke, “Adoption of solar and wind energy: The roles of carbon pricing and aggregate policy support,” *Energy Policy*, vol. 118, pp. 404 – 417, 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0301421518301848> 12
- [16] X. Zhao and D. Luo, “Forecasting fossil energy consumption structure toward low-carbon and sustainable economy in china: Evidence and policy responses,” *Energy Strategy Reviews*, vol. 22, pp. 303 –

- 312, 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S2211467X18300932> 12
- [17] S. Simoes, W. Nijs, P. Ruiz, A. Sgobbi, and C. Thiel, “Comparing policy routes for low-carbon power technology deployment in eu. an energy system analysis,” *Energy Policy*, vol. 101, pp. 353 – 365, 2017. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0301421516305493> 12
- [18] I. Khan, “Temporal carbon intensity analysis: renewable versus fossil fuel dominated electricity systems,” *Energy Sources, Part A: Recovery, Utilization and Environmental Effects*, vol. 41, no. 3, pp. 309–323, 2019. [Online]. Available: <https://doi.org/10.1080/15567036.2018.1516013> 12, 36
- [19] M. Buyle, J. Anthonissen, W. Van den Bergh, J. Braet, and A. Audenaert, “Analysis of the belgian electricity mix used in environmental life cycle assessment studies: how reliable is the ecoinvent 3.1 mix?” *Energy Efficiency*, vol. 12, no. 5, pp. 1105–1121, Jun 2019. 12, 16, 36
- [20] C. Jones, P. Gilbert, M. Raugei, S. Mander, and E. Leccisi, “An approach to prospective consequential life cycle assessment and net energy analysis of distributed electricity generation,” *Energy Policy*, vol. 100, pp. 350–358, 2017. [Online]. Available: <http://dx.doi.org/10.1016/j.enpol.2016.08.030> 12, 14, 15
- [21] R. Pattupara and R. Kannan, “Alternative low-carbon electricity pathways in switzerland and it’s neighbouring countries under a nuclear phase-out scenario,” *Applied Energy*, vol. 172, pp. 152 – 168, 2016. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S030626191630410X> 12
- [22] International Energy Agency, “Electricity information: Data and publications 2018,” Dec. 2018. [Online]. Available: <https://webstore.iea.org/electricity-information-2018> 13
- [23] S. Eun Kim, J. Yang, and J. Urpelainen, “Does power sector deregulation promote or discourage renewable energy policy? evidence from the states, 1991–2012,” *Review of Policy Research*, vol. 33, no. 1, pp. 22–50, 2016. 13
- [24] D. Richeson, “By the Numbers,” *College Mathematics Journal*, vol. 50, no. 4, pp. 286–287, 2019. 13

Bibliography

- [25] M. Zhang, X. Liu, W. Wang, and M. Zhou, “Decomposition analysis of co2 emissions from electricity generation in china,” *Energy Policy*, vol. 52, pp. 159 – 165, 2013, special Section: Transition Pathways to a Low Carbon Economy. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0301421512008713> 13
- [26] M. Messagie, J. Mertens, L. Oliveira, S. Rangaraju, J. Sanfelix, T. Coosemans, J. V. Mierlo, and C. Macharis, “The hourly life cycle carbon footprint of electricity generation in belgium, bringing a temporal resolution in life cycle assessment,” *Applied Energy*, vol. 134, pp. 469 – 476, 2014. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0306261914008824> 13, 16, 36
- [27] A. Nilsson, P. Stoll, and N. Brandt, “Assessing the impact of real-time price visualization on residential electricity consumption, costs, and carbon emissions,” *Resources, Conservation and Recycling*, vol. 124, pp. 152–161, 2017. [Online]. Available: <http://dx.doi.org/10.1016/j.resconrec.2015.10.007> 13, 16, 18, 19
- [28] E. Cubi, G. Doluweera, and J. Bergerson, “Incorporation of electricity GHG emissions intensity variability into building environmental assessment,” *Applied Energy*, vol. 159, pp. 62–69, 2015. [Online]. Available: <http://dx.doi.org/10.1016/j.apenergy.2015.08.091> 13, 16, 18, 19
- [29] I. Khan, “Importance of GHG emissions assessment in the electricity grid expansion towards a low-carbon future: a time-varying carbon intensity approach,” *Journal of Cleaner Production*, vol. 196, pp. 1587–1599, 2018. [Online]. Available: <https://doi.org/10.1016/j.jclepro.2018.06.162> 13, 16, 18, 19
- [30] I. Khan, M. W. Jack, and J. Stephenson, “Analysis of greenhouse gas emissions in electricity systems using time-varying carbon intensity,” *Journal of Cleaner Production*, vol. 184, pp. 1091–1101, 2018. [Online]. Available: <https://doi.org/10.1016/j.jclepro.2018.02.309> 13, 16, 18, 19
- [31] M. Baumann, M. Salzinger, S. Remppis, B. Schober, M. Held, and R. Graf, “Reducing the environmental impacts of electric vehicles and electricity supply. how hourly defined life cycle assessment and smart charging can contribute,” *World Electric Vehicle Journal*, vol. 10, no. 1, 2019. 13, 35, 36

- [32] S. Rangaraju, L. D. Vroey, M. Messagie, J. Mertens, and J. V. Mierlo, “Impacts of electricity mix, charging profile, and driving behavior on the emissions performance of battery electric vehicles: A belgian case study,” *Applied Energy*, vol. 148, pp. 496 – 505, 2015. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0306261915001580> 13
- [33] V. Olkkonen and S. Syri, “Spatial and temporal variations of marginal electricity generation: The case of the Finnish, Nordic, and European energy systems up to 2030,” *Journal of Cleaner Production*, vol. 126, pp. 515–525, 2016. 13
- [34] I. Khan, “Greenhouse gas emission accounting approaches in electricity generation systems: A review,” *Atmospheric Environment*, vol. 200, no. December 2018, pp. 131–141, 2019. [Online]. Available: <https://doi.org/10.1016/j.atmosenv.2018.12.005> 14, 36
- [35] D. Garcia-Gusano, D. Garrain, and J. Dufour, “Prospective life cycle assessment of the Spanish electricity production,” *Renewable and Sustainable Energy Reviews*, vol. 75, no. June 2016, pp. 21–34, 2017. [Online]. Available: <http://dx.doi.org/10.1016/j.rser.2016.10.045> 14, 15
- [36] H. Lund, B. V. Mathiesen, P. Christensen, and J. H. Schmidt, “Energy system analysis of marginal electricity supply in consequential LCA,” *International Journal of Life Cycle Assessment*, vol. 15, no. 3, pp. 260–271, 2010. 14, 15
- [37] R. C. Thomson, G. P. Harrison, and J. P. Chick, “Marginal greenhouse gas emissions displacement of wind power in Great Britain,” *Energy Policy*, vol. 101, no. September 2016, pp. 201–210, 2017. [Online]. Available: <http://dx.doi.org/10.1016/j.enpol.2016.11.012> 14, 15
- [38] B. Howard, M. Waite, and V. Modi, “Current and near-term GHG emissions factors from electricity production for New York State and New York City,” *Applied Energy*, vol. 187, pp. 255–271, 2017. [Online]. Available: <http://dx.doi.org/10.1016/j.apenergy.2016.11.061> 14, 15
- [39] R. Garcia, P. Marques, and F. Freire, “Life-cycle assessment of electricity in Portugal,” *Applied Energy*, vol. 134, pp. 563–572, 2014. [Online]. Available: <http://dx.doi.org/10.1016/j.apenergy.2014.08.067> 14, 15

Bibliography

- [40] R. Garcia and F. Freire, "Marginal Life-Cycle Greenhouse Gas Emissions of Electricity Generation in Portugal and Implications for Electric Vehicles," *Resources*, vol. 5, no. 4, p. 41, 2016. 15
- [41] M. A. Curran, M. Mann, and G. Norris, "The international workshop on electricity data for life cycle inventories," *Journal of Cleaner Production*, vol. 13, no. 8, pp. 853–862, 2005. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0959652604000460> 15
- [42] S. Soimakallio, J. Kiviluoma, and L. Saikku, "The complexity and challenges of determining GHG (greenhouse gas) emissions from grid electricity consumption and conservation in LCA (life cycle assessment) - A methodological review," *Energy*, vol. 36, no. 12, pp. 6705–6713, 2011. [Online]. Available: <http://dx.doi.org/10.1016/j.energy.2011.10.028> 15, 17
- [43] R. Turconi, A. Boldrin, and T. Astrup, "Life cycle assessment (LCA) of electricity generation technologies: Overview, comparability and limitations," *Renewable and Sustainable Energy Reviews*, vol. 28, pp. 555–565, 2013. xvii, 15, 24
- [44] A. Moro and L. Lonza, "Electricity carbon intensity in European Member States: Impacts on GHG emissions of electric vehicles," *Transportation Research Part D: Transport and Environment*, vol. 64, no. April 2017, pp. 5–14, 2017. [Online]. Available: <https://doi.org/10.1016/j.trd.2017.07.012> 15, 18, 29
- [45] "Iso 14044:2006. environmental management- life cycle assessment - requirements and guidelines," International Organization for Standardization, Tech. Rep., 2006. 15, 18, 36
- [46] "Iso 14040: Environmental management - life cycle assessment - principles and framework," International Organization for Standardization, Tech. Rep., 2006. 15
- [47] G. Rebitzer, T. Ekvall, R. Frischknecht, D. Hunkeler, G. Norris, T. Rydberg, W.-P. Schmidt, S. Suh, B. Weidema, and D. Pennington, "Life cycle assessment: Part 1: Framework, goal and scope definition, inventory analysis, and applications," *Environment International*, vol. 30, no. 5, pp. 701 – 720, 2004. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0160412003002459> 15, 19

Bibliography

- [48] J. Guinée, “Handbook on life cycle assessment — operational guide to the iso standards,” *The International Journal of Life Cycle Assessment*, vol. 6, no. 5, pp. 255–255, Sep 2001. [Online]. Available: <https://doi.org/10.1007/BF02978784> 16

Appendix A

Publications

Included in the thesis

Published journal papers

J2 P. Olivella-Rosell, P. Lloret-Gallego, Í. Munné-Collado, R. Villafafila-Robles, A. Sumper, S. Ottesen, J. Rajasekharan, B. Bremdal, “Local flexibility market design for aggregators providing multiple flexibility services at distribution network Level,” *Energies*, vol. 11, no. 4, p. 822, Apr. 2018. doi: 10.3390/en11040822

Submitted journal papers

J4 flexibility review hussain

Conference papers

C1 I. Munné-Collado, P. Lloret-Gallego, P. Olivella-Rosell, R. Villafafila-Robles, S. Ø. Ottesen, R. Gallart-Fernandez, V. Palma-Costa, A. Sumper, “System architecture for managing congestions in distributions grids using flexibility,” 25th International Conference on Electricity Distribution, June 2019.

- conference sara LCA

Book chapters

BC1 Í. Munné-Collado, P. Olivella-Rosell, A. Sumper, “Power Market Fundamentals,” in A. Sumper (ed) Micro and Local Power Markets, John Wiley & Sons, pp. 1-35, 2019. doi: 10.1002/9781119434573.ch1

BC2 Í. Munné-Collado, E. Bullich-Massagué, M. Aragüés-Peñalba, P. Olivella-Rosell “Local and Micro Power Markets,” in A. Sumper (ed) Micro and

Appendix A Publications

Local Power Markets, John Wiley & Sons, pp. 37-97, 2019.
doi: 10.1002/9781119434573.ch2

Not included in the thesis

Published journal papers

J3 Í. Munné-Collado, F. M. Aprà, P. Olivella-Rosell, R. Villafafila-Robles, A. Sumper, “The potential role of flexibility during peak hours on greenhouse gas emissions: a life cycle assessment of five targeted national electricity grid mixes,” *Energies*, vol. 12, no. 23, Nov. 2019. doi: 10.3390/en12234443

J4 review sara big data

J5 review hussain

Submitted journal papers

Conference papers

- kejrwejr

Local conferences

Published papers

Conference presentations

Supervised bachelor and master thesis

T1 F. Aprà, “Environomical analysis of peak hours electricity production in targeted European countries”, June 2019.

T2 K.,Beehuspoteea, “Impact factors of heat generation units for zoned temperature controlled in office buildings”, June 2019.

T3 A. Quattrone, “Development of flexibility device models for a micro-grid laboratory test”, June 2019.

T4 N. Condorelli, “Evaluation and forecast of CO₂ emissions in the electricity sector for European targeted countries” March 2020.

- T5** P. Plana, “Analysis of measures to increment the share of renewable energy in distribution grids” April 2020.
- T6** A. Bové Salat, “Optimal scheduling of flexible assets under a HEMS for prosumers’ economic savings” June 2020.
- T7** M. Ferran, “Power flow tool for active distribution grids and flexibility analysis”, June 2020.

Published technical reports

TR7 E. F. Bødal, P. Crespo-del-Granado, H. Farahmand, M. Korpås, P. Olivella-Rosell, I. Munné-Collado, P. Lloret-Gallego, “INVADE Deliverable 5.1 Challenges in distribution grid with high penetration of renewables,” June 2017. doi: 10.5281/zenodo.853271

- entregables INVADE LCA?
- entregables EMPOWER LCA?

