


APPROVER PLEASE CONFIRM
THAT EMBED'S WIDTH SHOULD
BE 5" NOT 8"




SECTION A - A

10 - EMBEDS - 20EM101

BILL OF MATERIAL									
QTY	SHIPPING BILL		SHOP BILL						
	NO. Pcs.	ERECTION MARK	NO.	SHAPE	MATERIAL GRADE	LENGTH	ASSY. MARK	REMARKS	WEIGHT
20	10	20EM101		EMBED				SQ-2	
			10	PL3/8"X5"	A36	0-10	20EM101	NO PAINT	53
			20	STUD 3/8 DIA	A108	0-5			4
TOTAL WEIGHT THIS DRAWING									57

HEADED STUDS SHOULD BE
ELECTRIC ARC (FUSION) WELDED

 <div style="display: inline-block; vertical-align: middle; margin-left: 10px;"> <p>ALAMO STRUCTURAL STEEL</p> <p style="font-size: small;">2784 OLD DALLAS RD. WACO, TEXAS 76705 PHONE: 254 799 2471 FAX: 254 799 6227</p> </div>			
FIELD CONN (U.N.)		HOLES (U.N.)	
3/4 A325N_TC		13/16"	
SURFACE PREP SSPC-SP2		SHOP PAINT NO PAINT	
DATE 10/04/2022		DET RFW	CHK AJM
JOB NO. 32-22017		DRAWING NO. 20EM101	