Municipality of Princeton
Witherspoon Hall
400 Witherspoon Street
Princeton, NJ 08540-3496

Office of the Engineer
Telephone (609)921-7077
Facsimile (609) 688-2026

JOHN M. WEST, P.E., P.E.
Land Use Engineer
jwest@princetonnj.gov

December 6, 2016

Chris Tarr, Esq.
Stevens & Lee
Princeton Pike Corporate Center
100 Lenox Drive – Suite 200
Lawrenceville, New Jersey 08648

RE: 86 Spruce Street; Block 30.03, Lots 62 & 63;
86 Spruce Street, LLC Owner / Applicant
Parking Lot-Minor Site Plan, Zone R4 (Boro)
Z1616-420

Dear Mr. Tarr:

The administrative staff has reviewed your above referenced application and it is hereby deemed incomplete due to the following incomplete checklist items:

1. Section 17A-390 of the Borough Code requires parking lots be paved and landscaped. The plans should be revised or a variance requested.
2. Section 17A-365.1 of the Borough Code prohibits the use of building mounted flood lights. The plans should be revised or a variance requested.
3. The Zoning Chart indicates an existing F.A.R. of 44% and a proposed F.A.R. of 39.4%, however, no changes are proposed. Please clarify the F.A.R.

Please call if you have any questions. We would be happy to meet with you regarding this letter.

Sincerely,

John M West, P.E.
Land Use Engineer
cc:
Derek Bridger, Zoning Officer
Ilene Cutroneo, Adm. Coordinator, Planning Board of Princeton
Claudia Ceballos