Municipality of Princeton
Municipal Building
400 Witherspoon Street
Princeton, NJ 08540-3496

Office of the Land Use Engineer
Telephone (609)921-7077
Fax: (609) 688-2027

March 21, 2017

Chris Tarr, Esq.
Stevens & Lee
Princeton Pike Corporate Center
100 Lenox Drive – Suite 200
Lawrenceville, New Jersey 08648

RE: 86 Spruce Street; Block 30.03, Lots 62 & 63;
86 Spruce Street, LLC Owner / Applicant
Parking Lot-Minor Site Plan, Zone R4 (Boro)
Z1616-420

Dear Mr. Tarr:

The administrative staff has reviewed your above referenced application for compliance with the conditions of approval and the following items must be addressed:

1. The rain garden should be elongated along the entire width of the parking lot.
2. A detailed planning list and maintenance schedule should be provided for the rain garden.
3. Black Cherry is not an acceptable street tree, tree selection should be coordinated with the Municipal Arborist.

Please call if you have any questions. We would be happy to meet with you regarding this letter.

Sincerely,

John M West, P.E.
Land Use Engineer
cc:
Derek Bridger, Zoning Officer
Ilene Cutroneo, Adm. Coordinator, Planning Board of Princeton
Claudia Ceballos