D01 | 15/05/2020 | ISSUED FOR REFERENCE | AMJ | SGC | SHD | PRI

DRAWING NUMBER: MD-216-49PR-EG-CV-GAD-1596 | REV D01

# SECTION : A - A
(SCALE - 1:50)

# LAYOUT OF GRADE SLAB FOR ENGINE HALL
(SCALE 1:75)

SCHEDULE 40 PVC PIPE WILL BE USED AS CABLE CONDUIT. SAND FILLING IN CABLE CONDUIT AREA SHALL BE DONE AND CONSOLIDATION SHALL BE DONE WITH WATER NO ROLLER COMPACTOR SHALL BE USED. BELLOW ENGINE FOUNDATION THEEXTRA EXCAVTED PART SHALL BE FILLED WITH C-15 LEAN MIX.

# KEY PLAN
(SCALE 1:1000)

# DETAIL - A
(SCALE - 1:25)

# DETAIL - B1
(SCALE 1:30)

# DETAIL - C1
(SCALE 1:25)

# DETAIL - B
(SCALE 1:30)

# DETAIL - D
(TYP. DETAIL OF DRAIN MKD. A TO F)
(SCALE 1:30)

# SECTION E - E
(SCALE - 1:25)

# SECTION G - G
(SCALE 1:50)

# DETAIL - C
(SCALE 1:25)

# SECTION H - H
(SCALE 1:50)

# SECTION J - J
(SCALE 1:50)

# SECTION F - F
(SCALE 1:30)

# SECTION K - K
(SCALE 1:50)

# SECTION L-L
(SCALE 1:50)

# DETAIL - '1'
(SCALE 1:50)

# DETAIL - '2'
(SCALE 1:50)

# DETAIL - '3'
(SCALE 1:50)

# SECTION P - P
(SCALE 1:30)

# SECTION Q-Q
(SCALE 1:50)

# SECTION 7-7
(SCALE 1:30)

# DETAIL - X
(SCALE 1:10)

# SECTION M - M
(SCALE 1:25)

# DETAIL - '8'
(SCALE 1:30)

# SECTION S-S
(SCALE 1:50)

# SECTION N - N
(TYP. DETAIL OF DRAIN PIT)
(SCALE 1:50)

# SECTION 6-6
(SCALE 1:30)

# DETAIL - Y
(SCALE 1:10)

# SECTION Y - Y
(SCALE 1:50)

# DETAIL - '9'
(SCALE 1:30)

# DETAIL - C1
(SHOWING RC DETAIL)
(SCALE 1:20)

# SECTION 1-1
(SCALE 1:50)

# SECTION L-L
(SHOWING RC DETAIL)
(SCALE 1:50)

# SECTION K - K
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION 6-6
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION 7-7
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION N - N
(SHOWING RC DETAIL)
(SCALE 1:50)

# SECTION M - M
(SHOWING RC DETAIL)
(SCALE 1:25)

# TYP. RC DETAIL OF FLOOR DRAIN PIT
(SCALE 1:30)

# TYP. RC DETAIL OF BEAM. MKD. B1
(SCALE 1:25)

# DETAIL OF CHQD. PLATE FOR OIL WATER COLLECTING SUMP
(SCALE 1:50)

# SECTION F - F
(SHOWING RC DETAIL)
(SCALE 1:20)

# SECTION P - P
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION Y - Y
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION M - M
(SHOWING RC DETAIL)
(SCALE 1:25)

# TYP. DETAIL OF MS RUNG LADDER
(SCALE 1:20)

# SECTION G - G
(SHOWING RC DETAIL)
(SCALE 1:30)

# DETAIL - B
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION H - H
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION J - J
(SHOWING RC DETAIL)
(SCALE 1:30)

# SECTION R-R
(SCALE 1:50)

# TYP. RC DETAIL OF 200 THK. HEAVY DUTY GRADE SLAB
SCALE 1:25

# TYP. RC DETAIL OF 150 THK. HEAVY DUTY GRADE SLAB
SCALE 1:25

# DETAIL - B1
(SHOWING RC DETAIL)
(SCALE 1:30)

# DETAIL - Z
(SCALE 1:10)

## LEGEND :-

R.L. - REDUCED LEVEL
T.O.C. - TOP OF CONCRETE.
F.G.L. - FINISHED GROUND LEVEL.
TYP. - TYPICAL.
P.C.C. - PLAIN CEMENT CONCRETE
℄ - CENTRE LINE
MKD. - MARKED
B.O.F. - BOTTOM OF FOUNDATION
THK. - THICK
FDN. - FOUNDATION
DIA - DIAMETER
DWG.- DRAWING
C/C- CENTRE TO CENTRE
OS. - OILY WATER DRAINAGE PIPE
I.L. - INVERT LEVEL
CE - CONDUIT EARTHING
PS - PIPE SLEEVE
N.T.S. - NOT TO SCALE

## NOTES :-

1. ALL DIMENSIONS ARE IN MILLIMETERS AND LEVELS AND CO-ORDINATES ARE IN METERS. UNLESS OTHERWISE STATED.
2. GRADE OF CONCRETE SHALL BE 35 MPa FOR FOUNDATION & 15 MPa FOR BLINDING CONCRETE.
3. GRADE OF REINFORCEMENT SHALL BE DEFORMED BAR 420 MPa (GRADE 60) - ASTM A615/A615M.
4. NET SAFE BEARING CAPACITY OF SOIL AT BOTTOM OF FOUNDATION CONSIDER 450KN/ SQ. M.
5. CLEAR COVER TO MAIN REINFORCEMENT SHALL BE 75 mm FOR RAFT & 50 mm FOR COLUMN.
6. IF ANY PART OF FOUNDATION COMES ON BACKFILL ZONE OF ADJACENT FOUNDATION OR ANY LOOSE SOIL ARE ENCOUNTERED BELOW FOUNDATION LEVEL THE SAME SHALL BE REMOVED AND FILLED WITH PCC.
7. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH DRAWING NO. MD-216-49PR-EG-ST-GAD-2400, MD-216-49PR-EG-ST-GAD-2408 & MD-216-49PR-EG-ST-GAD-2409.
8. FOR ALL OTHER NOTES REFER DRAWING NO. MD-101-SMEM-EG-ST-DST-0001 TO 0008
9. FOR GENERAL NOTES OF CIVIL WORKS & STANDARD REINFORCEMENT DETAIL REFER DRAWING NO. MD-216-1000-EG-CV-DED-1001 & 1005.
10. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH DRAWING NO. MD-216-49PR-EG-CV-GAD-1599.
11. OILY WATER DRAINAGE TO BE ADJUSTED ACCORDING TO SITE CONDITION.
12. FOR DETAILS OF GRADE SLAB REFER DRG. NO. MD-216-1000-EG-CV-DED-1002.
13. PIPING MATERIAL STANDARD - AT12, HDPE (PEA4710), ASTMD 3350, CLASS 445/4723.
14. ALL LEVELS AS MENTIONED ARE BOTTOM OF PIPE AND SCHEDULE 40 PVC PIPE FOR ELECTRICAL CONDUITS.

| DOCUMENT NUMBER | REFERENCE DOCUMENTS |
|---|---|
| MD-216-49PR-EG-EL-LAD-V553-1019 & 1011 | EARTHING LAYOUT |
| MD-101-SMEM-EG-EL-DST-0066 | ALL AREAS ELECTRICAL STANDARDS |
| | STRUCTURAL STEEL EARTHING TYPICAL DETAILS |
| DBAF507308 | ENGINE HALL CABLE CONDUIT |
| MD-216-1000-EG-ST-CRT-1001 | CIVIL, STRUCTURAL & ARCHITECTURAL-DESIGN CRITERIA |
| MD-216-49PR-EG-ME-GAD-V553-1001 | ENGINE & GENERATOR |
| MD-216-49PR-EG-ME-LAD-V553-1052 | ENGINE HALL, LOAD PLAN |
| MD-216-49PR-EG-ME-LAD-V553-1053 | ENGINE HALL, LOAD PLAN |
| MD-216-49PR-EG-ME-LAD-V553-1010 | ENGINE HALL, OILY WATER DRAINAGE |

| REV | DATE | REVISION DESCRIPTION | DRN | CHK | ENG | APP | EMP |
|---|---|---|---|---|---|---|---|
| D01 | 17/02/2023 | AS-BUILT & REVISED AS MKD. | SYA | SJM | AVG | AG | |
| C06 | 30/07/2021 | ISSUED FOR CONSTRUCTION AND REVISED AS MKD. | SYA | SJM | AVG | AG | |
| C05 | 07/12/2020 | ISSUED FOR CONSTRUCTION AND REVISED AS MKD. | PDK | SGC | SHD | PRI | |
| C04 | 28/11/2020 | ISSUED FOR CONSTRUCTION AND REVISED AS MKD. | PDK | SGC | SHD | PRI | |
| C03 | 16/10/2020 | ISSUED FOR CONSTRUCTION AND REVISED AS MKD. | AMJ | SGC | SHD | PRI | |
| C02 | 22/09/2020 | ISSUED FOR CONSTRUCTION AND REVISED AS MKD. | AMJ | SGC | SHD | PRI | |
| C01 | 01/09/2020 | ISSUED FOR CONSTRUCTION AND REVISED AS MKD. | AMJ | SGC | SHD | PRI | |
| A01 | 15/05/2020 | ISSUED FOR REFERENCE | AMJ | SGC | SHD | PRI | |

RESERVED FOR VENDOR LOGO AND DRAWING NUMBER

LARSEN & TOUBRO

This drawing is the property of LARSEN & TOUBRO and must not be passed on to any person or body not authorized by us to receive it nor be copied or otherwise made use either in full or in part by such person or body without our prior permission in writing.

Outotec

The content of these documents are the sole property of Outotec Oyj. Any rights not expressly granted herein are reserved. Reproduction, transfer or distribution of part or all of the contents in any form without prior written permission of Outotec is prohibited.

MA'ADEN معادن
Saudi Arabian Mining Company

This document and the information contained herein is Ma'aden proprietary know-how. This document or any part thereof should not be reproduced, stored in a retrieval system or transmitted by any means, electronic or otherwise, or divulged without prior written permission of Ma'aden.

| | |
|---|---|
| LARSEN & TOUBRO DRAWING NUMBER | 019045_008_C_G_24290_002 |
| REVISION | 7 |
| OUTOTEC DRAWING NUMBER | 900707__GAU01__WG01_MTL01__45055 |
| DOCUMENT ID | OU100682331 |
| REVISION | 7 |
| DRAWN | AMJ 24/04/2020 |
| CHECKED | SGC 12/05/2020 |
| ENGINEER | SHD 20/04/2020 |
| APPROVED | PRI 15/05/2020 |
| EMPLOYER | |
| SCALE | 1:200,100,20 |
| | A0 |

MANSOURAH - MASSARAH GOLD PROJECT
GENERAL ARRANGEMENT
ENGINE HALL
GA AND DETAIL OF GRADE SLAB

DRAWING NUMBER: MD-216-49PR-EG-CV-GAD-1596 | REV: D01