





R.C.C FOUNDATION DIMENSIONS TOP VIEW
(SCALE 1:20)




R.C.C FOUNDATION REINFORCEMENT TOP VIEW
(SCALE 1:20)



SECTION : D - D MAIN TOP REINFORCEMENT
(SCALE 1:10)



SECTION : D - D EXTRA TOP REINFORCEMENT
(SCALE 1:10)



SECTION : E - E
(SCALE 1:10)

CONCRETE INFORMATION

Concretes used	C35	
Concrete cover 1	75±10mm	BOTTOM AND SIDE OF FOUNDATION
Concrete cover 2	50±10mm	TOP OF FOUNDATION, COLUMN

REINFORCING BAR LIST

CAST UNIT CODE: P1 PCS: 1

REINFORCING BARS TYPE	POS	PCS	GRADE	D [mm]	L [mm]	dL [mm]	WEIGHT SUM [kg]	BENDING DIMENSIONS [mm] a	b	c	d	e	u	v	x	TD	COMMENT
U	P1/1	32	B500B	12	2170		61.9	164	500	500	500					60	
B	P1/2	32	B500B	16	2070		104.9	550	1565				90			80	
D	P1/3	32	B500B	12	1410		40.1	500	472	500						60	
A	P1/4	50	B500B	16	6510		514.3	6510									
A	P1/5	88	B500B	16	3640		506.1	3640									
D	P1/6	138	B500B	16	2120		463.2	900	405	900						80	
B	P1/7	4	B500B	16	1750		11.1	900	900				90			80	
A	P1/8	2	B500B	16	3560		11.2	3560									
U	P1/9	12	B500B	10	1320		9.8	132	294	294	294					40	
D	P1/10	32	B500B	8	770		9.8	350	110	350						32	
A	P1/11	2	B500B	16	6430		20.3	6430									

REINFORCING BAR TOTAL WEIGHT [kg] 1752.7

REINFORCEMENT BENDING SHAPES:




LEGEND:


- R.L. - REDUCED LEVEL
- T.O.C. - TOP OF CONCRETE
- B.O.F. - BOTTOM OF FOUNDATION
- F.G.L. - FINISHED GROUND LEVEL
- P.C.C. - PLAIN CEMENT CONCRETE
- TYP - TYPICAL
- MK'D - MARKED
- CL - CENTER LINE
- BOTTOM REINF. (B)
- TOP REINF. (T)
- SBC - SAFE BEARING CAPACITY
- MIN. - MINIMUM
- REF. - REFERED
- GA - GENERAL ARRANGEMENT
- DWG. - DRAWING
- R.C.C. - REINFORCED CEMENT CONCRETE

NOTES:


1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS ARE IN METRES UNLESS OTHERWISE STATED
2. GRADE OF CONCRETE SHALL BE C35 UNLESS NOTED OTHERWISE
3. GRADE OF REINFORCEMENT SHALL BE DEFORMED BAR ASTM A615-GRADE 60 (fy=420MPa)
4. CLEAR COVER TO MAIN REINFORCEMENT SHALL BE AS FOLLOWS:
   a) FOUNDATION: 75 mm (BOTTOM & SIDE)
   b) FOUNDATION: 50 mm (TOP)
   c) COLUMN & PEDESTAL: 50 mm
5. MINIMUM LAP LENGTHS OF REINFORCEMENT SHALL BE 40XBAR DIAMETER
6. FOR STANDARD REINFORCEMENT DETAILS & GENERAL NOTES FOR CIVIL WORKS REFER TO DRAWING NUMBER MD-216-1000-EG-CV-DED-1005 & 1001
7. ANCHOR BOLTS AND EMBEDDED STEELWORK SHALL BE HOT DEEP GALVANIZED
8. NET BEARING CAPACITY UNDER FOUNDATION 375 kPa



SECTION : A - A
(SCALE 1:20)




SECTION : B - B
(SCALE 1:20)



SECTION : C - C
(SCALE 1:20)

KEYPLAN


PLANT NORTH
GRIDLINE NORTH
GUARD ROOM
WATER TANK
WATER TANK
WATER TANK