

DRAWING NUMBER MD-216-49PQ-EG-CV-GAD-1608 REV D01




SECTION : A'-A'

SCALE 1:50




SECTION : B'-B'

SCALE 1:50




RC. DET. OF FOUNDATION
MKD. F1

SCALE 1:50




RC. DET. OF FOUNDATION
MKD. F2 & F3

SCALE 1:50




TYP. DET. OF INSERT MKD. IP-1 CHANNEL
TYPE E1000CI OR EQUIVALENT

SCALE - 1:5




SECTION : 3-3

SCALE - 1:5



PLAN : 2-2


SCALE - 1:5



VIEW : 4-4


(DETAIL OF COL. MKD. C2)

SCALE 1:20




RC. DET. OF COLUMN
MKD. C2

SCALE 1:20




SECTION : E-E

SCALE 1:50




SECTION : E'-E'

SCALE 1:50




DET. OF FOUNDATION
MKD. F5

SCALE 1:50




R.C DET. OF FOUNDATION
MKD. F5

SCALE 1:50




SECTION : F-F




DET. OF FOUNDATION
MKD. F6

SCALE 1:50




DET. OF FOUNDATION
MKD. F1

SCALE 1:50




SECTION : A-A

SCALE 1:50




VIEW : 1X-1X

SCALE 1:50




SECTION : B-B

SCALE 1:50



DET. OF FOUNDATION
MKD. F2 & F3


SCALE 1:50



VIEW : 1-1


(DETAIL OF COL. MKD. C1)

SCALE 1:20




RCC. DET. OF COL.
MKD. C1

SCALE 1:20




RC. DET. OF TB-2

SCALE 1:20




RC. DET. OF TB-1

SCALE 1:20




SECTION : D-D

SCALE 1:50




DET. OF FOUNDATION
MKD. F4

SCALE 1:50



SECTION : D'-D'

SCALE 1:50



R.C DET. OF FOUNDATION
MKD. F4

SCALE 1:50

LEGENDS :-

R.L. - REDUCED LEVEL
℄ - CENTRE LINE
T.O.C. - TOP OF CONCRETE
T.O.G. - TOP OF GROUT
TYP. - TYPICAL
F.G.L. - FINISHED GROUND LEVEL
F.F.L. - FINISHED FLOOR LEVEL
B.O.F. - BOTTOM OF FOUNDATION
MKD. - MARKED
THK. - THICK
BOTTOM REINFORCEMENT (B) - - - - - - -
TOP REINFORCEMENT (T) - ———
R.C. - REINFORCED CONCRETE
P.C.C - PLAIN CEMENT CONCRETE
FDN. - FOUNDATION
DET. - DETAIL
COL. - COLUMN
DIA. - DIAMETER

NOTES:-

1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS AND CO-ORDINATES ARE IN METRES UNLESS OTHERWISE STATED.
2. GRADE OF CONCRETE SHALL BE C35 (35MPa) FOR FOUNDATION & C15 (15MPa) FOR BLINDING CONCRETE.
3. GRADE OF REINFORCEMENT SHALL BE DEFORMED BAR 420 MPa (GRADE 60) - ASTM A615/A615M.
4. NET SAFE BEARING CAPACITY OF SOIL AT BOTTOM OF FOUNDATION CONSIDERED AS 450KN/ SQ. M
5. CLEAR COVER TO REINFORCEMENT SHALL BE FOUNDATIONS = 50 MM., COLUMNS = 50 MM.
6. FOR STANDARD REINFORCEMENT DETAIL & GENERAL NOTES FOR CIVIL WORKS REFER DRAWING NO. MD-216-1000-EG-CV-DED-1005 & 1001.
7. ALL CABLE TRAY SUPPORTS SHALL BE FIXED WITH CONCRETE COLUMNS BY ANCHOR FASTENERS OR INSERT PLATES.

REFERENCE DOCUMENTS		REV	DATE	REVISION DESCRIPTION	DRN	CHK	ENG	APP	EMP
DOCUMENT NUMBER									
MD-216-49PQ-EG-CV-GAD-1607	LAYOUT OF FOUNDATIONS	D01	01/12/2023	AS BUILT	AMJ	SJM	AVG	AG	
MD-216-1000-EG-ST-CRT-1001	CIVIL, STRUCTURAL & ARCHITECTURAL - DESIGN CRITERIA	C03	03/03/2022	ISSUED FOR CONSTRUCTION & REVISED AS MKD.	AMJ	SJM	AVG	AG	
		C02	17/11/2020	ISSUED FOR CONSTRUCTION AND REVISED AS MKD.	MNS	SJM	AVG	AG	
		C01	27/07/2020	ISSUED FOR CONSTRUCTION AND REVISED AS MKD.	ABS	SJM	AVG	AG	
		A01	19/06/2020	ISSUED FOR REFERENCE	ABS	SJM	AVG	AG	

RESERVED FOR VENDOR LOGO AND DRAWING NUMBER

LARSEN & TOUBRO

This drawing is the property of LARSEN & TOUBRO and must not be passed on to any person or body not authorized by us to receive it nor be copied or otherwise made use either in full or in part by such person or body without our prior permission in writing.

Outotec

The content of these documents are the sole property of Outotec Oyj. Any rights not expressly granted herein are reserved. Reproduction, transfer or distribution of part or all of the contents in any form without prior written permission of Outotec is prohibited.

MA'ADEN معادن
Saudi Arabian Mining Company شركة التعدين العربية السعودية

This document and the information contained herein is Ma'aden proprietary know-how. This document or any part thereof should not be reproduced, stored in a retrieval system or transmitted by any means, electronic or otherwise, or divulged without prior written permission of Ma'aden.

LARSEN & TOUBRO DRAWING NUMBER	019045_950_C_G_24301_004	REVISION 4
OUTOTEC DRAWING NUMBER	900707__GAU01__WD01__MTL01__45022	DOCUMENT ID OU100684599 / REVISION 4
DRAWN	ABS	05/06/2020
CHECKED	SJM	18/06/2020
ENGINEER	AVG	16/06/2020
APPROVED	AG	19/06/2020
EMPLOYER		
SCALE	1:50, 1:20	A1

MANSOURAH - MASSARAH GOLD PROJECT
GENERAL ARRANGEMENT DRAWING
PROCESS PLANT SUBSTATION 03
DETAIL OF FOUNDATIONS

DRAWING NUMBER MD-216-49PQ-EG-CV-GAD-1608 REV D01